

भारत सरकार Government of India विद्युत मंत्रालय Ministry of Power केन्द्रीय विद्युत प्राधिकरण Central Electricity Authority विद्युत प्रणाली संचार विकास प्रभाग

Power System Communication Development Division

CEA Case No.: RAJ-737						
Induced Voltage (IV) Calculation for PTCC proposal of 400 kV S/C line on D/C tower from 400/33 kV AREH4L S/s at Badi Sid to 765/400/220 kV Bhadla-2 S/s (Length: 11.038 km) - regd.						
S. No	Reference No.	Dated				
(i)	AREH4L/Rajasthan/PTCC/2024/01	06.02.2024				
(ii)	AREH4L E-mail:	25.07.2024				
(iii)	AREH4L E-mail:	31.07.2024				
(iv)	BSNL: DET/PTCC/ND/DV-10388/Raj-1489 /2024-25	25.07.2024				
(v)	North Western Railway: SG/158/NWR/PTCC/954 (received vide	21.03.2024				
	AREH4L e-mail dated 25.07.2024)					
(vi)	Defense: B/46937/Sigs 7(b)/3720	01.05.2024				

The PTCC proposal submitted vide reference (i), (ii) and (iii) has been examined. The LF induction on communication circuits of North Western Railway with respect to details furnished vide above reference (v) has been computed. The voltage likely to be induced on paralleling communication circuits of North Western Railway under Single Line to Ground fault condition are enclosed at Annexure-I. The screening factors as applicable have been considered.

DET, PTCC (NZ), BSNL vide reference (iv) and DG Signals, MoD vide reference (vi) has given their NOC for charging the line.

EPR zone for the proposed substation is mentioned below:

Name of the proposed Substation	Half diagonal distance,	Fault Curre nt I	Resistance of Earth Mat, R	d (mts) at 430	d (mts) at 650	d (mts) at 7 kV	d (mts) at 10
	D/2 (mts)	(KA)	(ohms)	V	V		kV
400/33 kV	151.1	32.319	0.4382	4825	3141	155	63
AREH4L S/s at							
Badi Sid							

Taking above into consideration, necessary action for issuance of PTCC route approval may be taken under intimation to this office.

Chief Engineer

To,

1.	Divisional	BSNL, O/o GM (North), QA & Inspection Circle	
	Engineer (PTCC),	D-Tax Building, Eastern Court, Janpath	
	Northern Zone New Delhi-110001		
2.	GM (S&T), North	Headquarter Office, Room No. 136, 1st Floor, Near	
	Western Railway	Jawahar Circle, Jaipur – 302 017	
3.	M/s Adani		For
	Renewable	Adani Corporate House, Shantigram, Nr. Vaishnavi Devi	information
	Energy Holding	Circle, SG Highway, Khodiyar, Ahmedabad – 382 421	
	Four Limited		

ANNEXURE-I

Map Scale : 1 cm = 500 m

Total Length: 11.038 kms

S.R. Value : 2000 Ohm-cm

CEA Case No.: RAJ-737

Name of the Power line: 400 kV S/C line on D/C tower from 400/33 kV

AREH4L S/s at Badi Sid to 765/400/220 kV Bhadla-2 S/s

		Length of		Effective	
		Parallelis	Mutual	Fault	I.V
		m	Coupling	current	in
S.No.	Telecom. Details	in Km.	in Ohms.	in Amps.	Volts.

North Western Railway: SG/158/NWR/PTCC/954 Dated: 21.03.2024					
1	Bap to Sird	6.5	0.02222	17821	395
2	Sird to Nokhra	0.7	0.0023	11740	27