



सत्यमेव जयते

भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
केन्द्रीय विद्युत प्राधिकरण
Central Electricity Authority
विद्युत प्रणाली संचार विकास प्रभाग
Power System Communication Development
Division

Subject: - PTCC clearance for modification/diversion work of 400 kV D/C Jeypore-Gajuwaka Transmission Line due to construction of Raipur-Vishakhapatnam National Highway-Reg.

PGCIL vide letter no: SR1/Vizag/TL/NHAI-Diversion/PTCC dated: 29.07.2024 has requested to review requirement of PTCC NOC/clearance in respect of diversion/modification of existing 400 kV D/C Jeypore-Gajuwaka Transmission Line. PGCIL has informed that due to construction of Raipur-Vishakhapatnam National Highway, diversion is done between Tower No 482-485 and Tower No 499-510 resulting in maximum lateral diversion of 254 m.

In line with the information as provided by PGCIL, received reference has been examined and it is found that fresh PTCC approval is not required due to proposed modification/diversion of the existing 400 kV D/C Jeypore-Gajuwaka Transmission Line for diversion work between Tower No 482-485 and Tower No 499 – 510.

Chief Engineer

To,
Sr. General Manager
Powergrid, Vizag SR-1