



सत्यमेव जयते

भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
केन्द्रीय विद्युत प्राधिकरण
Central Electricity Authority
विद्युत प्रणाली संचार विकास प्रभाग
Power System Communication Development
Division

Subject: - PTCC clearance for modification/diversion work of 400 kV D/C Tiruvalam – Chittoor Transmission Line due to construction of Chittoor-Thatchur Highway -Reg.

PGCIL vide letter no: SRTA-1/CTR/TL/NHAI-Diversion/2024/TVLM-CTR/07 dated: 12.07.2024 and e-mail dated 01.08.2024 has requested to review requirement of PTCC NOC/clearance in respect of diversion/modification of existing 400 kV D/C Tiruvalam – Chittoor Transmission Line. PGCIL has informed that due to construction of Chittoor-Thatchur Expressway Tower No 57 is dismantled and two towers are erected in its vicinity without any lateral diversion.

In line with the information as provided by PGCIL, received reference has been examined and it is found that fresh PTCC approval is not required due to proposed modification/diversion of the existing 400 kV D/C Tiruvalam – Chittoor Transmission Line at Tower No 57.

Chief Engineer

To,
General Manager
Powergrid, Nellore