



भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
केन्द्रीय विद्युत प्राधिकरण
Central Electricity Authority
विद्युत प्रणाली संचार विकास प्रभाग
Power System Communication Development

Subject: - PTCC clearance for modification/diversion work of 400 kV S/C STPS - Ratangarh Transmission Line due to construction of Amritsar – Jamnagar highway under Bharatmala Project-regd.

Rajasthan Rajya Vidyut Prasaran Nigam Limited (RVPN) vide email dated 22.08.2024 and letter No. - RVPN/SE(T&C)/XEN()/RTGH/F./D. dated 22.08.2024 has requested to review requirement of fresh PTCC clearance/ NOC in respect of diversion/ modification of existing 400 kV S/C STPS - Ratangarh Transmission Line due to construction of new Amritsar - Jamnagar highway under Bharatmala Project.

RVPN vide above letter has informed that existing 04 Towers (TW-62, TW-63, TW-64 and TW-65) are dismantled and 05 new towers are erected (TW-62, TW-62X, TW-63, TW-64 and TW-65) resulting in a maximum lateral deviation of approx. 125 m from the existing route.

In line with the information submitted by RVPN received reference has been examined and it is found that fresh PTCC approval is not required due to proposed modification/ diversion of the existing 400 kV S/C STPS - Ratangarh Transmission Line.

Chief Engineer

To,
Superintending Engineer (T&C)
RVPN, Ratangarh
Email: se.tnc.ratangarh@RVPN.CO.IN