

भारत सरकार

Government of India विद्युत मंत्रालय

Ministry of Power केन्द्रीय विद्युत प्राधिकरण

Central Electricity Authority विद्युत प्रणाली संचार विकास प्रभाग

Power System Communication Development Division

CEA Ca	CEA Case No. : CHH-87					
Induced Voltage(IV) calculation for PTCC proposal of 400 kV D/c Raipur Pool to Dhamtari Transmission Line [Length-87.959 km] - Regd.						
S.	S. Reference No. Dated					
No						
(i)	PRPDTL: WR-I/Durg/TLC/PTCC/797	27.05.2024				
(ii)	PRPDTL: e-Mail	23.10.2024				
(iii)	BSNL: IC/MBI/PTCC/MP	10.10.2024				
(iv)	South East Central Railway: SECR/S&T/PTCC/TD/480	31.07.2024				
(v)	Defense: B/46937/Sigs7(b)/3876	23.09.2024				

The PTCC proposal submitted vide reference (i) & (ii) has been examined. The LF induction on block & telecom circuits of South East Central Railway with respect to details furnished vide above references (iv) has been computed. The voltages likely to be induced on paralleling block & telecom circuits of South East Central Railway under Single Line to Ground fault condition are enclosed at Annexure-I. The screening factors, as applicable, have been considered. DET-PTCC WZ,BSNL and DG Signals, MoD have issued No Objection Certificate (NOC) vide reference (iii) & (v) respectively.

In view of the above, PTCC route approval may be issued for the subject transmission line under intimation to this office.

Encl.: As above

Chief Engineer

To,

- 0,			
1.	Divisional Engineer	QA & Inspection circle,1st floor, D- wing,	
	(PTCC), Western	BSNL Bldg.,	
	Zone	Santa Cruz (West), Mumbai-400054	
2	GM (S&T)	2 nd Floor, Zonal HQ SECR	
۷.		Bilaspur	
3.	DGM, PRPDTL	O/o DGM PRPDTL	Copy for information.

CEA-PS-17-11(12)/113	/2024	I-PCD Division		
			Dhamdha, Durg	

Dhamdha, Durg

1/44092/2024

7

ANNEXURE-I

-Out of Parallelism-

CEA Case No.: CHH-87 Name of the Power line: 400 kV D/C Raipur Pool to Dhamtari Transmission Line.			Map Scale : 1 cm= 500 m Total Length : 87.959 km S.R. Value : 50000 Ohm-cm			
S.No.	Telecom. Details	Length of Parallelism in Km.	Mutual Coupling in Ohms.	Effective Fault current in Amps.	I.V in Volts.	
South E	ast Central Railway: SECR/S&T/PTCC/TD/480	Dated 31.0	07.2024			
	Affected Blocks &	Telecom Circuit	ts Details			
1	Durg R/s to Rasmara R/s	1.5	0.0048	16500	79	
2	Rasmara R/s to Murhipar R/s	3.0	0.006	17300	104	
3	Murhipar R/s to Parmal Kasa R/s	-Out of Parallelism-				
4	Durg R/s to Durg Link Block Station R/s	-Out of Parallelism-				
5	Durg Link Block Station R/s to Maroda R/s	-Out of Parallelism-				
6	Maroda R/s to Risama R/s	2.5	0.0047	15500	73	

Risama R/s to Gunderdehi R/s