

भारत सरकार Government of India विद्युत मंत्रालय Ministry of Power केन्द्रीय विद्युत प्राधिकरण Central Electricity Authority विद्युत प्रणाली संचार विकास प्रभाग

Power System Communication Development Division

CEA Case No.: KNK-1048 Induced Voltage (IV) Calculation for PTCC proposal of 220 kV S/C line on D/C and M/C towers from the proposed 220/33 kV Pooling Substation, Huyilagola village, Gadag to proposed 400/220 kV Gadag PS (ISTS) (Length: 38.16 km)					
S. No	Reference No.	Dated			
(i)	RSPPL/RTC-W3/220 kV/PTCC/AUG/23-24/E/001	03.08.2023			
(ii)	RSPPL E-mail:	06.08.2024			
(iii)	BSNL: SR-PTCC/SKT6106/7	06.08.2024			
(iv)	South Western Railway: SG/SWR/PTCC/RENEW/2642	08.02.2024			
(v)	Defense: B/46937/Sigs7(b)/3493	19.10.2023			

The PTCC proposal submitted vide reference (i) and (ii) has been examined. The LF induction on communication circuits of South Western Railway with respect to details furnished vide above reference (iv) have been computed. The voltage likely to be induced on paralleling communication cables of South Western Railway under Single Line to Ground fault condition are enclosed at Annexure-I. The screening factors as applicable have been considered.

DET, PTCC (SZ), BSNL vide reference (iii) and DG Signals, MoD vide above reference (v) (enclosed as Annexure-II) have issued their No Objection Certificate (NOC) for charging of the line.

EPR Zones for proposed substations are mentioned below:

Name of the	Half	Fault	Resistance	d (mts)	d (mts)	d (mts)	d (mts)
proposed SS	Diagonal	Curren	of	at 430	at 650 V	at 7 kV	at 10
	Distance,	t, I	earthmat,	V			kV
	D/2 (mts)	(kA)	R (Ohms)				
220/33 kV Pooling	97.5	28	0.1079	588	356	NA	NA
Substation,							
Huyilagola village,							
Gadag							
400/220 kV Gadag	116	47.88	0.11403	1357	858	NA	NA
PS (ISTS)							

Taking the above into consideration, necessary action for issuance of PTCC route approval may be taken under intimation to this office.

Encl.: As above

Chief Engineer

To,

1.	Divisional Engineer	O/o CGM, QA & Inspection circle, 2 nd	
(PTCC)		Floor, Sanchar complex, WMS compound,	
		Jayanagar, 5 th block, 9 th main, 47 th cross,	
		Bengaluru- 560 041	
2	GM (S&T), South	South Western Railway Headquarter, Rail	
۷.	Western Railway	Soudha, Hubbali – 580 023	
	M/s Renew Solar	Renew Hub, Commercial Block-1, Zone-6,	
3.	Power Private	Golf Course Road, DLF City Phase-V,	Copy for information
	Limited	Gurugram	

ANNEXURE-I

CEA Case No.: KNK-1048 Name of the Power line: 220 kV S/C line on D/C and M/C towers from the proposed 220/33 kV Pooling Substation, Huyilagola village, Gadag to proposed 400/220 kV Gadag PS (ISTS)		Map Scale : 1 cm= 500 m Total Length : 38.16 km S.R. Value : 2000 Ohm-cm			
S.No.	Telecom. Details	Length of Parallelis m in Km.	Mutual Coupling in Ohms.	Effective Fault current in Amps.	I.V in Volts.
	South Western Railway: SG/SWI	 R/PTCC/RENEW/2	2642 Date: 08.0)2.2024	
1	HBL to BLR		Out of parallelism		

Tele: 23019746

Directorate General of Signals

Signals - 7 KNK-1049 General Staff Branch Integrated HQ of MoD, (Army) DHQ PO, New Delhi - 110011

Oct 2023

B/46937/Sigs 7(b)/3493

Senior Manager, Projects ReNew Solar Power Private Limited ReNew Hub, Commercial Block-1, Zone-6 Golf Course Road, DLF City Phase-V Gurugram-122009

PTCC PROPOSAL FOR CONSTRUCTION OF RENEW SOLAR POWER PVT LTD 220KV S/C LINE ON D/C AND M/C TOWERS FROM THE PROPOSED 220/33KV POOLING SUBSTATION, HUYILAGOLA VILLAGE, GADAG TALUK, GADAG DISTRICT TO THE PROPOSED 400/220KV GADAG PS (ISTS), GULAGULLI VILLAGE, GADAG DISTRICT

- Refer your letter No RSPPL/RTC-W2/220kV/PTCC/AUG/23-24/E/001 15 Aug 2023 (copy att).
- No Objection Certificate (NOC) is accorded based on inputs provided as per Map sheets received vide your letter mentioned above.
- Documents alongwith map sheets (in original) are returned herewith for your further necessary action.

SP Choval)

Lieutenant Colonel

General Staff Officer Grade 1 (Communication) for Additional Director General (Telecommunication)

Enclosures: As above

Copy to :-

The Director (PTCC), CEA

Power Communication Development Division NRPC Complex, 18-A Shaheed Jeet Singh Marg

Katwaria Sarai, New Delhi - 110016

for information

The DET(PTCC), Northern Zone Bharat Sanchar Nigam Limited O/o PGM (North), QA & Inspection Circle,

D-Tax Building, Eastern Court, Janpath

New Delhi-110001

Central Electricity Authority

Divis

Is enamine & pt