

# भारत सरकार Government of India विद्युत मंत्रालय Ministry of Power केन्द्रीय विद्युत प्राधिकरण Central Electricity Authority विद्युत प्रणाली संचार विकास प्रभाग

### Power System Communication Development Division \*\*\*\*\*\*\*

CEA Case No.: KNK-1071						
Induced Voltage (IV) Calculation for PTCC proposal of 33 kV (partially S/C and partially D/C) Feeder-11 from 220/33 kV Pooling Substation, Thondihala Koppal to Double Pole yard Tapping						
Point AL-08 of RSOPL Peak Power Wind farm. (Length: S/C- 6.98 kms + D/C-4.95 kms).						
S. No	Reference No.	Dated				
(i)	RSOPL/Peak power/33kV/PTCC/24-25/017	18.01.2024				
(ii)	RSOPL E-mail:	10.07.2024				
(iii)	BSNL: SR-PTCC/SKT5930/2	26.06.2024				
(iv)	South Western Railway: SG/SWR/PTCC/KNK1071/2726	07.06.2024				
(v)	Defense: B/46937/Sigs 7(b)/3726	16.05.2024				

The PTCC proposal submitted vide reference (i) and (ii) has been examined.

DET (PTCC), SZ, BSNL vide reference (iii), PCSTE, SWR vide reference (iv) and DG Signals, MoD vide reference (v) has given their NOC for charging the line.

EPR Zones for proposed substations are mentioned below.

Name of the proposed SS	Half Diagonal	Fault Current,	Resistance of earthmat,	d (mts) at 430	d (mts) at 650	d (mts) at 7 kV	d (mts) at 10 kV
Post seed and	Distance, D/2 (mts)	I (kA)	R (Ohms)	V	V		
220/33 kV Pooling Substation, Thondihala Koppal	88.46	24	0.1201	505	304	NA	NA
33 kV Feeder-11 Double Pole yard Tapping Point AL-08	6.01	6.2	0.469	35	21	NA	NA

Taking above into consideration, necessary action for issuance of PTCC route approval may be taken under intimation to this office.

Encl.: As above

#### **Chief Engineer**

#### To,

1.	Divisional Engineer	O/o CGM, QA&I circle,	
	(PTCC), Southern Zone	2 <sup>nd</sup> floor, Sanchar Complex, WMS	
		Compound, Jayanagar, 5 <sup>th</sup> block, 9 <sup>th</sup> main,	
		47 <sup>th</sup> cross, Bengaluru- 560 041	
	M/s ReNew Surya Ojas Private Limited	ReNew Hub, Commercial Block-1, Zone-6,	
, ,		Golf Course Road, DLF City Phase-V,	Copy for information
		Gurugram – 122 009	

Directorate General of Signals
Signals - 7
General Staff Branch KNK-1071
Integrated HQ of MoD, (Army)
DHQ PO, New Delhi - 110011

6 May 2024

B/46937/Sigs 7(b)/3726

Senior Manager, Projects
ReNew Surya Ojas Private Limited
Corporate Off: ReNew Hub, Commercial Block-1
Zone-6, Golf Course Road, DLF City Phase-V
Gurugram-122009

## PTCC PROPOSAL FOR 33KV SCOH LINE (33KV FEEDER NO 11) FROM THE 220/33 KV POOLING S/S AT THONDIHALA VILLAGE, YELBURGA TALUK, KOPPAL DISTRICT TO PROPOSED RENEW (RSOPL) WIND 33KV WIND POWER DOUBLE POLE YARD TAPPING POINT AL-08

- 1. Refer your letter No RSOPL/Peak Power/33kV/PTCC/MoD/24-25/E/041 dt 03 Feb 2024 (copy att).
- 2. No Objection Certificate (NOC) is accorded based on inputs provided as per Map sheet received vide your letter mentioned above.
- 3. Documents alongwith map sheets (in original) are returned herewith for your further necessary action.

(Puneet Lakhanpal)
Lieutenant Colonel
General Staff Officer Grade 1 (Communication)
for Additional Director General (Telecommunication)

Enclosures : As above Copy to :-

The Divisional Engineer (PTCC)
'D' Wing, 3<sup>rd</sup> Floor, Admn Bdg
Telecom Complex,
Juhu Tara Road,
Santracruz West, Mumbai – 400054

Chief Engineer, PSCD Division Central Electricity Authority Room No 702 (North Wing) Sewa Bhawan, R.K. Puram, Sector-1 New Delhi-110066

The DET(PTCC), Northern Zone Bharat Sanchar Nigam Limited O/o PGM (North), QA & Inspection Circle, D-Tax Building, Eastern Court, Janpath New Delhi-110001 - for information

Central Electricity Authority PCD Division

sh Anch (DD)