

# भारत सरकार Government of India विद्युत मंत्रालय Ministry of Power केन्द्रीय विद्युत प्राधिकरण Central Electricity Authority विद्युत प्रणाली संचार विकास प्रभाग

### Power System Communication Development Division

CEA Case No.: KNK-1114 Induced Voltage (IV) Calculation for PTCC proposal of 33 kV Feeder-2 (partially S/C and partially D/C) from the 220/33 kV Pooling Substation of M/s RSRPL at Huyilagola village, Gadag to 33 kV wind power Double pole yard tapping point RNPK-47 of RSRPL (Length: 4.1 kms D/C + 10.8 kms S/C: Total = 14.9 kms). **Dated** S. No Reference No. RSRPL/RTC1-W2/33 kV/PTCC/CEA/24-25/E/074 22.04.2024 (i) BSNL: SR-PTCC/SKT6192/7 20.09.2024 (ii) (iii) South Western Railway: SG/SWR/PTCC/KNK1114/2747 05.07.2024 Defense: B/46937/Sigs 7(b)/3935 22.07.2024 (iv)

The PTCC proposal submitted vide reference (i) has been examined. DET, PTCC (SZ), BSNL vide reference (ii), GM (S&T), South Western Railway vide reference (iii) and DG Signals, MoD vide above reference (iv) (enclosed as Annexure-I) have issued their No Objection Certificate (NOC) for charging of the line.

EPR Zones for proposed substations are mentioned below.

Name of the proposed SS	Half Diagonal Distance, D/2 (mts)	Fault Current, I (kA)	Resistanc e of earthmat, R (Ohms)	d (mts) at 430 V	d (mts) at 650 V	d (mts) at 7 kV	d (mts) at 10 kV
220/33kV Pooling Substation of M/s RSRPL at Huyilagola village, Gadag	97.5	24	0.2005	994	624	NA	NA
33kV wind power Double pole yard tapping point RNPK- 47	14.5	25	0.1143	82	49	NA	NA

Taking above into consideration, necessary action for issuance of PTCC route approval (RAC) may be taken under intimation to this office.

As per the decision taken in 111<sup>th</sup> and 112<sup>th</sup> CLPTCC meeting, necessary instructions for "Deemed Energization approval" shall be specified while issuing RAC.

Encl.: As above

**Chief Engineer** 

#### To,

1.	Divisional Engineer	O/o CGM, QA&I circle,		
	(PTCC), Southern Zone	2 <sup>nd</sup> floor, Sanchar Complex, WMS Compound,		
		Jayanagar, 5 <sup>th</sup> block, 9 <sup>th</sup> main, 47 <sup>th</sup> cross,		
		Bengaluru- 560 041		
2	M/s ReNew Surya	ReNew Hub, Commercial Block-1, Zone-6,	Copy	for
۷.	Roshni Private Limited	Golf Course Road, Gurugram – 122 009	information	

1/43397/2024

Directorate General of Signals

Signals 7

General Staff Branch KNK-III

Integrated HQ of MoD, (Army)

DHQ PO, New Delhi – 110011

B/46937/Sigs 7(b)/3935/

Jul 2024

Senior Manager, Projects ReNew Surya Roshni Private Limited Corporate Off: ReNew Hub, Commercial Block-1 Zone-6, Golf Course Road DLF City Phase-V, Gurugram-122009

## 33KV FEEDER NO-2 PTCC PROPOSAL (PARTIALLY SC AND PARTIALLY DC LINE) FROM THE 220/33KV POOLING S/S AT HUYILAGOLA VILLAGE TO PROPOSED RENEW (RSRPL) WIND 33KV WIND POWER DOUBLE POLE YARD TAPPING POINT RNPK-47

- 1. Refer your letter No. RSRPL/RTC1-W2/33 KV/PTCC/BSNL/24-25/E/094 dt 06 May 2024 (copy att).
- 2. **No Objection Certificate (NOC) is accorded** based on inputs provided as per Map sheet received vide your letter mentioned above.

3. Documens alongwith map sheets (in original) are returned herewith for your further necessary action.

(Puneet Lakhanpal)
Lieutenant Colonel
General Staff Officer Grade 1 (Communication)
for Additional Director General (Telecommunication)

Enclosures : As above

#### Copy to :-

The Divisional Engineer (PTCC)
'D' Wing, 3<sup>rd</sup> Floor, Admn Bdg
Telecom Complex,
Juhu Tara Road,
Santracruz West, Mumbai – 400054

Chief Engineer, PSCD Division Central Electricity Authority Room No 702 (North Wing) Sewa Bhawan, R.K. Puram, Sector-1 New Delhi-110066

The DET(PTCC), Northern Zone

Bharat Sanchar Nigam Limited

Olo PGM (North), QA & Inspection Circle,

D-Tax Building, Eastern Court, Janpath

New Delhi-110001

- for information

केब्द्रीय किंद्रुत प्राधिकरण पी.सी.झे प्रभाग वरी संख्या <u>१</u>८० नांक ८०००