

# भारत सरकार Government of India विद्युत मंत्रालय Ministry of Power केन्द्रीय विद्युत प्राधिकरण Central Electricity Authority विद्युत प्रणाली संचार विकास प्रभाग Power System Communication Development

\*\*\*\*\*

CEA Case No.: TNG-149						
Induced Voltage (IV) calculation in respect of PTCC proposal of 220KV DC line from Shadnagar SS to M/s MCIPL (Length: 8.01 km O/H + 0.25 km UG) - regd.						
S. No	Reference No.	Dated				
(i)	TCTL: CE(Const)/SE(Const-I)/DE-II/ADE-	06.04.2024				
	I/F.Microsoft,Makeguda/D.No.17/24					
(ii)	BSNL: SR-PTCC/STS5997/7	27.07.2024				
(iii)	South Central Railway: SG.85/4/3/PTCC/SCR/2024-25/TS 7 RTD	19.07.2024				
(iv)	Defense: B/46937/Sigs 7(b)/3872	16.07.2024				

The PTCC proposal submitted vide above reference (i) has been examined. The LF induction on Block and Telecom circuits of South Central Railway with respect to details furnished vide above reference (iii) has been computed. The voltage likely to be induced on paralleling Block and Telecom circuits of South Central Railway under Single Line to Ground fault condition are enclosed at Annexure-I. The screening factors as applicable have been considered. DET, BSNL (Bangalore) has given NOC vide above reference (ii).

DG Signals, MoD have issued No Objection Certificate (NOC) vide reference (iv) (enclosed as Annexure II)

EPR Zones for proposed substations are mentioned below

El R Zones for proposed substations are mentioned below.							
Name of the	Half	Fault	Resistance	d (mts)	d (mts)	d (mts)	d (mts)
proposed SS	Diagonal	Current, I	of earthmat,	at 430 V	at 650	at 7 kV	at 10
	Distance,	(kA)	R (Ohms)		V		kV
	D/2 (mts)						
220kV	87.96	28	0.5	2776	1807	88	35
Shadnagar SS							
M/s MCIPL,	53.5	28	0.86	2943	1928	131	75
Makeguda							

As per the details submitted by BSNL vide above reference (ii), no telecom exchanges are lying in the EPR zone of the proposed substation.

Taking above into consideration, necessary action for issuance of PTCC route approval may be taken under intimation to this office.

Encl.: As above

**Chief Engineer** 

## To,

1.	Divisional Engineer	BSNL, Inspection Circle, 2nd Floor, Sanchar Complex, WMS			
	(PTCC), Southern Zone	Compound, Jayanagar 5th Block, 9th Main, 47th Cross			
		,Bangalore-			
		560041			
2.	General Manager (S&T)	South Central Railway, O/o PCSTE, 7 <sup>th</sup> floor, Rail Nilayam, Secunderabad - 500025			
3.	Chief Engineer Construction	TSTRANSCO, Vidyut Soudha, Hyderabad-500082			

### **ANNEXURE-I**

Map Scale : 1 cm = 500 mCEA Case No.: TNG-149 **Total Length:** 8.01 km O/H + 0.25 kmUG Name of the Power line: 220KV DC line from Shadnagar SS to M/s **MCIPL** S.R. Value: 25000 Ohm-cm Length of **Effective** Mutual I.V Parallelis **Fault** m Coupling current in S.No. Telecom. Details in Km. in Ohms. Volts. in Amps. South Central Railway Letter No.- SG.85/4/3/PTCC/SCR/2024-25/TS 7 RTD Date: 19.07.2024 Timmapur (TMX) – Shadnagar (SHNR) 1 7.6 0.016 16352 262 2 Shadnagar (SHNR) – Balanagar (BABR) Out of Parallelism

### Annexure II

Directorate General of Signals
Signals 7
General Staff Branch
Integrated HQ of MoD, (Army)
DHQ PO, New Delhi – 110011

B/46937/Sigs 7(b)/3872/

Chief Engineer, Construction
Transmission Corporation of Telangana Limited
Vidyut Soudha,
Hyderabad – 500 082

/ Jul 2024

# ERECTION OF 220KV DC LINE FROM 220KV SS SHADNAGAR TO M/S MICROSOFT CORPORATION (INDIA) PVT LTD AT MEKAGUDA FOR A LENGTH OF 8.26 KM ( 8.010KM OF OH LINE AND 0.25KM OF UNDERGROUND CABLE) IN RANGAREDDY DISTRICT – PTCC PROPOSALS-FORWARDEDREGARDING

- 1. Refer your letter No CE(Const)/SE(Const-1)/DE-II/ADE-I/F.Microsoft, Mekaguda/D.No 17/24 dt 06 Apr 2024.
- 2. **No Objection Certificate (NOC) is accorded** based on inputs provided as per Map sheet received vide your letter mentioned above.
- 3. Documens alongwith map sheets (in original) are returned herewith for your further necessary action.

(Puneet Lakhanpal)
Lieutenant Colonel
General Staff Officer Grade 1 (Communication)
for Additional Director General (Telecommunication)

Enclosures : As above

# Copy to :-

Chief Engineer, PSCD Division Central Electricity Authority Room No 702 (North Wing) Sewa Bhawan, R.K. Puram, Sector-1 New Delhi-110066

The DET(PTCC), Northern Zone Bharat Sanchar Nigam Limited O/o PGM (North), QA & Inspection Circle, D-Tax Building, Eastern Court, Janpath New Delhi-110001 - for information