



सत्यमेव जयते

भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
केन्द्रीय विद्युत प्राधिकरण
Central Electricity Authority
विद्युत प्रणाली संचार विकास प्रभाग
Power System Communication Development
Division

CEA Case No. : UP-650		
Induced Voltage(IV) calculation for PTCC proposal of 400 kV D/C Garautha - Talbehat Transmission Line [Length-129.387 km] - Regd.		
S. No	Reference No.	Dated
(i)	UPPTCL: 943/ETDJ	05.06.2024
(ii)	BSNL: DET/PTCC/ND/DV-10409/UP-1201/2024-2025	09.10.2024
(iii)	Northern Central Railway: NCR/S&T/2074/Telecom/PTCC(Part-2)	18.09.2024
(iv)	Defense: B/46937/Sigs7(b)/3983	06.09.2024

The PTCC proposal submitted vide reference (i) has been examined. The LF induction on block & telecom circuits of North Central Railway with respect to details furnished vide above references (iii) has been computed. The voltages likely to be induced on paralleling block & telecom circuits of North Central Railway under Single Line to Ground fault condition are enclosed at Annexure-I. The screening factors, as applicable, have been considered. DET-PTCC NZ,BSNL and DG Signals, MoD have issued No Objection Certificate (NOC) vide reference (ii) & (iv) respectively.

EPR zone for 400 kV proposed S/S is mentioned below:

Name of the proposed Substation	Half diagonal distance , D/2 (mts)	Fault Current I (KA)	Resistance of Earth Mat, R (ohms)	d (mts) at 430 V	d (mts) at 650 V	d (mts) at 7kV	d (mts) at 10kV
400 kV Garautha S/s	188	37.8	0.07	969	577	N.A	N.A
400 kV Talbehat S/s	339	44.1	0.069	2060	1248	N.A	N.A

As per the Telecom Details submitted by BSNL vide above reference (ii), no telephone exchange of BSNL is falling within the EPR zone of proposed Substation.

Taking above into consideration, necessary action for issuance of PTCC route approval shall be taken under intimation to this office.

As per the decision taken in 111th and 112th CLPTCC meeting, necessary instructions for "Deemed Energization approval" shall be specified while issuing RAC.

Encl.: As above

Chief Engineer

To,

1.	Divisional Engineer (PTCC), Northern Zone	BSNL, O/o PGM(North), QA & Inspection Circle D-Tax Building, Eastern Court, Janpath New Delhi-110001	
2.	GM (S&T)	HQ Office, S&T Branch North Central Railway Prayagraj	Annexure-I
3.	Executive Engineer UPPTCL	ETD 132 kV S/s Hasari, Jhansi	Copy for information.

ANNEXURE-I

CEA Case No.: UP-650 Name of the Power line: 400 kV D/C Garautha - Talbehat Transmission Line.			Map Scale : 1 cm= 500 m Total Length : 129.387 km S.R. Value : 7500 Ohm-cm		
S.No.	Telecom. Details	Length of Parallelism in Km.	Mutual Coupling in Ohms.	Effective Fault current in Amps.	I.V in Volts.
Northern Central Railway:NCR/S&T/2074/Telecom/PTCC(Part-2) Dated 18.09.2024					
<u>Affected Blocks & Telecom Circuits Details</u>					
1	Ranipur Road R/s to Mauranipur R/s	-Out of Parallelism-			
2	Mauranipur R/s to Rora R/s	5.0	0.0085	15300	130
3	Rora R/s to Harpalpur R/s	1.0	0.00045	15500	7