



सत्यमेव जयते

भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
केन्द्रीय विद्युत प्राधिकरण
Central Electricity Authority
विद्युत प्रणाली संचार विकास प्रभाग
Power System Communication Development Division

CEA Case No. : MRA-1259		
Induced Voltage calculation for PTCC proposal for 33 kV S/C Feeder-05 from 220/33 kV Pooling Substation of M/s RG(MO)PL at Jaulala village, Beed to 33 kV Wind Power Double pole yard tapping point P-51 N1 of RG(MO)PL (Length: 27.42 kms).		
S. No	Reference No.	Dated
(i)	RG(MO)PL/Patoda CTU/33kV line/PTCC/CEA/24-25/E/107	04.05.2024
(ii)	BSNL: IC/MBI/PTCC/MRA-2639/03	06.11.2024
(iii)	Central Railway: N.153/PTCC/33kV/MAH-882	11.07.2024
(iv)	Defense: B/46937/Sigs 7(b)/3950	16.07.2024

The PTCC proposal submitted vide reference (i) has been examined. DET (PTCC), WZ, BSNL vide reference (ii), GM (S&T), Central Railway vide reference (iii) and DG Signals, MoD vide reference (iv) have issued No Objection Certificate (NOC) for charging of the line.

EPR zone for the proposed substation is mentioned below:

Name of the proposed Substation	Half diagonal distance , D/2 (mts)	Fault Current I (KA)	Resistance of Earth Mat, R (ohms)	d (mts) at 430 V	d (mts) at 650 V	d (mts) at 7kV	d (mts) at 10kV
220/33 kV Pooling Substation of M/s RG(MO)PL at Jaulala village, Beed	78.5	28	0.1079	473	286	NA	NA
33 kV Wind Power Double pole yard tapping point	14.5	15	0.1143	43	24	NA	NA

Taking above into consideration, necessary action for issuance of PTCC route approval (RAC) shall be taken under intimation to this office in the stipulated period as specified in PTCC Manual and subsequent CLPTCC meetings.

As per the decision taken in 111th and 112th CLPTCC meeting, necessary instructions for “Deemed Energization approval” shall be specified while issuing RAC.

Chief Engineer

To,

1.	Divisional Engineer (PTCC), Western Zone	QA & Inspection circle, 1 st floor, D- wing, BSNL Admin Bldg., Junu Tara Road, Santacruz (West), Mumbai-400054	
2.	M/s ReNew Green (MHP One) Private Limited	ReNew Hub, Commercial Block-1, Zone-6, Golf Course Road, DLF City, Phase-V, Gurugram	Copy for information