

भारत सरकार Government of India विद्युत मंत्रालय Ministry of Power केन्द्रीय विद्युत प्राधिकरण Central Electricity Authority विद्युत संचार विकास प्रभाग

Power Communication Development Division

CEA Case No.: MRA-1281				
Induced Voltage (IV)calculation for PTCC proposal of 220 kV D/C Nagewadi - Bhokardhan				
Transmission Line[Length – 45.03 km] – Regd.				
S.	Reference No. Dated			
No				
(i)	MSETCL: MSETCL/CO/PS/PTCC/In/B-606/No05822	26.08.2024		
(ii)	BSNL: IC/MBI/PTCC/MRA-2677/03	27.11.2024		
(iii)	South Central Railway: SG.85/4/3/PTCC/2024-25/SCRMH09RTD	09.12.2024		
(iv)	Defense: B/46937/Sigs-7(b)/4146	06.11.2024		

The PTCC proposal submitted vide reference (i) has been examined. The LF induction on Block and Telecom circuits of South Central Railway with respect to details furnished vide above reference(iii)has been computed. The voltage likely to be induced on paralleling Block and Telecom circuits of South Central Railway under Single Line to Ground fault condition are enclosed at Annexure-I.The screening factors as applicable have been considered. DET-PTCC, BSNL WZ and DG Signals, MoD has issued No Objection Certificate (NOC) vide reference (ii) & (iv) respectively.

Taking above into consideration, necessary action regarding issuance of PTCC approval for the subject cited transmission line may be taken under intimation to this office.

Chief Engineer

To,

1.	Divisional QA & Inspection circle,		
	Engineer (PTCC),	1st floor, D- wing, BSNL Admin Bldg.,	
	Western Zone	Junu Tara Road, Santacruz (West),	
		Mumbai-400054	
2.	GM (S&T)	South Central Railway	
		Secunderabad	
	Chief Engineer	O/o Chief Engineer	
3.	(Proj. Scheme	MSETCL, Mumbai	Copy for information.
	Dept.)		Copy for information.
	MSETCL		

ANNEXURE-I

CEA Case No.: MRA-1281

Map Scale : 1 cm= 500 m

Total Length : 45.03 km

Name of the Power line: 220 kV D/C Nagewadi - Bhokardhan

Transmission Line. S.R. Value: 5000 Ohm-cm

				Effective	
		Length of	Mutual	Fault	I.V
S.No.	Telecom. Details	Parallelism	Coupling	current	in
		in Km.	in Ohms.	in Amps.	Volts.

South Central Railway: SG.85/4/3/PTCC/2024-25/SCRMH09RTD Dated 09.12.2024					
Affected Blocks & Telecom Circuits Details					
1	Badnapur - Dinagaon	-Out of Parallelism-			
2	Dinagaon - Jalna	-Out of Parallelism-			
3	Jalna - Sarwari	-Out of Parallelism-			