

भारत सरकार Government of India विद्युत मंत्रालय Ministry of Power केन्द्रीय विद्युत प्राधिकरण Central Electricity Authority विद्युत प्रणाली संचार विकास प्रभाग Power System Communication Development Division

CEA Case No.: NAG-01							
Induced Voltage(IV) calculation for PTCC proposal of 220 kV S/C New Kohima -							
Mokokchung Transmission Line [Length-86.54 km] - Regd.							
S.	Reference No.	Dated					
No	DOCH MEDGIDANICO /EWA 06/202	00.00.2021					
(i)	PGCIL: NERSIP/MKG/TW-06/303	09.08.2021					
(ii)	PGCIL: e-Mail	12.12.2024					
(iii)	BSNL: DET/ER/PTCC/EML160820213447/CEA/01	26.11.2024					
(iv)	NEFR: N/146/2/10Pt.VI(TC)	28.09.2021					
(v)	Defense: B/46937/Sigs7(b)/	18.10.2024					

The PTCC proposal submitted vide reference (i) & (ii) has been examined. The LF induction on block & telecom circuits of Defense establishment with respect to details furnished vide above references (v) has been computed. The voltages likely to be induced on paralleling block & telecom circuits of Defense under Single Line to Ground fault condition are enclosed at Annexure-I. The screening factors, as applicable, have been considered. DET-PTCC EZ,BSNL and GM S&T, NEFR has issued No Objection Certificate (NOC) vide reference (iii) & (iv) respectively.

Taking above into consideration, necessary action regarding issuance of PTCC approval for the subject cited transmission line may be taken under intimation to this office.

Chief Engineer

To,

1.	Divisional	BSNL, O/o QA & Inspection Circle	
	Engineer (PTCC),	QA Bhawan, EP-GP Block	
	Eastern Zone	Sector-V, Salt lake, Kolkata	
	Director General	General Staff Branch, Integrated HQ,	
2.	of Signals	MoD (army), Sena Bhawan, DHQ,	Annexure-I
		PO, New Delhi- 110 105	
3	Sr. GM, NERSIP	NERTS, 220/132 kV Mokokchung GIS	
		Mokokchung, Nagaland	

ANNEXURE-I

CEA Case No.: NAG-01 Name of the Power line: 220 kV S/C New Kohima - Mokokchung Transmission Line			Map Scale : 1 cm= 500 m Total Length 86.54 km S.R. Value : 7500 Ohm-cm					
S.No.	Telecom. Details	Length of Parallelism in Km.	Mutual Coupling in Ohms.	Effective Fault current in Amps.	I.V in Volts.			
Defense Letter No : B/46937/Sigs7(b)/ Dated 18.10.2024								
Affected Blocks & Telecom Circuits Details								
1	Army Camp Mokokchung Note: Camp closed	-Out of Parallelism-						
2	Tseminyu Camp Note: Camp closed	1.5	0.001	14500	15			
3	Zadima Camp Note: Camp closed	1.0	0.0028	22400	63			