

## भारत सरकार Government of India विद्युत मंत्रालय Ministry of Power केन्द्रीय विद्युत प्राधिकरण Central Electricity Authority विद्युत प्रणाली संचार विकास प्रभाग

Power System Communication Development Division

\*\*\*\*\*

CEA Case No.: UP-660					
Induced Voltage (IV) calculation for PTCC proposal of 220 kV S/C Birdha to Lalitpur					
Transmission Line on D/C Tower [Length-27.7 km] - Regd.					
S.	Reference No.	Dated			
No					
(i)	UPPTCL: 1314/ETD-(J)	21.08.2024			
(ii)	BSNL: DE/PTCC/NZ/ BSNL-TD/DV-10458/UP-1215/2024-2025/	22.01.2025			
(iii)	North Central Railway: NCR/S&T/2074/Telecom/PTCC (Part-2)	20.09.2024			
(iv)	Defense: B/46937/Sigs7(b)/4113	06.11.2024			

The PTCC proposal submitted vide reference (i) has been examined. The LF induction on block & telecom circuits of North Central Railway with respect to details furnished vide above references (iii) has been computed. The voltages likely to be induced on paralleling block & telecom circuits of North Central Railway under Single Line to Ground fault condition are enclosed at Annexure-I. The screening factors, as applicable, have been considered. DET-PTCC NZ,BSNL and DG Signals, MoD have issued No Objection Certificate (NOC) vide reference (ii) & (iv) respectively.

EPR zone for 220 kV proposed S/S is mentioned below:

Name of the proposed Substation	Half diagonal distance , D/2 (mts)	Fault Current I (KA)	Resistance of Earth Mat, R (ohms)	d (mts) at 430 V	d (mts) at 650 V	d (mts) at 7kV	d (mts) at 10kV
220 kV Birdha S/s	105	24	0.093	440	256	N.A	N.A

As per the Telecom Details submitted by BSNL vide above reference (ii), no telephone exchange of BSNL is falling within the EPR zone of proposed Substation.

Taking above into consideration, necessary action for issuance of PTCC route approval (RAC) shall be taken under intimation to this office in the stipulated period as specified in PTCC Manual and subsequent CLPTCC meetings.

**Chief Engineer** 

## To,

1.	Divisional	BSNL, O/o PGM(North), QA & Inspection	
	Engineer (PTCC),	Circle	
	Northern Zone	D-Tax Building, Eastern Court, Janpath	
		New Delhi-110001	
2	GM (S&T)	North Central Railway	
۷.		HQ (S &T) Branch, Prayagraj	
2	Executive Engineer	ETD - UPPTCL	Conv. for information
3.	UPPTCL	132 kV S/s Hasari, Jhansi	Copy for information.

## ANNEXURE-I

CEA Case No.: UP-660  Name of the Power line: 220 kV S/C Birdha to Lalitpur Transmission Line on D/C Tower.		Map Scale : 1 cm= 500 m  Total Length : 27.7 km  S.R. Value : 7500 Ohm-cm				
S.No.	Telecom. Details	Length of Parallelism in Km.	Mutual Coupling in Ohms.	Effective Fault current in Amps.	I.V in Volts.	
North Central Railway: NCR/S&T/2074/Telecom/PTCC (Part-2) Dated 20.09.2024						
Affected Blocks & Telecom Circuits Details						
1	Lalitpur R/s to Birari R/s	2.0	0.0036	20600	74	
2	Birari R/s to Udaipura R/s	-Out of Parallelism-				