



सत्यमेव जयते



भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
केन्द्रीय विद्युत प्राधिकरण
Central Electricity Authority
विद्युत प्रणाली संचार विकास प्रभाग
Power System Communication Development Division

CEA Case No. : RAJ-801		
Induced Voltage (IV) Calculation for PTCC proposal of 33 kV XLPE, AL Ar UG cable from proposed 220/33 kV 300 MW Solar Power PSS of M/s Gorbea Solar Private Limited at Village Badi Sid Tehsil Bap to proposed Solar Fd#05, 9.5 MVA 0.66/33 kV IDT at Village Badi Sid Tehsil Bap (Length: 1.97 kms)		
S. No	Reference No.	Dated
(i)	CEA/PTCC/Gorbea-33kV/Solar FD#05/2025	15.01.2025
(ii)	BSNL: RJJDPD-18/16/13/2021-ADMN AND PLG	27.06.2025
(iii)	North Western Railway: SG/158/NWR/PTCC/1054-1067	24.03.2025

The PTCC proposal submitted vide reference (i) has been examined. The LF induction on communication circuits of BSNL and North Western Railway with respect to details furnished vide above references (ii) and (iii) respectively has been computed. The voltage likely to be induced on paralleling communication cables of BSNL and North Western Railway under Single Line to Ground fault condition are enclosed at Annexure-I and Annexure-II respectively. The screening factors as applicable have been considered.

EPR Zones for proposed substations are mentioned below.

Name of the proposed SS	Half Diagonal Distance, D/2 (mts)	Fault Current, I (kA)	Resistance of earthmat, R (Ohms)	d (mts) at 430 V	d (mts) at 650 V	d (mts) at 7 kV	d (mts) at 10 kV
220/33 kV 300 MW Solar Power PSS of M/s GSPL at Village Badi Sid Tehsil Bap	74.32	25	0.392	1619	1046	30	NA
Solar Fd#05, 9.5 MVA 0.66/33 kV IDT	17.67	25	0.5	496	322	14	4

As per the details submitted by BSNL, No telephone exchanges are falling within the EPR zone of proposed substation.

Taking the above into consideration, the values of Induced Voltages may be examined, and further information may be sent to the undersigned, as per the procedure specified in the PTCC Manual 2010.

Encl.: As above

Chief Engineer

To,

1.	AGM (NWO), BSNL	O/o PGM BA Jodhpur Unit – AGM (NWO) Subhash Nagar, Pal Road, Jodhpur - 342008	
2.	GM (S&T), North Western Railway	Headquarter office, Room No. 136, First Floor, Near Jawahar Circle, Jaipur – 302017	
3.	M/s Gorbea Solar Private Limited	First Floor, D-2 Southern Park Building, Saket, New Delhi – 110 017	Copy for information

ANNEXURE-I

CEA Case No.: RAJ-801			Map Scale : 1 cm= 500 m		
Name of the Power line: 33 kV XLPE, AL Ar UG cable from proposed 220/33 kV 300 MW Solar Power PSS of M/s Gorbea Solar Private Limited at Village Badi Sid Tehsil Bap to proposed Solar Fd#05, 9.5 MVA 0.66/33 kV IDT at Village Badi Sid Tehsil Bap			Total Length : 1.97 km		
			S.R. Value : 5000 Ohm-cm		
S.No.	Telecom. Details	Length of Parallelism in Km.	Mutual Coupling in Ohms.	Effective Fault current in Amps.	I.V in Volts.
BSNL: RJJDPD-18/16/13/2021-ADMN AND PLG Date: 27.06.2025					
1	Kanshing ki Sid BTS		IV calculation is not required. Thus, BSNL letter is assumed as Deemed NOC		

ANNEXURE-II

CEA Case No.: RAJ-801			Map Scale : 1 cm= 500 m		
Name of the Power line: 33 kV XLPE, AL Ar UG cable from proposed 220/33 kV 300 MW Solar Power PSS of M/s Gorbea Solar Private Limited at Village Badi Sid Tehsil Bap to proposed Solar Fd#05, 9.5 MVA 0.66/33 kV IDT at Village Badi Sid Tehsil Bap			Total Length : 1.97 km		
			S.R. Value : 5000 Ohm-cm		
S.No.	Telecom. Details	Length of Parallelism in Km.	Mutual Coupling in Ohms.	Effective Fault current in Amps.	I.V in Volts.
North Western Railway: SG/158/NWR/PTCC/1054-1067 Date: 24.03.2025					
1	Nokhra to Sird		Out of IV consideration zone		
2	Sird to Bap		Out of IV consideration zone		