



सत्यमेव जयते



भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
केन्द्रीय विद्युत प्राधिकरण
Central Electricity Authority
विद्युत प्रणाली संचार विकास प्रभाग
Power System Communication Development Division

On behalf of
 Central Level Power & Telecommunication Co-ordination Committee

No: As assigned

Date: As assigned

Subject: Provisional Certificate of Approval for the Route of Power Line of M/s Adani Renewable Energy Thirty Seven Limited.

Provisional Route Approval Certificate for the following listed lines of M/s Adani Renewable Energy Thirty Seven Limited is annexed to this letter:

S.No.	Name
1	33 kV for Feeder No.0103 3C x 400 sqmm Al cable laid underground from 400/33 kV Substation (AGEL-PSS-5) to M/s Adani Renewable Energy Thirty Seven Limited Battery Energy Storage System (BESS) located near PSS-5, Khavda RE Park (Length: 1.130 kms)
2	33 kV for Feeder No.0203 3C x 400 sqmm Al cable laid underground from 400/33 kV Substation (AGEL-PSS-5) to M/s Adani Renewable Energy Thirty Seven Limited Battery Energy Storage System (BESS) located near PSS-5, Khavda RE Park (Length: 1.335 kms)
3	33 kV for Feeder No.0321 3C x 400 sqmm Al cable laid underground from 400/33 kV Substation (AGEL-PSS-5) to M/s Adani Renewable Energy Thirty Seven Limited Battery Energy Storage System (BESS) located near PSS-5, Khavda RE Park (Length: 1.095 kms)
4	33 kV for Feeder No.0421 3C x 400 sqmm Al cable laid underground from 400/33 kV Substation (AGEL-PSS-5) to M/s Adani Renewable Energy Thirty Seven Limited Battery Energy Storage System (BESS) located near PSS-5, Khavda RE Park (Length: 1.340 kms)
5	33 kV for Feeder No.0518 3C x 400 sqmm Al cable laid underground from 400/33 kV Substation (AGEL-PSS-5) to M/s Adani Renewable Energy Thirty Seven Limited Battery Energy Storage System (BESS) located near PSS-5, Khavda RE Park (Length: 1.230 kms)
6	33 kV for Feeder No.0618 3C x 400 sqmm Al cable laid underground from 400/33 kV Substation (AGEL-PSS-5) to M/s Adani Renewable Energy Thirty Seven Limited M/s Adani Renewable Energy Thirty Seven Limited Battery Energy Storage System (BESS) located near PSS-5, Khavda RE Park (Length: 1.465 kms)
7	33 kV for Feeder No.0706 3C x 400 sqmm Al cable laid underground from 400/33 kV Substation (AGEL-PSS-5) to M/s Adani Renewable Energy Thirty

	Seven Limited Battery Energy Storage System (BESS) located near PSS-5, Khavda RE Park (Length: 1.385 kms)
8	33 kV for Feeder No.0816 3C x 400 sqmm Al cable laid underground from 400/33 kV Substation (AGEL-PSS-5) to M/s Adani Renewable Energy Thirty Seven Limited Battery Energy Storage System (BESS) located near PSS-5, Khavda RE Park (Length: 1.470 kms)
9	33 kV for Feeder No.0903 3C x 400 sqmm Al cable laid underground from 400/33 kV Substation (AGEL-PSS-5) to M/s Adani Renewable Energy Thirty Seven Limited Battery Energy Storage System (BESS) located near PSS-5, Khavda RE Park (Length: 1.200 kms)
10	33 kV for Feeder No.1003 3C x 400 sqmm Al cable laid underground from 400/33 kV Substation (AGEL-PSS-5) to Battery Energy Storage System (BESS) located near PSS-5, Khavda RE Park (Length: 1.680 kms)
11	33 kV for Feeder No.1119 3C x 400 sqmm Al cable laid underground from 400/33 kV Substation (AGEL-PSS-5) to M/s Adani Renewable Energy Thirty Seven Limited Battery Energy Storage System (BESS) located near PSS-5, Khavda RE Park (Length: 1.175 kms)
12	33 kV for Feeder No.1217 3C x 400 sqmm Al cable laid underground from 400/33 kV Substation (AGEL-PSS-5) to M/s Adani Renewable Energy Thirty Seven Limited Battery Energy Storage System (BESS) located near PSS-5, Khavda RE Park (Length: 1.430 kms)

Chief Engineer

To,

1.	M/s Adani Renewable Energy Thirty Seven Limited	Adani Corporate House, Shantigram, Nr. Vaishno Devi Circle, SG Highway, Khodiyar, Ahmedabad-382421
----	--	---

CEA Case No.: GUJ-1046-Feeder-0103

Provisional Approval for the Route of Extra High Tension (EHT)/ High Tension (HT) Power Line / Telecommunication Line

Provisional Approval of the Central Level Power & Telecommunication Co-ordination Committee is hereby conveyed having a validity of 60 days from the date of issuance for **33 kV for Feeder No.0103 3C x 400 sqmm Al cable laid underground from 400/33 kV Substation (AGEL-PSS-5) to M/s Adani Renewable Energy Thirty Seven Limited Battery Energy Storage System (BESS) located near PSS-5, Khavda RE Park (Length: 1.130 kms)** particulars of which are given in Annexure I.

The approval is for the route only and is subject to the following conditions.

1. The approval is based on the Power system/ Telecom system conditions' details as reported by the Power supply authority/ Telecom authority at present. Any changes either to Transmission line or the Power system or the paralleling telecommunication lines which are likely to alter the low frequency induction from the estimated at present should be reported to PTCC for its prior approval.
2. The Power and Telecommunication authorities shall be required to adopt such measures as may be recommended by PTCC for counteracting any interference that might arise when the EHT line is in normal operation.
3. Each crossing should satisfy the conditions as laid down in Para 6 -10 of PTCC Code of Practice for crossings.
4. The angle of crossing shall be 90 degrees but in no case less than 60 degrees.
5. The power line shall be equipped with protective switchgear such that the duration of earth current shall be as short as possible but never exceeding 0.5 seconds.
6. The power line shall be energized within a mutually acceptable time limit after obtaining a Certificate from the concerned Telecom and/or Railway authority regarding completion of provision of all protective measures as recommended by PTCC and also under specific clearance from the Telecom and/or Railway authority maintaining the Telecom system.
7. The energization of Extra High Tension power lines would not be held up for want of installation of GD tubes on telecom lines when the induced voltages are in the range of 430 to 650 V.
8. The telecom line shall be commissioned within a mutually acceptable time after completing provision of all protective measures as recommended by PTCC and also after obtaining specific clearance from the Power authority, if certain measures as recommended by PTCC are to be carried out on power system.
9. The later entrant in the field shall bear the entire cost of providing GD tubes and their fitting as recommended by PTCC, including 15% spares and/or any other protective measures as recommended by PTCC.
10. The route approval shall be subject to special conditions as laid down under Annexure II.

Annexure I

1

- (a) Name of the Power Supply authority seeking approval M/s Adani Renewable Energy Thirty Seven Limited
- (b) Reference number & date: ARE37L/PTCC/25-26/BESS Khavda/001
Dated 11.10.2025
Undertaking for Provisional RAC Dated 12.02.2026
- (c) Name of the Power line 33 kV for Feeder No.0103 3C x 400 sqmm Al cable laid underground from 400/33 kV Substation (AGEL-PSS-5) to M/s Adani Renewable Energy Thirty Seven Limited Battery Energy Storage System (BESS) located near PSS-5, Khavda RE Park (Length: 1.130 kms)
- (d) Length of Power line: 1.130 kms
- (e) Operating Voltage 33 kV
- (f) Number of circuits 1

2

- (a) Names of parallel telecom lines: As per Annexure-II
- (b) Length of parallelism: As per Annexure-II
- 3 Average value of earth resistivity in the region: 5000 ohm-cms
- 4 Whether LF test necessary: No
- 5 Special conditions subject to which this certificate will be effective As per Annexure-II

Annexure II

Name of the Power Line: 33 kV for Feeder No.0103 3C x 400 sqmm Al cable laid underground from 400/33 kV Substation (AGEL-PSS-5) to M/s Adani Renewable Energy Thirty Seven Limited Battery Energy Storage System (BESS) located near PSS-5, Khavda RE Park (Length: 1.130 kms)

1. BSNL Telecom Details:

DET (PTCC), WZ, BSNL vide letter: IC/MBI/PTCC/Offline/GUJ-3175 dated 23.01.2026 has given their NOC.

2. Railway Telecom Details:

General Manager (S&T), Western Railway vide letter SG.158/28/12/1680 dated 05.12.2025 has issued their NOC.

3. EPR zone for the proposed substation is mentioned below:

Name of the proposed Substation	Half diagonal distance, D/2 (mts)	Fault Current I (KA)	Resistance of Earth Mat, R (ohms)	d (mts) at 430 V	d (mts) at 650 V	d (mts) at 7kV	d (mts) at 10kV
400/33 kV AGEL-PSS-5	121.97	63	0.3	5239	3425	207	109
33/0.69 kV BESS of M/s AGE37L	251	25	0.5	7046	4576	197	63

Telecom authorities to ensure the protection of telecom equipment and personnel within the EPR zone of the proposed substation at the cost of the later entrant.

CEA Case No.: GUJ-1046-Feeder-0203

Provisional Approval for the Route of Extra High Tension (EHT)/ High Tension (HT) Power Line / Telecommunication Line

Provisional Approval of the Central Level Power & Telecommunication Co-ordination Committee is hereby conveyed having a validity of 60 days from the date of issuance for **33 kV for Feeder No.0203 3C x 400 sqmm Al cable laid underground from 400/33 kV Substation (AGEL-PSS-5) to M/s Adani Renewable Energy Thirty Seven Limited Battery Energy Storage System (BESS) located near PSS-5, Khavda RE Park (Length: 1.335 kms)** particulars of which are given in Annexure III.

The approval is for the route only and is subject to the following conditions.

1. The approval is based on the Power system/ Telecom system conditions' details as reported by the Power supply authority/ Telecom authority at present. Any changes either to Transmission line or the Power system or the paralleling telecommunication lines which are likely to alter the low frequency induction from the estimated at present should be reported to PTCC for its prior approval.
2. The Power and Telecommunication authorities shall be required to adopt such measures as may be recommended by PTCC for counteracting any interference that might arise when the EHT line is in normal operation.
3. Each crossing should satisfy the conditions as laid down in Para 6 -10 of PTCC Code of Practice for crossings.
4. The angle of crossing shall be 90 degrees but in no case less than 60 degrees.
5. The power line shall be equipped with protective switchgear such that the duration of earth current shall be as short as possible but never exceeding 0.5 seconds.
6. The power line shall be energized within a mutually acceptable time limit after obtaining a Certificate from the concerned Telecom and/or Railway authority regarding completion of provision of all protective measures as recommended by PTCC and also under specific clearance from the Telecom and/or Railway authority maintaining the Telecom system.
7. The energization of Extra High Tension power lines would not be held up for want of installation of GD tubes on telecom lines when the induced voltages are in the range of 430 to 650 V.
8. The telecom line shall be commissioned within a mutually acceptable time after completing provision of all protective measures as recommended by PTCC and also after obtaining specific clearance from the Power authority, if certain measures as recommended by PTCC are to be carried out on power system.
9. The later entrant in the field shall bear the entire cost of providing GD tubes and their fitting as recommended by PTCC, including 15% spares and/or any other protective measures as recommended by PTCC.
10. The route approval shall be subject to special conditions as laid down under Annexure IV.

Annexure III

1

- (a) Name of the Power Supply authority seeking approval M/s Adani Renewable Energy Thirty Seven Limited
- (b) Reference number & date: ARE37L/PTCC/25-26/BESS Khavda/001
Dated 11.10.2025
Undertaking for Provisional RAC Dated 12.02.2026
- (c) Name of the Power line 33 kV for Feeder No.0203 3C x 400 sqmm Al cable laid underground from 400/33 kV Substation (AGEL-PSS-5) to M/s Adani Renewable Energy Thirty Seven Limited Battery Energy Storage System (BESS) located near PSS-5, Khavda RE Park (Length: 1.335 kms)
- (d) Length of Power line: 1.335 kms
- (e) Operating Voltage 33 kV
- (f) Number of circuits 1

2

- (a) Names of parallel telecom lines: As per Annexure-IV
- (b) Length of parallelism: As per Annexure-IV
- 3 Average value of earth resistivity in the region: 5000 ohm-cms
- 4 Whether LF test necessary: No
- 5 Special conditions subject to which this certificate will be effective As per Annexure-IV

Annexure IV

Name of the Power Line: 33 kV for Feeder No.0203 3C x 400 sqmm Al cable laid underground from 400/33 kV Substation (AGEL-PSS-5) to M/s Adani Renewable Energy Thirty Seven Limited Battery Energy Storage System (BESS) located near PSS-5, Khavda RE Park (Length: 1.335 kms)

1. BSNL Telecom Details:

DET (PTCC), WZ, BSNL vide letter: IC/MBI/PTCC/Offline/GUJ-3175 dated 23.01.2026 has given their NOC.

2. Railway Telecom Details:

General Manager (S&T), Western Railway vide letter SG.158/28/12/1680 dated 05.12.2025 has issued their NOC.

3. EPR zone for the proposed substation is mentioned below:

Name of the proposed Substation	Half diagonal distance, D/2 (mts)	Fault Current I (KA)	Resistance of Earth Mat, R (ohms)	d (mts) at 430 V	d (mts) at 650 V	d (mts) at 7kV	d (mts) at 10kV
400/33 kV AGEL-PSS-5	121.97	63	0.3	5239	3425	207	109
33/0.69 kV BESS of M/s AGE37L	251	25	0.5	7046	4576	197	63

Telecom authorities to ensure the protection of telecom equipment and personnel within the EPR zone of the proposed substation at the cost of the later entrant.

CEA Case No.: GUJ-1046-Feeder-0321

Provisional Approval for the Route of Extra High Tension (EHT)/ High Tension (HT) Power Line / Telecommunication Line

Provisional Approval of the Central Level Power & Telecommunication Co-ordination Committee is hereby conveyed having a validity of 60 days from the date of issuance for **33 kV for Feeder No.0321 3C x 400 sqmm Al cable laid underground from 400/33 kV Substation (AGEL-PSS-5) to M/s Adani Renewable Energy Thirty Seven Limited Battery Energy Storage System (BESS) located near PSS-5, Khavda RE Park (Length: 1.095 kms)** particulars of which are given in Annexure V.

The approval is for the route only and is subject to the following conditions.

1. The approval is based on the Power system/ Telecom system conditions' details as reported by the Power supply authority/ Telecom authority at present. Any changes either to Transmission line or the Power system or the paralleling telecommunication lines which are likely to alter the low frequency induction from the estimated at present should be reported to PTCC for its prior approval.
2. The Power and Telecommunication authorities shall be required to adopt such measures as may be recommended by PTCC for counteracting any interference that might arise when the EHT line is in normal operation.
3. Each crossing should satisfy the conditions as laid down in Para 6 -10 of PTCC Code of Practice for crossings.
4. The angle of crossing shall be 90 degrees but in no case less than 60 degrees.
5. The power line shall be equipped with protective switchgear such that the duration of earth current shall be as short as possible but never exceeding 0.5 seconds.
6. The power line shall be energized within a mutually acceptable time limit after obtaining a Certificate from the concerned Telecom and/or Railway authority regarding completion of provision of all protective measures as recommended by PTCC and also under specific clearance from the Telecom and/or Railway authority maintaining the Telecom system.
7. The energization of Extra High Tension power lines would not be held up for want of installation of GD tubes on telecom lines when the induced voltages are in the range of 430 to 650 V.
8. The telecom line shall be commissioned within a mutually acceptable time after completing provision of all protective measures as recommended by PTCC and also after obtaining specific clearance from the Power authority, if certain measures as recommended by PTCC are to be carried out on power system.
9. The later entrant in the field shall bear the entire cost of providing GD tubes and their fitting as recommended by PTCC, including 15% spares and/or any other protective measures as recommended by PTCC.
10. The route approval shall be subject to special conditions as laid down under Annexure VI.

Annexure V

1

- (a) Name of the Power Supply authority seeking approval M/s Adani Renewable Energy Thirty Seven Limited
- (b) Reference number & date: ARE37L/PTCC/25-26/BESS Khavda/001
Dated 11.10.2025
Undertaking for Provisional RAC Dated 12.02.2026
- (c) Name of the Power line 33 kV for Feeder No.0321 3C x 400 sqmm Al cable laid underground from 400/33 kV Substation (AGEL-PSS-5) to M/s Adani Renewable Energy Thirty Seven Limited Battery Energy Storage System (BESS) located near PSS-5, Khavda RE Park (Length: 1.095 kms)
- (d) Length of Power line: 1.095 kms
- (e) Operating Voltage 33 kV
- (f) Number of circuits 1

2

- (a) Names of parallel telecom lines: As per Annexure-VI
- (b) Length of parallelism: As per Annexure-VI
- 3 Average value of earth resistivity in the region: 5000 ohm-cms
- 4 Whether LF test necessary: No
- 5 Special conditions subject to which this certificate will be effective As per Annexure-VI

Annexure VI

Name of the Power Line: 33 kV for Feeder No.0321 3C x 400 sqmm Al cable laid underground from 400/33 kV Substation (AGEL-PSS-5) to M/s Adani Renewable Energy Thirty Seven Limited Battery Energy Storage System (BESS) located near PSS-5, Khavda RE Park (Length: 1.095 kms)

1. BSNL Telecom Details:

DET (PTCC), WZ, BSNL vide letter: IC/MBI/PTCC/Offline/GUJ-3175 dated 23.01.2026 has given their NOC.

2. Railway Telecom Details:

General Manager (S&T), Western Railway vide letter SG.158/28/12/1680 dated 05.12.2025 has issued their NOC.

3. EPR zone for the proposed substation is mentioned below:

Name of the proposed Substation	Half diagonal distance, D/2 (mts)	Fault Current I (KA)	Resistance of Earth Mat, R (ohms)	d (mts) at 430 V	d (mts) at 650 V	d (mts) at 7kV	d (mts) at 10kV
400/33 kV AGEL-PSS-5	121.97	63	0.3	5239	3425	207	109
33/0.69 kV BESS of M/s AGE37L	251	25	0.5	7046	4576	197	63

Telecom authorities to ensure the protection of telecom equipment and personnel within the EPR zone of the proposed substation at the cost of the later entrant.

CEA Case No.: GUJ-1046-Feeder-0421

Provisional Approval for the Route of Extra High Tension (EHT)/ High Tension (HT) Power Line / Telecommunication Line

Provisional Approval of the Central Level Power & Telecommunication Co-ordination Committee is hereby conveyed having a validity of 60 days from the date of issuance for **33 kV for Feeder No.0421 3C x 400 sqmm Al cable laid underground from 400/33 kV Substation (AGEL-PSS-5) to M/s Adani Renewable Energy Thirty Seven Limited Battery Energy Storage System (BESS) located near PSS-5, Khavda RE Park (Length: 1.340 kms)** particulars of which are given in Annexure VII.

The approval is for the route only and is subject to the following conditions.

1. The approval is based on the Power system/ Telecom system conditions' details as reported by the Power supply authority/ Telecom authority at present. Any changes either to Transmission line or the Power system or the paralleling telecommunication lines which are likely to alter the low frequency induction from the estimated at present should be reported to PTCC for its prior approval.
2. The Power and Telecommunication authorities shall be required to adopt such measures as may be recommended by PTCC for counteracting any interference that might arise when the EHT line is in normal operation.
3. Each crossing should satisfy the conditions as laid down in Para 6 -10 of PTCC Code of Practice for crossings.
4. The angle of crossing shall be 90 degrees but in no case less than 60 degrees.
5. The power line shall be equipped with protective switchgear such that the duration of earth current shall be as short as possible but never exceeding 0.5 seconds.
6. The power line shall be energized within a mutually acceptable time limit after obtaining a Certificate from the concerned Telecom and/or Railway authority regarding completion of provision of all protective measures as recommended by PTCC and also under specific clearance from the Telecom and/or Railway authority maintaining the Telecom system.
7. The energization of Extra High Tension power lines would not be held up for want of installation of GD tubes on telecom lines when the induced voltages are in the range of 430 to 650 V.
8. The telecom line shall be commissioned within a mutually acceptable time after completing provision of all protective measures as recommended by PTCC and also after obtaining specific clearance from the Power authority, if certain measures as recommended by PTCC are to be carried out on power system.
9. The later entrant in the field shall bear the entire cost of providing GD tubes and their fitting as recommended by PTCC, including 15% spares and/or any other protective measures as recommended by PTCC.
10. The route approval shall be subject to special conditions as laid down under Annexure VIII.

Annexure VII

1

- (a) Name of the Power Supply authority seeking approval M/s Adani Renewable Energy Thirty Seven Limited
- (b) Reference number & date: ARE37L/PTCC/25-26/BESS Khavda/001
Dated 11.10.2025
Undertaking for Provisional RAC Dated 12.02.2026
- (c) Name of the Power line 33 kV for Feeder No.0421 3C x 400 sqmm Al cable laid underground from 400/33 kV Substation (AGEL-PSS-5) to M/s Adani Renewable Energy Thirty Seven Limited Battery Energy Storage System (BESS) located near PSS-5, Khavda RE Park (Length: 1.340 kms)
- (d) Length of Power line: 1.340 kms
- (e) Operating Voltage 33 kV
- (f) Number of circuits 1

2

- (a) Names of parallel telecom lines: As per Annexure-VIII
- (b) Length of parallelism: As per Annexure-VIII
- 3 Average value of earth resistivity in the region: 5000 ohm-cms
- 4 Whether LF test necessary: No
- 5 Special conditions subject to which this certificate will be effective As per Annexure-VIII

Annexure VIII

Name of the Power Line: 33 kV for Feeder No.0421 3C x 400 sqmm Al cable laid underground from 400/33 kV Substation (AGEL-PSS-5) to M/s Adani Renewable Energy Thirty Seven Limited Battery Energy Storage System (BESS) located near PSS-5, Khavda RE Park (Length: 1.340 kms)

1. BSNL Telecom Details:

DET (PTCC), WZ, BSNL vide letter: IC/MBI/PTCC/Offline/GUJ-3175 dated 23.01.2026 has given their NOC.

2. Railway Telecom Details:

General Manager (S&T), Western Railway vide letter SG.158/28/12/1680 dated 05.12.2025 has issued their NOC.

3. EPR zone for the proposed substation is mentioned below:

Name of the proposed Substation	Half diagonal distance, D/2 (mts)	Fault Current I (KA)	Resistance of Earth Mat, R (ohms)	d (mts) at 430 V	d (mts) at 650 V	d (mts) at 7kV	d (mts) at 10kV
400/33 kV AGEL-PSS-5	121.97	63	0.3	5239	3425	207	109
33/0.69 kV BESS of M/s AGE37L	251	25	0.5	7046	4576	197	63

Telecom authorities to ensure the protection of telecom equipment and personnel within the EPR zone of the proposed substation at the cost of the later entrant.

CEA Case No.: GUJ-1046-Feeder-0518

Provisional Approval for the Route of Extra High Tension (EHT)/ High Tension (HT) Power Line / Telecommunication Line

Provisional Approval of the Central Level Power & Telecommunication Co-ordination Committee is hereby conveyed having a validity of 60 days from the date of issuance for **33 kV for Feeder No.0518 3C x 400 sqmm Al cable laid underground from 400/33 kV Substation (AGEL-PSS-5) to M/s Adani Renewable Energy Thirty Seven Limited Battery Energy Storage System (BESS) located near PSS-5, Khavda RE Park (Length: 1.230 kms)** particulars of which are given in Annexure IX.

The approval is for the route only and is subject to the following conditions.

1. The approval is based on the Power system/ Telecom system conditions' details as reported by the Power supply authority/ Telecom authority at present. Any changes either to Transmission line or the Power system or the paralleling telecommunication lines which are likely to alter the low frequency induction from the estimated at present should be reported to PTCC for its prior approval.
2. The Power and Telecommunication authorities shall be required to adopt such measures as may be recommended by PTCC for counteracting any interference that might arise when the EHT line is in normal operation.
3. Each crossing should satisfy the conditions as laid down in Para 6 -10 of PTCC Code of Practice for crossings.
4. The angle of crossing shall be 90 degrees but in no case less than 60 degrees.
5. The power line shall be equipped with protective switchgear such that the duration of earth current shall be as short as possible but never exceeding 0.5 seconds.
6. The power line shall be energized within a mutually acceptable time limit after obtaining a Certificate from the concerned Telecom and/or Railway authority regarding completion of provision of all protective measures as recommended by PTCC and also under specific clearance from the Telecom and/or Railway authority maintaining the Telecom system.
7. The energization of Extra High Tension power lines would not be held up for want of installation of GD tubes on telecom lines when the induced voltages are in the range of 430 to 650 V.
8. The telecom line shall be commissioned within a mutually acceptable time after completing provision of all protective measures as recommended by PTCC and also after obtaining specific clearance from the Power authority, if certain measures as recommended by PTCC are to be carried out on power system.
9. The later entrant in the field shall bear the entire cost of providing GD tubes and their fitting as recommended by PTCC, including 15% spares and/or any other protective measures as recommended by PTCC.
10. The route approval shall be subject to special conditions as laid down under Annexure X.

Annexure IX

1

- (a) Name of the Power Supply authority seeking approval M/s Adani Renewable Energy Thirty Seven Limited
- (b) Reference number & date: ARE37L/PTCC/25-26/BESS Khavda/001
Dated 11.10.2025
Undertaking for Provisional RAC Dated 12.02.2026
- (c) Name of the Power line 33 kV for Feeder No.0518 3C x 400 sqmm Al cable laid underground from 400/33 kV Substation (AGEL-PSS-5) to M/s Adani Renewable Energy Thirty Seven Limited Battery Energy Storage System (BESS) located near PSS-5, Khavda RE Park (Length: 1.230 kms)
- (d) Length of Power line: 1.230 kms
- (e) Operating Voltage 33 kV
- (f) Number of circuits 1

2

- (a) Names of parallel telecom lines: As per Annexure-X
- (b) Length of parallelism: As per Annexure-X
- 3 Average value of earth resistivity in the region: 5000 ohm-cms
- 4 Whether LF test necessary: No
- 5 Special conditions subject to which this certificate will be effective As per Annexure-X

Annexure X

Name of the Power Line: 33 kV for Feeder No.0518 3C x 400 sqmm Al cable laid underground from 400/33 kV Substation (AGEL-PSS-5) to M/s Adani Renewable Energy Thirty Seven Limited Battery Energy Storage System (BESS) located near PSS-5, Khavda RE Park (Length: 1.230 kms)

1. BSNL Telecom Details:

DET (PTCC), WZ, BSNL vide letter: IC/MBI/PTCC/Offline/GUJ-3175 dated 23.01.2026 has given their NOC.

2. Railway Telecom Details:

General Manager (S&T), Western Railway vide letter SG.158/28/12/1680 dated 05.12.2025 has issued their NOC.

3. EPR zone for the proposed substation is mentioned below:

Name of the proposed Substation	Half diagonal distance, D/2 (mts)	Fault Current I (KA)	Resistance of Earth Mat, R (ohms)	d (mts) at 430 V	d (mts) at 650 V	d (mts) at 7kV	d (mts) at 10kV
400/33 kV AGEL-PSS-5	121.97	63	0.3	5239	3425	207	109
33/0.69 kV BESS of M/s AGE37L	251	25	0.5	7046	4576	197	63

Telecom authorities to ensure the protection of telecom equipment and personnel within the EPR zone of the proposed substation at the cost of the later entrant.

CEA Case No.: GUJ-1046-Feeder-0618

Provisional Approval for the Route of Extra High Tension (EHT)/ High Tension (HT) Power Line / Telecommunication Line

Provisional Approval of the Central Level Power & Telecommunication Co-ordination Committee is hereby conveyed having a validity of 60 days from the date of issuance for **33 kV for Feeder No.0618 3C x 400 sqmm Al cable laid underground from 400/33 kV Substation (AGEL-PSS-5) to M/s Adani Renewable Energy Thirty Seven Limited M/s Adani Renewable Energy Thirty Seven Limited Battery Energy Storage System (BESS) located near PSS-5, Khavda RE Park (Length: 1.465 kms)** particulars of which are given in Annexure XI.

The approval is for the route only and is subject to the following conditions.

1. The approval is based on the Power system/ Telecom system conditions' details as reported by the Power supply authority/ Telecom authority at present. Any changes either to Transmission line or the Power system or the paralleling telecommunication lines which are likely to alter the low frequency induction from the estimated at present should be reported to PTCC for its prior approval.
2. The Power and Telecommunication authorities shall be required to adopt such measures as may be recommended by PTCC for counteracting any interference that might arise when the EHT line is in normal operation.
3. Each crossing should satisfy the conditions as laid down in Para 6 -10 of PTCC Code of Practice for crossings.
4. The angle of crossing shall be 90 degrees but in no case less than 60 degrees.
5. The power line shall be equipped with protective switchgear such that the duration of earth current shall be as short as possible but never exceeding 0.5 seconds.
6. The power line shall be energized within a mutually acceptable time limit after obtaining a Certificate from the concerned Telecom and/or Railway authority regarding completion of provision of all protective measures as recommended by PTCC and also under specific clearance from the Telecom and/or Railway authority maintaining the Telecom system.
7. The energization of Extra High Tension power lines would not be held up for want of installation of GD tubes on telecom lines when the induced voltages are in the range of 430 to 650 V.
8. The telecom line shall be commissioned within a mutually acceptable time after completing provision of all protective measures as recommended by PTCC and also after obtaining specific clearance from the Power authority, if certain measures as recommended by PTCC are to be carried out on power system.
9. The later entrant in the field shall bear the entire cost of providing GD tubes and their fitting as recommended by PTCC, including 15% spares and/or any other protective measures as recommended by PTCC.
10. The route approval shall be subject to special conditions as laid down under Annexure XII.

Annexure XI

1

- (a) Name of the Power Supply authority seeking approval M/s Adani Renewable Energy Thirty Seven Limited
- (b) Reference number & date: ARE37L/PTCC/25-26/BESS Khavda/001
Dated 11.10.2025
Undertaking for Provisional RAC Dated 12.02.2026
- (c) Name of the Power line 33 kV for Feeder No.0618 3C x 400 sqmm Al cable laid underground from 400/33 kV Substation (AGEL-PSS-5) to M/s Adani Renewable Energy Thirty Seven Limited M/s Adani Renewable Energy Thirty Seven Limited Battery Energy Storage System (BESS) located near PSS-5, Khavda RE Park (Length: 1.465 kms)
- (d) Length of Power line: 1.465 kms
- (e) Operating Voltage 33 kV
- (f) Number of circuits 1

2

- (a) Names of parallel telecom lines: As per Annexure-XII
- (b) Length of parallelism: As per Annexure-XII
- 3 Average value of earth resistivity in the region: 5000 ohm-cms
- 4 Whether LF test necessary: No
- 5 Special conditions subject to which this certificate will be effective As per Annexure-XII

Annexure XII

Name of the Power Line: 33 kV for Feeder No.0618 3C x 400 sqmm Al cable laid underground from 400/33 kV Substation (AGEL-PSS-5) to M/s Adani Renewable Energy Thirty Seven Limited M/s Adani Renewable Energy Thirty Seven Limited Battery Energy Storage System (BESS) located near PSS-5, Khavda RE Park (Length: 1.465 kms)

1. BSNL Telecom Details:

DET (PTCC), WZ, BSNL vide letter: IC/MBI/PTCC/Offline/GUJ-3175 dated 23.01.2026 has given their NOC.

2. Railway Telecom Details:

General Manager (S&T), Western Railway vide letter SG.158/28/12/1680 dated 05.12.2025 has issued their NOC.

3. EPR zone for the proposed substation is mentioned below:

Name of the proposed Substation	Half diagonal distance, D/2 (mts)	Fault Current I (KA)	Resistance of Earth Mat, R (ohms)	d (mts) at 430 V	d (mts) at 650 V	d (mts) at 7kV	d (mts) at 10kV
400/33 kV AGEL-PSS-5	121.97	63	0.3	5239	3425	207	109
33/0.69 kV BESS of M/s AGE37L	251	25	0.5	7046	4576	197	63

Telecom authorities to ensure the protection of telecom equipment and personnel within the EPR zone of the proposed substation at the cost of the later entrant.

CEA Case No.: GUJ-1046-Feeder-0706

Provisional Approval for the Route of Extra High Tension (EHT)/ High Tension (HT) Power Line / Telecommunication Line

Provisional Approval of the Central Level Power & Telecommunication Co-ordination Committee is hereby conveyed having a validity of 60 days from the date of issuance for **33 kV for Feeder No.0706 3C x 400 sqmm Al cable laid underground from 400/33 kV Substation (AGEL-PSS-5) to M/s Adani Renewable Energy Thirty Seven Limited Battery Energy Storage System (BESS) located near PSS-5, Khavda RE Park (Length: 1.385 kms)** particulars of which are given in Annexure XIII.

The approval is for the route only and is subject to the following conditions.

1. The approval is based on the Power system/ Telecom system conditions' details as reported by the Power supply authority/ Telecom authority at present. Any changes either to Transmission line or the Power system or the paralleling telecommunication lines which are likely to alter the low frequency induction from the estimated at present should be reported to PTCC for its prior approval.
2. The Power and Telecommunication authorities shall be required to adopt such measures as may be recommended by PTCC for counteracting any interference that might arise when the EHT line is in normal operation.
3. Each crossing should satisfy the conditions as laid down in Para 6 -10 of PTCC Code of Practice for crossings.
4. The angle of crossing shall be 90 degrees but in no case less than 60 degrees.
5. The power line shall be equipped with protective switchgear such that the duration of earth current shall be as short as possible but never exceeding 0.5 seconds.
6. The power line shall be energized within a mutually acceptable time limit after obtaining a Certificate from the concerned Telecom and/or Railway authority regarding completion of provision of all protective measures as recommended by PTCC and also under specific clearance from the Telecom and/or Railway authority maintaining the Telecom system.
7. The energization of Extra High Tension power lines would not be held up for want of installation of GD tubes on telecom lines when the induced voltages are in the range of 430 to 650 V.
8. The telecom line shall be commissioned within a mutually acceptable time after completing provision of all protective measures as recommended by PTCC and also after obtaining specific clearance from the Power authority, if certain measures as recommended by PTCC are to be carried out on power system.
9. The later entrant in the field shall bear the entire cost of providing GD tubes and their fitting as recommended by PTCC, including 15% spares and/or any other protective measures as recommended by PTCC.
10. The route approval shall be subject to special conditions as laid down under Annexure XIV.

Annexure XIII

1

- (a) Name of the Power Supply authority seeking approval M/s Adani Renewable Energy Thirty Seven Limited
- (b) Reference number & date: ARE37L/PTCC/25-26/BESS Khavda/001
Dated 11.10.2025
Undertaking for Provisional RAC Dated 12.02.2026
- (c) Name of the Power line 33 kV for Feeder No.0706 3C x 400 sqmm Al cable laid underground from 400/33 kV Substation (AGEL-PSS-5) to M/s Adani Renewable Energy Thirty Seven Limited Battery Energy Storage System (BESS) located near PSS-5, Khavda RE Park (Length: 1.385 kms)
- (d) Length of Power line: 1.385 kms
- (e) Operating Voltage 33 kV
- (f) Number of circuits 1

2

- (a) Names of parallel telecom lines: As per Annexure-XIV
- (b) Length of parallelism: As per Annexure-XIV
- 3 Average value of earth resistivity in the region: 5000 ohm-cms
- 4 Whether LF test necessary: No
- 5 Special conditions subject to which this certificate will be effective As per Annexure-XIV

Annexure XIV

Name of the Power Line: 33 kV for Feeder No.0706 3C x 400 sqmm Al cable laid underground from 400/33 kV Substation (AGEL-PSS-5) to M/s Adani Renewable Energy Thirty Seven Limited Battery Energy Storage System (BESS) located near PSS-5, Khavda RE Park (Length: 1.385 kms)

1. BSNL Telecom Details:

DET (PTCC), WZ, BSNL vide letter: IC/MBI/PTCC/Offline/GUJ-3175 dated 23.01.2026 has given their NOC.

2. Railway Telecom Details:

General Manager (S&T), Western Railway vide letter SG.158/28/12/1680 dated 05.12.2025 has issued their NOC.

3. EPR zone for the proposed substation is mentioned below:

Name of the proposed Substation	Half diagonal distance, D/2 (mts)	Fault Current I (KA)	Resistance of Earth Mat, R (ohms)	d (mts) at 430 V	d (mts) at 650 V	d (mts) at 7kV	d (mts) at 10kV
400/33 kV AGEL-PSS-5	121.97	63	0.3	5239	3425	207	109
33/0.69 kV BESS of M/s AGE37L	251	25	0.5	7046	4576	197	63

Telecom authorities to ensure the protection of telecom equipment and personnel within the EPR zone of the proposed substation at the cost of the later entrant.

CEA Case No.: GUJ-1046-Feeder-0816

Provisional Approval for the Route of Extra High Tension (EHT)/ High Tension (HT) Power Line / Telecommunication Line

Provisional Approval of the Central Level Power & Telecommunication Co-ordination Committee is hereby conveyed having a validity of 60 days from the date of issuance for **33 kV for Feeder No.0816 3C x 400 sqmm Al cable laid underground from 400/33 kV Substation (AGEL-PSS-5) to M/s Adani Renewable Energy Thirty Seven Limited Battery Energy Storage System (BESS) located near PSS-5, Khavda RE Park (Length: 1.470 kms)** particulars of which are given in Annexure XV.

The approval is for the route only and is subject to the following conditions.

1. The approval is based on the Power system/ Telecom system conditions' details as reported by the Power supply authority/ Telecom authority at present. Any changes either to Transmission line or the Power system or the paralleling telecommunication lines which are likely to alter the low frequency induction from the estimated at present should be reported to PTCC for its prior approval.
2. The Power and Telecommunication authorities shall be required to adopt such measures as may be recommended by PTCC for counteracting any interference that might arise when the EHT line is in normal operation.
3. Each crossing should satisfy the conditions as laid down in Para 6 -10 of PTCC Code of Practice for crossings.
4. The angle of crossing shall be 90 degrees but in no case less than 60 degrees.
5. The power line shall be equipped with protective switchgear such that the duration of earth current shall be as short as possible but never exceeding 0.5 seconds.
6. The power line shall be energized within a mutually acceptable time limit after obtaining a Certificate from the concerned Telecom and/or Railway authority regarding completion of provision of all protective measures as recommended by PTCC and also under specific clearance from the Telecom and/or Railway authority maintaining the Telecom system.
7. The energization of Extra High Tension power lines would not be held up for want of installation of GD tubes on telecom lines when the induced voltages are in the range of 430 to 650 V.
8. The telecom line shall be commissioned within a mutually acceptable time after completing provision of all protective measures as recommended by PTCC and also after obtaining specific clearance from the Power authority, if certain measures as recommended by PTCC are to be carried out on power system.
9. The later entrant in the field shall bear the entire cost of providing GD tubes and their fitting as recommended by PTCC, including 15% spares and/or any other protective measures as recommended by PTCC.
10. The route approval shall be subject to special conditions as laid down under Annexure XVI.

Annexure XV

1

- (a) Name of the Power Supply authority seeking approval M/s Adani Renewable Energy Thirty Seven Limited
- (b) Reference number & date: ARE37L/PTCC/25-26/BESS Khavda/001
Dated 11.10.2025
Undertaking for Provisional RAC Dated 12.02.2026
- (c) Name of the Power line 33 kV for Feeder No.0816 3C x 400 sqmm Al cable laid underground from 400/33 kV Substation (AGEL-PSS-5) to M/s Adani Renewable Energy Thirty Seven Limited Battery Energy Storage System (BESS) located near PSS-5, Khavda RE Park (Length: 1.470 kms)
- (d) Length of Power line: 1.470 kms
- (e) Operating Voltage 33 kV
- (f) Number of circuits 1

2

- (a) Names of parallel telecom lines: As per Annexure-XVI
- (b) Length of parallelism: As per Annexure-XVI
- 3 Average value of earth resistivity in the region: 5000 ohm-cms
- 4 Whether LF test necessary: No
- 5 Special conditions subject to which this certificate will be effective As per Annexure-XVI

Annexure XVI

Name of the Power Line: 33 kV for Feeder No.0816 3C x 400 sqmm Al cable laid underground from 400/33 kV Substation (AGEL-PSS-5) to M/s Adani Renewable Energy Thirty Seven Limited Battery Energy Storage System (BESS) located near PSS-5, Khavda RE Park (Length: 1.470 kms)

1. BSNL Telecom Details:

DET (PTCC), WZ, BSNL vide letter: IC/MBI/PTCC/Offline/GUJ-3175 dated 23.01.2026 has given their NOC.

2. Railway Telecom Details:

General Manager (S&T), Western Railway vide letter SG.158/28/12/1680 dated 05.12.2025 has issued their NOC.

3. EPR zone for the proposed substation is mentioned below:

Name of the proposed Substation	Half diagonal distance, D/2 (mts)	Fault Current I (KA)	Resistance of Earth Mat, R (ohms)	d (mts) at 430 V	d (mts) at 650 V	d (mts) at 7kV	d (mts) at 10kV
400/33 kV AGEL-PSS-5	121.97	63	0.3	5239	3425	207	109
33/0.69 kV BESS of M/s AGE37L	251	25	0.5	7046	4576	197	63

Telecom authorities to ensure the protection of telecom equipment and personnel within the EPR zone of the proposed substation at the cost of the later entrant.

CEA Case No.: GUJ-1046-Feeder-0903

Provisional Approval for the Route of Extra High Tension (EHT)/ High Tension (HT) Power Line / Telecommunication Line

Provisional Approval of the Central Level Power & Telecommunication Co-ordination Committee is hereby conveyed having a validity of 60 days from the date of issuance for **33 kV for Feeder No.0903 3C x 400 sqmm Al cable laid underground from 400/33 kV Substation (AGEL-PSS-5) to M/s Adani Renewable Energy Thirty Seven Limited Battery Energy Storage System (BESS) located near PSS-5, Khavda RE Park (Length: 1.200 kms)** particulars of which are given in Annexure XVII.

The approval is for the route only and is subject to the following conditions.

1. The approval is based on the Power system/ Telecom system conditions' details as reported by the Power supply authority/ Telecom authority at present. Any changes either to Transmission line or the Power system or the paralleling telecommunication lines which are likely to alter the low frequency induction from the estimated at present should be reported to PTCC for its prior approval.
2. The Power and Telecommunication authorities shall be required to adopt such measures as may be recommended by PTCC for counteracting any interference that might arise when the EHT line is in normal operation.
3. Each crossing should satisfy the conditions as laid down in Para 6 -10 of PTCC Code of Practice for crossings.
4. The angle of crossing shall be 90 degrees but in no case less than 60 degrees.
5. The power line shall be equipped with protective switchgear such that the duration of earth current shall be as short as possible but never exceeding 0.5 seconds.
6. The power line shall be energized within a mutually acceptable time limit after obtaining a Certificate from the concerned Telecom and/or Railway authority regarding completion of provision of all protective measures as recommended by PTCC and also under specific clearance from the Telecom and/or Railway authority maintaining the Telecom system.
7. The energization of Extra High Tension power lines would not be held up for want of installation of GD tubes on telecom lines when the induced voltages are in the range of 430 to 650 V.
8. The telecom line shall be commissioned within a mutually acceptable time after completing provision of all protective measures as recommended by PTCC and also after obtaining specific clearance from the Power authority, if certain measures as recommended by PTCC are to be carried out on power system.
9. The later entrant in the field shall bear the entire cost of providing GD tubes and their fitting as recommended by PTCC, including 15% spares and/or any other protective measures as recommended by PTCC.
10. The route approval shall be subject to special conditions as laid down under Annexure XVIII.

Annexure XVII

1

- (a) Name of the Power Supply authority seeking approval M/s Adani Renewable Energy Thirty Seven Limited
- (b) Reference number & date: ARE37L/PTCC/25-26/BESS Khavda/001
Dated 11.10.2025
Undertaking for Provisional RAC Dated 12.02.2026
- (c) Name of the Power line 33 kV for Feeder No.0903 3C x 400 sqmm Al cable laid underground from 400/33 kV Substation (AGEL-PSS-5) to M/s Adani Renewable Energy Thirty Seven Limited Battery Energy Storage System (BESS) located near PSS-5, Khavda RE Park (Length: 1.200 kms)
- (d) Length of Power line: 1.200 kms
- (e) Operating Voltage 33 kV
- (f) Number of circuits 1

2

- (a) Names of parallel telecom lines: As per Annexure-XVIII
- (b) Length of parallelism: As per Annexure-XVIII
- 3 Average value of earth resistivity in the region: 5000 ohm-cms
- 4 Whether LF test necessary: No
- 5 Special conditions subject to which this certificate will be effective As per Annexure-XVIII

Annexure XVIII

Name of the Power Line: 33 kV for Feeder No.0903 3C x 400 sqmm Al cable laid underground from 400/33 kV Substation (AGEL-PSS-5) to M/s Adani Renewable Energy Thirty Seven Limited Battery Energy Storage System (BESS) located near PSS-5, Khavda RE Park (Length: 1.200 kms)

1. BSNL Telecom Details:

DET (PTCC), WZ, BSNL vide letter: IC/MBI/PTCC/Offline/GUJ-3175 dated 23.01.2026 has given their NOC.

2. Railway Telecom Details:

General Manager (S&T), Western Railway vide letter SG.158/28/12/1680 dated 05.12.2025 has issued their NOC.

3. EPR zone for the proposed substation is mentioned below:

Name of the proposed Substation	Half diagonal distance, D/2 (mts)	Fault Current I (KA)	Resistance of Earth Mat, R (ohms)	d (mts) at 430 V	d (mts) at 650 V	d (mts) at 7kV	d (mts) at 10kV
400/33 kV AGEL-PSS-5	121.97	63	0.3	5239	3425	207	109
33/0.69 kV BESS of M/s AGE37L	251	25	0.5	7046	4576	197	63

Telecom authorities to ensure the protection of telecom equipment and personnel within the EPR zone of the proposed substation at the cost of the later entrant.

CEA Case No.: GUJ-1046-Feeder-1003

Provisional Approval for the Route of Extra High Tension (EHT)/ High Tension (HT) Power Line / Telecommunication Line

Provisional Approval of the Central Level Power & Telecommunication Co-ordination Committee is hereby conveyed having a validity of 60 days from the date of issuance for **33 kV for Feeder No.1003 3C x 400 sqmm Al cable laid underground from 400/33 kV Substation (AGEL-PSS-5) to Battery Energy Storage System (BESS) located near PSS-5, Khavda RE Park (Length: 1.680 kms)** particulars of which are given in Annexure XIX.

The approval is for the route only and is subject to the following conditions.

1. The approval is based on the Power system/ Telecom system conditions' details as reported by the Power supply authority/ Telecom authority at present. Any changes either to Transmission line or the Power system or the paralleling telecommunication lines which are likely to alter the low frequency induction from the estimated at present should be reported to PTCC for its prior approval.
2. The Power and Telecommunication authorities shall be required to adopt such measures as may be recommended by PTCC for counteracting any interference that might arise when the EHT line is in normal operation.
3. Each crossing should satisfy the conditions as laid down in Para 6 -10 of PTCC Code of Practice for crossings.
4. The angle of crossing shall be 90 degrees but in no case less than 60 degrees.
5. The power line shall be equipped with protective switchgear such that the duration of earth current shall be as short as possible but never exceeding 0.5 seconds.
6. The power line shall be energized within a mutually acceptable time limit after obtaining a Certificate from the concerned Telecom and/or Railway authority regarding completion of provision of all protective measures as recommended by PTCC and also under specific clearance from the Telecom and/or Railway authority maintaining the Telecom system.
7. The energization of Extra High Tension power lines would not be held up for want of installation of GD tubes on telecom lines when the induced voltages are in the range of 430 to 650 V.
8. The telecom line shall be commissioned within a mutually acceptable time after completing provision of all protective measures as recommended by PTCC and also after obtaining specific clearance from the Power authority, if certain measures as recommended by PTCC are to be carried out on power system.
9. The later entrant in the field shall bear the entire cost of providing GD tubes and their fitting as recommended by PTCC, including 15% spares and/or any other protective measures as recommended by PTCC.
10. The route approval shall be subject to special conditions as laid down under Annexure XX.

Annexure XIX

1

- (a) Name of the Power Supply authority seeking approval M/s Adani Renewable Energy Thirty Seven Limited
- (b) Reference number & date: ARE37L/PTCC/25-26/BESS Khavda/001
Dated 11.10.2025
Undertaking for Provisional RAC Dated 12.02.2026
- (c) Name of the Power line 33 kV for Feeder No.1003 3C x 400 sqmm Al cable laid underground from 400/33 kV Substation (AGEL-PSS-5) to Battery Energy Storage System (BESS) located near PSS-5, Khavda RE Park (Length: 1.680 kms)
- (d) Length of Power line: 1.680 kms
- (e) Operating Voltage 33 kV
- (f) Number of circuits 1

2

- (a) Names of parallel telecom lines: As per Annexure-XX
- (b) Length of parallelism: As per Annexure-XX
- 3 Average value of earth resistivity in the region: 5000 ohm-cms
- 4 Whether LF test necessary: No
- 5 Special conditions subject to which this certificate will be effective As per Annexure-XX

Annexure XX

Name of the Power Line: 33 kV for Feeder No.1003 3C x 400 sqmm Al cable laid underground from 400/33 kV Substation (AGEL-PSS-5) to Battery Energy Storage System (BESS) located near PSS-5, Khavda RE Park (Length: 1.680 kms)

1. BSNL Telecom Details:

DET (PTCC), WZ, BSNL vide letter: IC/MBI/PTCC/Offline/GUJ-3175 dated 23.01.2026 has given their NOC.

2. Railway Telecom Details:

General Manager (S&T), Western Railway vide letter SG.158/28/12/1680 dated 05.12.2025 has issued their NOC.

3. EPR zone for the proposed substation is mentioned below:

Name of the proposed Substation	Half diagonal distance, D/2 (mts)	Fault Current I (KA)	Resistance of Earth Mat, R (ohms)	d (mts) at 430 V	d (mts) at 650 V	d (mts) at 7kV	d (mts) at 10kV
400/33 kV AGEL-PSS-5	121.97	63	0.3	5239	3425	207	109
33/0.69 kV BESS of M/s AGE37L	251	25	0.5	7046	4576	197	63

Telecom authorities to ensure the protection of telecom equipment and personnel within the EPR zone of the proposed substation at the cost of the later entrant.

CEA Case No.: GUJ-1046-Feeder-1119

Provisional Approval for the Route of Extra High Tension (EHT)/ High Tension (HT) Power Line / Telecommunication Line

Provisional Approval of the Central Level Power & Telecommunication Co-ordination Committee is hereby conveyed having a validity of 60 days from the date of issuance for **33 kV for Feeder No.1119 3C x 400 sqmm Al cable laid underground from 400/33 kV Substation (AGEL-PSS-5) to M/s Adani Renewable Energy Thirty Seven Limited Battery Energy Storage System (BESS) located near PSS-5, Khavda RE Park (Length: 1.175 kms)** particulars of which are given in Annexure XXI.

The approval is for the route only and is subject to the following conditions.

1. The approval is based on the Power system/ Telecom system conditions' details as reported by the Power supply authority/ Telecom authority at present. Any changes either to Transmission line or the Power system or the paralleling telecommunication lines which are likely to alter the low frequency induction from the estimated at present should be reported to PTCC for its prior approval.
2. The Power and Telecommunication authorities shall be required to adopt such measures as may be recommended by PTCC for counteracting any interference that might arise when the EHT line is in normal operation.
3. Each crossing should satisfy the conditions as laid down in Para 6 -10 of PTCC Code of Practice for crossings.
4. The angle of crossing shall be 90 degrees but in no case less than 60 degrees.
5. The power line shall be equipped with protective switchgear such that the duration of earth current shall be as short as possible but never exceeding 0.5 seconds.
6. The power line shall be energized within a mutually acceptable time limit after obtaining a Certificate from the concerned Telecom and/or Railway authority regarding completion of provision of all protective measures as recommended by PTCC and also under specific clearance from the Telecom and/or Railway authority maintaining the Telecom system.
7. The energization of Extra High Tension power lines would not be held up for want of installation of GD tubes on telecom lines when the induced voltages are in the range of 430 to 650 V.
8. The telecom line shall be commissioned within a mutually acceptable time after completing provision of all protective measures as recommended by PTCC and also after obtaining specific clearance from the Power authority, if certain measures as recommended by PTCC are to be carried out on power system.
9. The later entrant in the field shall bear the entire cost of providing GD tubes and their fitting as recommended by PTCC, including 15% spares and/or any other protective measures as recommended by PTCC.
10. The route approval shall be subject to special conditions as laid down under Annexure XXII.

Annexure XXI

1

- (a) Name of the Power Supply authority seeking approval M/s Adani Renewable Energy Thirty Seven Limited
- (b) Reference number & date: ARE37L/PTCC/25-26/BESS Khavda/001
Dated 11.10.2025
Undertaking for Provisional RAC Dated 12.02.2026
- (c) Name of the Power line 33 kV for Feeder No.1119 3C x 400 sqmm Al cable laid underground from 400/33 kV Substation (AGEL-PSS-5) to M/s Adani Renewable Energy Thirty Seven Limited Battery Energy Storage System (BESS) located near PSS-5, Khavda RE Park (Length: 1.175 kms)
- (d) Length of Power line: 1.175 kms
- (e) Operating Voltage 33 kV
- (f) Number of circuits 1

2

- (a) Names of parallel telecom lines: As per Annexure-XXII
- (b) Length of parallelism: As per Annexure-XXII
- 3 Average value of earth resistivity in the region: 5000 ohm-cms
- 4 Whether LF test necessary: No
- 5 Special conditions subject to which this certificate will be effective As per Annexure-XXII

Annexure XXII

Name of the Power Line: 33 kV for Feeder No.1119 3C x 400 sqmm Al cable laid underground from 400/33 kV Substation (AGEL-PSS-5) to M/s Adani Renewable Energy Thirty Seven Limited Battery Energy Storage System (BESS) located near PSS-5, Khavda RE Park (Length: 1.175 kms)

1. BSNL Telecom Details:

DET (PTCC), WZ, BSNL vide letter: IC/MBI/PTCC/Offline/GUJ-3175 dated 23.01.2026 has given their NOC.

2. Railway Telecom Details:

General Manager (S&T), Western Railway vide letter SG.158/28/12/1680 dated 05.12.2025 has issued their NOC.

3. EPR zone for the proposed substation is mentioned below:

Name of the proposed Substation	Half diagonal distance, D/2 (mts)	Fault Current I (KA)	Resistance of Earth Mat, R (ohms)	d (mts) at 430 V	d (mts) at 650 V	d (mts) at 7kV	d (mts) at 10kV
400/33 kV AGEL-PSS-5	121.97	63	0.3	5239	3425	207	109
33/0.69 kV BESS of M/s AGE37L	251	25	0.5	7046	4576	197	63

Telecom authorities to ensure the protection of telecom equipment and personnel within the EPR zone of the proposed substation at the cost of the later entrant.

CEA Case No.: GUJ-1046-Feeder-1217

Provisional Approval for the Route of Extra High Tension (EHT)/ High Tension (HT) Power Line / Telecommunication Line

Provisional Approval of the Central Level Power & Telecommunication Co-ordination Committee is hereby conveyed having a validity of 60 days from the date of issuance for **33 kV for Feeder No.1217 3C x 400 sqmm Al cable laid underground from 400/33 kV Substation (AGEL-PSS-5) to M/s Adani Renewable Energy Thirty Seven Limited Battery Energy Storage System (BESS) located near PSS-5, Khavda RE Park (Length: 1.430 kms)** particulars of which are given in Annexure XXIII.

The approval is for the route only and is subject to the following conditions.

1. The approval is based on the Power system/ Telecom system conditions' details as reported by the Power supply authority/ Telecom authority at present. Any changes either to Transmission line or the Power system or the paralleling telecommunication lines which are likely to alter the low frequency induction from the estimated at present should be reported to PTCC for its prior approval.
2. The Power and Telecommunication authorities shall be required to adopt such measures as may be recommended by PTCC for counteracting any interference that might arise when the EHT line is in normal operation.
3. Each crossing should satisfy the conditions as laid down in Para 6 -10 of PTCC Code of Practice for crossings.
4. The angle of crossing shall be 90 degrees but in no case less than 60 degrees.
5. The power line shall be equipped with protective switchgear such that the duration of earth current shall be as short as possible but never exceeding 0.5 seconds.
6. The power line shall be energized within a mutually acceptable time limit after obtaining a Certificate from the concerned Telecom and/or Railway authority regarding completion of provision of all protective measures as recommended by PTCC and also under specific clearance from the Telecom and/or Railway authority maintaining the Telecom system.
7. The energization of Extra High Tension power lines would not be held up for want of installation of GD tubes on telecom lines when the induced voltages are in the range of 430 to 650 V.
8. The telecom line shall be commissioned within a mutually acceptable time after completing provision of all protective measures as recommended by PTCC and also after obtaining specific clearance from the Power authority, if certain measures as recommended by PTCC are to be carried out on power system.
9. The later entrant in the field shall bear the entire cost of providing GD tubes and their fitting as recommended by PTCC, including 15% spares and/or any other protective measures as recommended by PTCC.
10. The route approval shall be subject to special conditions as laid down under Annexure XXIV.

Annexure XXIII

1

- (a) Name of the Power Supply authority seeking approval M/s Adani Renewable Energy Thirty Seven Limited
- (b) Reference number & date: ARE37L/PTCC/25-26/BESS Khavda/001
Dated 11.10.2025
Undertaking for Provisional RAC Dated 12.02.2026
- (c) Name of the Power line 33 kV for Feeder No.1217 3C x 400 sqmm Al cable laid underground from 400/33 kV Substation (AGEL-PSS-5) to M/s Adani Renewable Energy Thirty Seven Limited Battery Energy Storage System (BESS) located near PSS-5, Khavda RE Park (Length: 1.430 kms)
- (d) Length of Power line: 1.430 kms
- (e) Operating Voltage 33 kV
- (f) Number of circuits 1

2

- (a) Names of parallel telecom lines: As per Annexure-XXIV
- (b) Length of parallelism: As per Annexure-XXIV
- 3 Average value of earth resistivity in the region: 5000 ohm-cms
- 4 Whether LF test necessary: No
- 5 Special conditions subject to which this certificate will be effective As per Annexure-XXIV

Annexure XXIV

Name of the Power Line: 33 kV for Feeder No.1217 3C x 400 sqmm Al cable laid underground from 400/33 kV Substation (AGEL-PSS-5) to M/s Adani Renewable Energy Thirty Seven Limited Battery Energy Storage System (BESS) located near PSS-5, Khavda RE Park (Length: 1.430 kms)

1. BSNL Telecom Details:

DET (PTCC), WZ, BSNL vide letter: IC/MBI/PTCC/Offline/GUJ-3175 dated 23.01.2026 has given their NOC.

2. Railway Telecom Details:

General Manager (S&T), Western Railway vide letter SG.158/28/12/1680 dated 05.12.2025 has issued their NOC.

3. EPR zone for the proposed substation is mentioned below:

Name of the proposed Substation	Half diagonal distance, D/2 (mts)	Fault Current I (KA)	Resistance of Earth Mat, R (ohms)	d (mts) at 430 V	d (mts) at 650 V	d (mts) at 7kV	d (mts) at 10kV
400/33 kV AGEL-PSS-5	121.97	63	0.3	5239	3425	207	109
33/0.69 kV BESS of M/s AGE37L	251	25	0.5	7046	4576	197	63

Telecom authorities to ensure the protection of telecom equipment and personnel within the EPR zone of the proposed substation at the cost of the later entrant.