



सत्यमेव जयते



भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
केन्द्रीय विद्युत प्राधिकरण
Central Electricity Authority
विद्युत प्रणाली संचार विकास प्रभाग
Power System Communication Development Division

On behalf of
 Central Level Power & Telecommunication Co-ordination Committee

No: As assigned**Date:** As assigned

Subject: Provisional Certificate of Approval for the Route of Power Line of M/s Kutch Copper Tubes Ltd.

Provisional Route Approval Certificate for the following listed lines of M/s Kutch Copper Tubes Ltd is annexed to this letter:

S.No.	Name
1	33 kV, 3C x 300 sqmm armoured HT UG cable feeder no. 0507 from 400/33 kV Substation PSS-8 to Solar Plant IDT block no. 13 (Plot No. 15A) of Kutch Copper Tubes Limited at Khavda RE Park (Length: 5.491 km)

Chief Engineer

To,

1.	M/s Kutch Copper Tubes Ltd	Adani Corporate House, Shnatigram, Nr. Vaishno Devi Circle, SG Highway, Khodiyar, Ahmedabad -382421
----	----------------------------	---

CEA Case No.: GUJ-1094 - Feeder -0507

Provisional Approval for the Route of Extra High Tension (EHT)/ High Tension (HT) Power Line / Telecommunication Line

Provisional Approval of the Central Level Power & Telecommunication Co-ordination Committee is hereby conveyed having a validity of 60 days from the date of issuance for **33 kV, 3C x 300 sqmm armoured HT UG cable feeder no. 0507 from 400/33 kV Substation PSS-8 to Solar Plant IDT block no. 13 (Plot No. 15A) of Kutch Copper Tubes Limited at Khavda RE Park (Length: 5.491 km)** particulars of which are given in Annexure I.

The approval is for the route only and is subject to the following conditions.

1. The approval is based on the Power system/ Telecom system conditions' details as reported by the Power supply authority/ Telecom authority at present. Any changes either to Transmission line or the Power system or the paralleling telecommunication lines which are likely to alter the low frequency induction from the estimated at present should be reported to PTCC for its prior approval.
2. The Power and Telecommunication authorities shall be required to adopt such measures as may be recommended by PTCC for counteracting any interference that might arise when the EHT line is in normal operation.
3. Each crossing should satisfy the conditions as laid down in Para 6 -10 of PTCC Code of Practice for crossings.
4. The angle of crossing shall be 90 degrees but in no case less than 60 degrees.
5. The power line shall be equipped with protective switchgear such that the duration of earth current shall be as short as possible but never exceeding 0.5 seconds.
6. The power line shall be energized within a mutually acceptable time limit after obtaining a Certificate from the concerned Telecom and/or Railway authority regarding completion of provision of all protective measures as recommended by PTCC and also under specific clearance from the Telecom and/or Railway authority maintaining the Telecom system.
7. The energization of Extra High Tension power lines would not be held up for want of installation of GD tubes on telecom lines when the induced voltages are in the range of 430 to 650 V.
8. The telecom line shall be commissioned within a mutually acceptable time after completing provision of all protective measures as recommended by PTCC and also after obtaining specific clearance from the Power authority, if certain measures as recommended by PTCC are to be carried out on power system.
9. The later entrant in the field shall bear the entire cost of providing GD tubes and their fitting as recommended by PTCC, including 15% spares and/or any other protective measures as recommended by PTCC.
10. The route approval shall be subject to special conditions as laid down under Annexure II.

Annexure I

1

- (a) Name of the Power Supply authority seeking approval M/s Kutch Copper Tubes Ltd
- (b) Reference number & date: KCTL/PTCC/25-26/Solar Khavda/001
Dated 27.12.2025
Undertaking for Provisional RAC Dated 25.02.2026
- (c) Name of the Power line 33 kV, 3C x 300 sqmm armoured HT UG cable feeder no. 0507 from 400/33 kV Substation PSS-8 to Solar Plant IDT block no. 13 (Plot No. 15A) of Kutch Copper Tubes Limited at Khavda RE Park (Length: 5.491 km)
- (d) Length of Power line: 5.491 km
- (e) Operating Voltage 33 kV
- (f) Number of circuits 1

2

- (a) Names of parallel telecom lines: As per Annexure-II
- (b) Length of parallelism: As per Annexure-II
- 3 Average value of earth resistivity in the region: 5000 ohm-cms
- 4 Whether LF test necessary: No
- 5 Special conditions subject to which this certificate will be effective As per Annexure-II

Annexure II

Name of the Power Line: 33 kV, 3C x 300 sqmm armoured HT UG cable feeder no. 0507 from 400/33 kV Substation PSS-8 to Solar Plant IDT block no. 13 (Plot No. 15A) of Kutch Copper Tubes Limited at Khavda RE Park (Length: 5.491 km)

1. BSNL Telecom Details:

DET (PTCC), WZ, BSNL vide letter: IC/MBI/PTCC/Offline/GUJ-3216 dated 28.01.2026 has given their NOC

2. Railway Telecom Details:

General Manager (S&T), Western Railway vide letter SG.158/28/12/1744 dated 09.02.2026 has issued their NOC

3. EPR zone for the proposed substation is mentioned below:

Name of the proposed Substation	Half diagonal distance, D/2 (mts)	Fault Current I (KA)	Resistance of Earth Mat, R (ohms)	d (mts) at 430 V	d (mts) at 650 V	d (mts) at 7kV	d (mts) at 10kV
400/33 kV PSS-08	122	63	0.3	5240	3425	207	109
33/0.8 kV Solar IDT	13	28	0.0029	N.A	N.A	N.A	N.A

Telecom authorities to ensure the protection of telecom equipment and personnel within the EPR zone of the proposed substation at the cost of the later entrant.