



सत्यमेव जयते



भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
केन्द्रीय विद्युत प्राधिकरण
Central Electricity Authority
विद्युत प्रणाली संचार विकास प्रभाग
Power System Communication Development Division

On behalf of
 Central Level Power & Telecommunication Co-ordination Committee

No: As assigned

Date: As assigned

Subject: Provisional Certificate of Approval for the Route of Power Line of M/s Khaba Renewable Energy Private Limited.

Provisional Route Approval Certificate for the following listed lines of M/s Khaba Renewable Energy Private Limited is annexed to this letter:

S.No.	Name
1	33 kV Underground Cable for 362.5MWp/250MW Solar Power Project developed by M/s Khaba Renewable Energy Pvt Ltd, at Village- Khodal, Tehsil- Sheo, District- Barmer, Rajasthan from IDT 1 to 220/33 kV KREPL 250 MW PSS at Khodal Village, Sheo Tehsil, Barmer (Length: 0.57 km)
2	33 kV Underground Cable Line for 362.5MWp/250MW Solar Power Project developing by M/s Khaba Renewable Energy Pvt Ltd, at Village- Khodal, Tehsil- Sheo, District- Barmer, Rajasthan From IDT 2 to 220/33 kV KREPL 250 MW PSS at Khodal Village, Sheo Tehsil, Barmer (Length: 0.462 km)
3	33 kV Underground Cable Line for 362.5MWp/250MW Solar Power Project developing by M/s Khaba Renewable Energy Pvt Ltd, at Village- Khodal, Tehsil- Sheo, District- Barmer, Rajasthan From IDT 3 to 220/33 kV KREPL 250 MW PSS at Khodal Village, Sheo Tehsil, Barmer (Length: 1.283 km)
4	33 kV Underground Cable Line for 362.5MWp/250MW Solar Power Project developing by M/s Khaba Renewable Energy Pvt Ltd, at Village- Khodal, Tehsil- Sheo, District- Barmer, Rajasthan From IDT4 to 220/33 kV KREPL 250 MW PSS at Khodal Village, Sheo Tehsil, Barmer (Length: 1.831 km)
5	33 kV Underground Cable Line for 362.5MWp/250MW Solar Power Project developing by M/s Khaba Renewable Energy Pvt Ltd, at Village- Khodal, Tehsil- Sheo, District- Barmer, Rajasthan From IDT 5 to 220/33 kV KREPL 250 MW PSS at Khodal Village, Sheo Tehsil, Barmer (Length: 1.102 km)

6	33 kV Underground Cable Line for 362.5MWp/250MW Solar Power Project developing by M/s Khaba Renewable Energy Pvt Ltd, at Village- Khodal, Tehsil- Sheo, District- Barmer, Rajasthan From IDT 6 to 220/33 kV KREPL 250 MW PSS at Khodal Village, Sheo Tehsil, Barmer (Length: 1.123 km)
7	33 kV Underground Cable Line for 362.5MWp/250MW Solar Power Project developing by M/s Khaba Renewable Energy Pvt Ltd, at Village- Khodal, Tehsil- Sheo, District- Barmer, Rajasthan From IDT 7 to 220/33 kV KREPL 250 MW PSS at Khodal Village, Sheo Tehsil, Barmer (Length: 1.551 km)
8	33 kV Underground Cable Line for 362.5MWp/250MW Solar Power Project developing by M/s Khaba Renewable Energy Pvt Ltd, at Village- Khodal, Tehsil- Sheo, District- Barmer, Rajasthan from IDT 8 to 220/33 kV KREPL 250 MW PSS at Khodal Village, Sheo Tehsil, Barmer (Length: 1.95 km)
9	33 kV Underground Cable Line for 362.5MWp/250MW Solar Power Project developing by M/s Khaba Renewable Energy Pvt Ltd, at Village- Khodal, Tehsil- Sheo, District- Barmer, Rajasthan From IDT 9 to 220/33 kV KREPL 250 MW PSS at Khodal Village, Sheo Tehsil, Barmer (Length: 2.308 km)
10	33 kV Underground Cable Line for 362.5MWp/250MW Solar Power Project developing by M/s Khaba Renewable Energy Pvt Ltd, at Village- Khodal, Tehsil- Sheo, District- Barmer, Rajasthan From IDT 10 to 220/33 kV KREPL 250 MW PSS at Khodal Village, Sheo Tehsil, Barmer (Length: 2.865 km)
11	33 kV Underground Cable Line for 362.5MWp/250MW Solar Power Project developing by M/s Khaba Renewable Energy Pvt Ltd, at Village- Khodal, Tehsil- Sheo, District- Barmer, Rajasthan From IDT 12 to 220/33 kV KREPL 250 MW PSS at Khodal Village, Sheo Tehsil, Barmer (Length: 2.327 km)
12	33 kV Underground Cable Line for 362.5MWp/250MW Solar Power Project developing by M/s Khaba Renewable Energy Pvt Ltd, at Village- Khodal, Tehsil- Sheo, District- Barmer, Rajasthan From IDT 13 to 220/33 kV KREPL 250 MW PSS at Khodal Village, Sheo Tehsil, Barmer (Length: 2.243 km)
13	33 kV Underground Cable Line for 362.5MWp/250MW Solar Power Project developing by M/s Khaba Renewable Energy Pvt Ltd, at Village- Khodal, Tehsil- Sheo, District- Barmer, Rajasthan From IDT 14 to 220/33 kV KREPL 250 MW PSS at Khodal Village, Sheo Tehsil, Barmer (Length: 1.98 km)
14	33 kV Underground Cable Line for 362.5MWp/250MW Solar Power Project developing by M/s Khaba Renewable Energy Pvt Ltd, at Village- Khodal, Tehsil- Sheo, District- Barmer, Rajasthan From IDT 15 to 220/33 kV KREPL 250 MW PSS at Khodal Village, Sheo Tehsil, Barmer (Length: 1.16 km)
15	33 kV Underground Cable Line for 362.5MWp/250MW Solar Power Project developing by M/s Khaba Renewable Energy Pvt Ltd, at Village- Khodal, Tehsil- Sheo, District- Barmer, Rajasthan From IDT 16 to 220/33 kV KREPL 250 MW PSS at Khodal Village, Sheo Tehsil, Barmer (Length: 2.178 km)
16	33 kV Underground Cable Line for 362.5MWp/250MW Solar Power Project developing by M/s Khaba Renewable Energy Pvt Ltd, at Village- Khodal, Tehsil- Sheo, District- Barmer, Rajasthan From IDT 17 to 220/33 kV KREPL 250 MW PSS at Khodal Village, Sheo Tehsil, Barmer (Length: 3.424 km)
17	33 kV Underground Cable Line for 362.5MWp/250MW Solar Power Project developing by M/s Khaba Renewable Energy Pvt Ltd, at Village- Khodal, Tehsil- Sheo, District- Barmer, Rajasthan From IDT 18 to 220/33 kV KREPL 250 MW PSS at Khodal Village, Sheo Tehsil, Barmer (Length: 3.992 km)

18	33 kV Underground Cable Line for 362.5MWp/250MW Solar Power Project developing by M/s Khaba Renewable Energy Pvt Ltd, at Village- Khodal, Tehsil- Sheo, District- Barmer, Rajasthan From IDT 22 to 220/33 kV KREPL 250 MW PSS at Khodal Village, Sheo Tehsil, Barmer (Length: 2.86 km)
----	--

Chief Engineer

To,

1.	M/s Khaba Renewable Energy Private Limited	14th Floor, Vatika Tower-B, DLF Golf Course Road, Suncity, Sector 54, Gurugram – 122 033
----	--	--

CEA Case No.: RAJ-972 - A

Provisional Approval for the Route of Extra High Tension (EHT)/ High Tension (HT) Power Line / Telecommunication Line

Provisional Approval of the Central Level Power & Telecommunication Co-ordination Committee is hereby conveyed having a validity of 60 days from the date of issuance for **33 kV Underground Cable for 362.5MWp/250MW Solar Power Project developed by M/s Khaba Renewable Energy Pvt Ltd, at Village- Khodal, Tehsil- Sheo, District- Barmer, Rajasthan from IDT 1 to 220/33 kV KREPL 250 MW PSS at Khodal Village, Sheo Tehsil, Barmer (Length: 0.57 km)** particulars of which are given in Annexure I.

The approval is for the route only and is subject to the following conditions.

1. The approval is based on the Power system/ Telecom system conditions' details as reported by the Power supply authority/ Telecom authority at present. Any changes either to Transmission line or the Power system or the paralleling telecommunication lines which are likely to alter the low frequency induction from the estimated at present should be reported to PTCC for its prior approval.
2. The Power and Telecommunication authorities shall be required to adopt such measures as may be recommended by PTCC for counteracting any interference that might arise when the EHT line is in normal operation.
3. Each crossing should satisfy the conditions as laid down in Para 6 -10 of PTCC Code of Practice for crossings.
4. The angle of crossing shall be 90 degrees but in no case less than 60 degrees.
5. The power line shall be equipped with protective switchgear such that the duration of earth current shall be as short as possible but never exceeding 0.5 seconds.
6. The power line shall be energized within a mutually acceptable time limit after obtaining a Certificate from the concerned Telecom and/or Railway authority regarding completion of provision of all protective measures as recommended by PTCC and also under specific clearance from the Telecom and/or Railway authority maintaining the Telecom system.
7. The energization of Extra High Tension power lines would not be held up for want of installation of GD tubes on telecom lines when the induced voltages are in the range of 430 to 650 V.
8. The telecom line shall be commissioned within a mutually acceptable time after completing provision of all protective measures as recommended by PTCC and also after obtaining specific clearance from the Power authority, if certain measures as recommended by PTCC are to be carried out on power system.
9. The later entrant in the field shall bear the entire cost of providing GD tubes and their fitting as recommended by PTCC, including 15% spares and/or any other protective measures as recommended by PTCC.
10. The route approval shall be subject to special conditions as laid down under Annexure II.

Annexure I

1

- | | | |
|-----|---|---|
| (a) | Name of the Power Supply authority seeking approval | M/s Khaba Renewable Energy Private Limited |
| (b) | Reference number & date: | NHPC/25-26/031 dated 31.12.2025
E-mail dated 24.02.2026 |
| (c) | Name of the Power line | 33 kV Underground Cable for 362.5MWp/250MW Solar Power Project developed by M/s Khaba Renewable Energy Pvt Ltd, at Village- Khodal, Tehsil- Sheo, District- Barmer, Rajasthan from IDT 1 to 220/33 kV KREPL 250 MW PSS at Khodal Village, Sheo Tehsil, Barmer (Length: 0.57 km) |
| (d) | Length of Power line: | 0.57 km |
| (e) | Operating Voltage | 33 kV |
| (f) | Number of circuits | 1 |

2

- | | | |
|-----|--|--------------------|
| (a) | Names of parallel telecom lines: | As per Annexure-II |
| (b) | Length of parallelism: | As per Annexure-II |
| 3 | Average value of earth resistivity in the region: | 2500 ohm-cms |
| 4 | Whether LF test necessary: | No |
| 5 | Special conditions subject to which this certificate will be effective | As per Annexure-II |

Annexure II

Name of the Power Line: 33 kV Underground Cable for 362.5MWp/250MW Solar Power Project developed by M/s Khaba Renewable Energy Pvt Ltd, at Village- Khodal, Tehsil- Sheo, District- Barmer, Rajasthan from IDT 1 to 220/33 kV KREPL 250 MW PSS at Khodal Village, Sheo Tehsil, Barmer (Length: 0.57 km)

1. BSNL Telecom Details:

AGM (CFA), CO Jaipur, BSNL vide letter RJCO-19/16(13)/3/2020-CFA/19012 dated 02.02.2026 has stated non-existence of any BSNL telecom assets within the 5 km periphery of proposed route. Thus, BSNL letter is taken as Deemed NOC.

2. Railway Telecom Details:

Deputy CSTE, Telecom, North Western Railway vide letter SG/158/NWR/PTCC/1320 dated 04.02.2026 has given their NOC for charging of the line.

3. EPR zone for the proposed substation is mentioned below:

Name of the proposed Substation	Half diagonal distance, D/2 (mts)	Fault Current I (KA)	Resistance of Earth Mat, R (ohms)	d (mts) at 430 V	d (mts) at 650 V	d (mts) at 7kV	d (mts) at 10kV
220/33 kV KREPL 250 MW PSS at Khodal Village, Sheo Tehsil, Barmer	93.49	35	0.225	1619	1039	12	N.A
ICR	13.28	15.774	0.1	35	19	N.A	N.A

Telecom authorities to ensure the protection of telecom equipment and personnel within the EPR zone of the proposed substation at the cost of the later entrant.

CEA Case No.: RAJ-972 - B

Provisional Approval for the Route of Extra High Tension (EHT)/ High Tension (HT) Power Line / Telecommunication Line

Provisional Approval of the Central Level Power & Telecommunication Co-ordination Committee is hereby conveyed having a validity of 60 days from the date of issuance for **33 kV Underground Cable Line for 362.5MWp/250MW Solar Power Project developing by M/s Khaba Renewable Energy Pvt Ltd, at Village- Khodal, Tehsil- Sheo, District- Barmer, Rajasthan From IDT 2 to 220/33 kV KREPL 250 MW PSS at Khodal Village, Sheo Tehsil, Barmer (Length: 0.462 km)** particulars of which are given in Annexure III.

The approval is for the route only and is subject to the following conditions.

1. The approval is based on the Power system/ Telecom system conditions' details as reported by the Power supply authority/ Telecom authority at present. Any changes either to Transmission line or the Power system or the paralleling telecommunication lines which are likely to alter the low frequency induction from the estimated at present should be reported to PTCC for its prior approval.
2. The Power and Telecommunication authorities shall be required to adopt such measures as may be recommended by PTCC for counteracting any interference that might arise when the EHT line is in normal operation.
3. Each crossing should satisfy the conditions as laid down in Para 6 -10 of PTCC Code of Practice for crossings.
4. The angle of crossing shall be 90 degrees but in no case less than 60 degrees.
5. The power line shall be equipped with protective switchgear such that the duration of earth current shall be as short as possible but never exceeding 0.5 seconds.
6. The power line shall be energized within a mutually acceptable time limit after obtaining a Certificate from the concerned Telecom and/or Railway authority regarding completion of provision of all protective measures as recommended by PTCC and also under specific clearance from the Telecom and/or Railway authority maintaining the Telecom system.
7. The energization of Extra High Tension power lines would not be held up for want of installation of GD tubes on telecom lines when the induced voltages are in the range of 430 to 650 V.
8. The telecom line shall be commissioned within a mutually acceptable time after completing provision of all protective measures as recommended by PTCC and also after obtaining specific clearance from the Power authority, if certain measures as recommended by PTCC are to be carried out on power system.
9. The later entrant in the field shall bear the entire cost of providing GD tubes and their fitting as recommended by PTCC, including 15% spares and/or any other protective measures as recommended by PTCC.
10. The route approval shall be subject to special conditions as laid down under Annexure IV.

Annexure III

1

- (a) Name of the Power Supply authority seeking approval M/s Khaba Renewable Energy Private Limited
- (b) Reference number & date: NHPC/25-26/031 dated 31.12.2025
E-mail dated 24.02.2026
- (c) Name of the Power line 33 kV Underground Cable Line for 362.5MWp/250MW Solar Power Project developing by M/s Khaba Renewable Energy Pvt Ltd, at Village- Khodal, Tehsil-Sheo, District- Barmer, Rajasthan From IDT 2 to 220/33 kV KREPL 250 MW PSS at Khodal Village, Sheo Tehsil, Barmer (Length: 0.462 km)
- (d) Length of Power line: 0.462 km
- (e) Operating Voltage 33 kV
- (f) Number of circuits 1

2

- (a) Names of parallel telecom lines: As per Annexure-IV
- (b) Length of parallelism: As per Annexure-IV
- 3 Average value of earth resistivity in the region: 2500 ohm-cms
- 4 Whether LF test necessary: No
- 5 Special conditions subject to which this certificate will be effective As per Annexure-IV

Annexure IV

Name of the Power Line: 33 kV Underground Cable Line for 362.5MWp/250MW Solar Power Project developing by M/s Khaba Renewable Energy Pvt Ltd, at Village- Khodal, Tehsil- Sheo, District- Barmer, Rajasthan From IDT 2 to 220/33 kV KREPL 250 MW PSS at Khodal Village, Sheo Tehsil, Barmer (Length: 0.462 km)

1. BSNL Telecom Details:

AGM (CFA), CO Jaipur, BSNL vide letter RJCO-19/16(13)/3/2020-CFA/19012 dated 02.02.2026 has stated non-existence of any BSNL telecom assets within the 5 km periphery of proposed route. Thus, BSNL letter is taken as Deemed NOC.

2. Railway Telecom Details:

Deputy CSTE, Telecom, North Western Railway vide letter SG/158/NWR/PTCC/1320 dated 04.02.2026 has given their NOC for charging of the line.

3. EPR zone for the proposed substation is mentioned below:

Name of the proposed Substation	Half diagonal distance, D/2 (mts)	Fault Current I (KA)	Resistance of Earth Mat, R (ohms)	d (mts) at 430 V	d (mts) at 650 V	d (mts) at 7kV	d (mts) at 10kV
220/33 kV KREPL 250 MW PSS at Khodal Village, Sheo Tehsil, Barmer	93.49	35	0.225	1619	1039	12	N.A
ICR	13.28	15.774	0.1	35	19	N.A	N.A

Telecom authorities to ensure the protection of telecom equipment and personnel within the EPR zone of the proposed substation at the cost of the later entrant.

CEA Case No.: RAJ-972 - C

Provisional Approval for the Route of Extra High Tension (EHT)/ High Tension (HT) Power Line / Telecommunication Line

Provisional Approval of the Central Level Power & Telecommunication Co-ordination Committee is hereby conveyed having a validity of 60 days from the date of issuance for **33 kV Underground Cable Line for 362.5MWp/250MW Solar Power Project developing by M/s Khaba Renewable Energy Pvt Ltd, at Village- Khodal, Tehsil- Sheo, District- Barmer, Rajasthan From IDT 3 to 220/33 kV KREPL 250 MW PSS at Khodal Village, Sheo Tehsil, Barmer (Length: 1.283 km)** particulars of which are given in Annexure V.

The approval is for the route only and is subject to the following conditions.

1. The approval is based on the Power system/ Telecom system conditions' details as reported by the Power supply authority/ Telecom authority at present. Any changes either to Transmission line or the Power system or the paralleling telecommunication lines which are likely to alter the low frequency induction from the estimated at present should be reported to PTCC for its prior approval.
2. The Power and Telecommunication authorities shall be required to adopt such measures as may be recommended by PTCC for counteracting any interference that might arise when the EHT line is in normal operation.
3. Each crossing should satisfy the conditions as laid down in Para 6 -10 of PTCC Code of Practice for crossings.
4. The angle of crossing shall be 90 degrees but in no case less than 60 degrees.
5. The power line shall be equipped with protective switchgear such that the duration of earth current shall be as short as possible but never exceeding 0.5 seconds.
6. The power line shall be energized within a mutually acceptable time limit after obtaining a Certificate from the concerned Telecom and/or Railway authority regarding completion of provision of all protective measures as recommended by PTCC and also under specific clearance from the Telecom and/or Railway authority maintaining the Telecom system.
7. The energization of Extra High Tension power lines would not be held up for want of installation of GD tubes on telecom lines when the induced voltages are in the range of 430 to 650 V.
8. The telecom line shall be commissioned within a mutually acceptable time after completing provision of all protective measures as recommended by PTCC and also after obtaining specific clearance from the Power authority, if certain measures as recommended by PTCC are to be carried out on power system.
9. The later entrant in the field shall bear the entire cost of providing GD tubes and their fitting as recommended by PTCC, including 15% spares and/or any other protective measures as recommended by PTCC.
10. The route approval shall be subject to special conditions as laid down under Annexure VI.

Annexure V

1

- (a) Name of the Power Supply authority seeking approval M/s Khaba Renewable Energy Private Limited
- (b) Reference number & date: NHPC/25-26/031 dated 31.12.2025
E-mail dated 24.02.2026
- (c) Name of the Power line 33 kV Underground Cable Line for 362.5MWp/250MW Solar Power Project developing by M/s Khaba Renewable Energy Pvt Ltd, at Village- Khodal, Tehsil-Sheo, District- Barmer, Rajasthan From IDT 3 to 220/33 kV KREPL 250 MW PSS at Khodal Village, Sheo Tehsil, Barmer (Length: 1.283 km)
- (d) Length of Power line: 1.283 km
- (e) Operating Voltage 33 kV
- (f) Number of circuits 1

2

- (a) Names of parallel telecom lines: As per Annexure-VI
- (b) Length of parallelism: As per Annexure-VI
- 3 Average value of earth resistivity in the region: 2500 ohm-cms
- 4 Whether LF test necessary: No
- 5 Special conditions subject to which this certificate will be effective As per Annexure-VI

Annexure VI

Name of the Power Line: 33 kV Underground Cable Line for 362.5MWp/250MW Solar Power Project developing by M/s Khaba Renewable Energy Pvt Ltd, at Village- Khodal, Tehsil- Sheo, District- Barmer, Rajasthan From IDT 3 to 220/33 kV KREPL 250 MW PSS at Khodal Village, Sheo Tehsil, Barmer (Length: 1.283 km)

1. BSNL Telecom Details:

AGM (CFA), CO Jaipur, BSNL vide letter RJCO-19/16(13)/3/2020-CFA/19012 dated 02.02.2026 has stated non-existence of any BSNL telecom assets within the 5 km periphery of proposed route. Thus, BSNL letter is taken as Deemed NOC.

2. Railway Telecom Details:

Deputy CSTE, Telecom, North Western Railway vide letter SG/158/NWR/PTCC/1320 dated 04.02.2026 has given their NOC for charging of the line.

3. EPR zone for the proposed substation is mentioned below:

Name of the proposed Substation	Half diagonal distance, D/2 (mts)	Fault Current I (KA)	Resistance of Earth Mat, R (ohms)	d (mts) at 430 V	d (mts) at 650 V	d (mts) at 7kV	d (mts) at 10kV
220/33 kV KREPL 250 MW PSS at Khodal Village, Sheo Tehsil, Barmer	93.49	35	0.225	1619	1039	12	N.A
ICR	13.28	15.774	0.1	35	19	N.A	N.A

Telecom authorities to ensure the protection of telecom equipment and personnel within the EPR zone of the proposed substation at the cost of the later entrant.

CEA Case No.: RAJ-972 - D

Provisional Approval for the Route of Extra High Tension (EHT)/ High Tension (HT) Power Line / Telecommunication Line

Provisional Approval of the Central Level Power & Telecommunication Co-ordination Committee is hereby conveyed having a validity of 60 days from the date of issuance for **33 kV Underground Cable Line for 362.5MWp/250MW Solar Power Project developing by M/s Khaba Renewable Energy Pvt Ltd, at Village- Khodal, Tehsil- Sheo, District- Barmer, Rajasthan From IDT4 to 220/33 kV KREPL 250 MW PSS at Khodal Village, Sheo Tehsil, Barmer (Length: 1.831 km)** particulars of which are given in Annexure VII.

The approval is for the route only and is subject to the following conditions.

1. The approval is based on the Power system/ Telecom system conditions' details as reported by the Power supply authority/ Telecom authority at present. Any changes either to Transmission line or the Power system or the paralleling telecommunication lines which are likely to alter the low frequency induction from the estimated at present should be reported to PTCC for its prior approval.
2. The Power and Telecommunication authorities shall be required to adopt such measures as may be recommended by PTCC for counteracting any interference that might arise when the EHT line is in normal operation.
3. Each crossing should satisfy the conditions as laid down in Para 6 -10 of PTCC Code of Practice for crossings.
4. The angle of crossing shall be 90 degrees but in no case less than 60 degrees.
5. The power line shall be equipped with protective switchgear such that the duration of earth current shall be as short as possible but never exceeding 0.5 seconds.
6. The power line shall be energized within a mutually acceptable time limit after obtaining a Certificate from the concerned Telecom and/or Railway authority regarding completion of provision of all protective measures as recommended by PTCC and also under specific clearance from the Telecom and/or Railway authority maintaining the Telecom system.
7. The energization of Extra High Tension power lines would not be held up for want of installation of GD tubes on telecom lines when the induced voltages are in the range of 430 to 650 V.
8. The telecom line shall be commissioned within a mutually acceptable time after completing provision of all protective measures as recommended by PTCC and also after obtaining specific clearance from the Power authority, if certain measures as recommended by PTCC are to be carried out on power system.
9. The later entrant in the field shall bear the entire cost of providing GD tubes and their fitting as recommended by PTCC, including 15% spares and/or any other protective measures as recommended by PTCC.
10. The route approval shall be subject to special conditions as laid down under Annexure VIII.

Annexure VII

1

- (a) Name of the Power Supply authority seeking approval M/s Khaba Renewable Energy Private Limited
- (b) Reference number & date: NHPC/25-26/031 dated 31.12.2025
E-mail dated 24.02.2026
- (c) Name of the Power line 33 kV Underground Cable Line for 362.5MWp/250MW Solar Power Project developing by M/s Khaba Renewable Energy Pvt Ltd, at Village- Khodal, Tehsil-Sheo, District- Barmer, Rajasthan From IDT4 to 220/33 kV KREPL 250 MW PSS at Khodal Village, Sheo Tehsil, Barmer (Length: 1.831 km)
- (d) Length of Power line: 1.831 km
- (e) Operating Voltage 33 kV
- (f) Number of circuits 1

2

- (a) Names of parallel telecom lines: As per Annexure-VIII
- (b) Length of parallelism: As per Annexure-VIII
- 3 Average value of earth resistivity in the region: 2500 ohm-cms
- 4 Whether LF test necessary: No
- 5 Special conditions subject to which this certificate will be effective As per Annexure-VIII

Annexure VIII

Name of the Power Line: 33 kV Underground Cable Line for 362.5MWp/250MW Solar Power Project developing by M/s Khaba Renewable Energy Pvt Ltd, at Village- Khodal, Tehsil- Sheo, District- Barmer, Rajasthan From IDT4 to 220/33 kV KREPL 250 MW PSS at Khodal Village, Sheo Tehsil, Barmer (Length: 1.831 km)

1. BSNL Telecom Details:

AGM (CFA), CO Jaipur, BSNL vide letter RJCO-19/16(13)/3/2020-CFA/19012 dated 02.02.2026 has stated non-existence of any BSNL telecom assets within the 5 km periphery of proposed route. Thus, BSNL letter is taken as Deemed NOC.

2. Railway Telecom Details:

Deputy CSTE, Telecom, North Western Railway vide letter SG/158/NWR/PTCC/1320 dated 04.02.2026 has given their NOC for charging of the line.

3. EPR zone for the proposed substation is mentioned below:

Name of the proposed Substation	Half diagonal distance, D/2 (mts)	Fault Current I (KA)	Resistance of Earth Mat, R (ohms)	d (mts) at 430 V	d (mts) at 650 V	d (mts) at 7kV	d (mts) at 10kV
220/33 kV KREPL 250 MW PSS at Khodal Village, Sheo Tehsil, Barmer	93.49	35	0.225	1619	1039	12	N.A
ICR	13.28	15.774	0.1	35	19	N.A	N.A

Telecom authorities to ensure the protection of telecom equipment and personnel within the EPR zone of the proposed substation at the cost of the later entrant.

CEA Case No.: RAJ-972 - E

Provisional Approval for the Route of Extra High Tension (EHT)/ High Tension (HT) Power Line / Telecommunication Line

Provisional Approval of the Central Level Power & Telecommunication Co-ordination Committee is hereby conveyed having a validity of 60 days from the date of issuance for **33 kV Underground Cable Line for 362.5MWp/250MW Solar Power Project developing by M/s Khaba Renewable Energy Pvt Ltd, at Village- Khodal, Tehsil- Sheo, District- Barmer, Rajasthan From IDT 5 to 220/33 kV KREPL 250 MW PSS at Khodal Village, Sheo Tehsil, Barmer (Length: 1.102 km)** particulars of which are given in Annexure IX.

The approval is for the route only and is subject to the following conditions.

1. The approval is based on the Power system/ Telecom system conditions' details as reported by the Power supply authority/ Telecom authority at present. Any changes either to Transmission line or the Power system or the paralleling telecommunication lines which are likely to alter the low frequency induction from the estimated at present should be reported to PTCC for its prior approval.
2. The Power and Telecommunication authorities shall be required to adopt such measures as may be recommended by PTCC for counteracting any interference that might arise when the EHT line is in normal operation.
3. Each crossing should satisfy the conditions as laid down in Para 6 -10 of PTCC Code of Practice for crossings.
4. The angle of crossing shall be 90 degrees but in no case less than 60 degrees.
5. The power line shall be equipped with protective switchgear such that the duration of earth current shall be as short as possible but never exceeding 0.5 seconds.
6. The power line shall be energized within a mutually acceptable time limit after obtaining a Certificate from the concerned Telecom and/or Railway authority regarding completion of provision of all protective measures as recommended by PTCC and also under specific clearance from the Telecom and/or Railway authority maintaining the Telecom system.
7. The energization of Extra High Tension power lines would not be held up for want of installation of GD tubes on telecom lines when the induced voltages are in the range of 430 to 650 V.
8. The telecom line shall be commissioned within a mutually acceptable time after completing provision of all protective measures as recommended by PTCC and also after obtaining specific clearance from the Power authority, if certain measures as recommended by PTCC are to be carried out on power system.
9. The later entrant in the field shall bear the entire cost of providing GD tubes and their fitting as recommended by PTCC, including 15% spares and/or any other protective measures as recommended by PTCC.
10. The route approval shall be subject to special conditions as laid down under Annexure X.

Annexure IX

1

- (a) Name of the Power Supply authority seeking approval M/s Khaba Renewable Energy Private Limited
- (b) Reference number & date: NHPC/25-26/031 dated 31.12.2025
E-mail dated 24.02.2026
- (c) Name of the Power line 33 kV Underground Cable Line for 362.5MWp/250MW Solar Power Project developing by M/s Khaba Renewable Energy Pvt Ltd, at Village- Khodal, Tehsil-Sheo, District- Barmer, Rajasthan From IDT 5 to 220/33 kV KREPL 250 MW PSS at Khodal Village, Sheo Tehsil, Barmer (Length: 1.102 km)
- (d) Length of Power line: 1.102 km
- (e) Operating Voltage 33 kV
- (f) Number of circuits 1

2

- (a) Names of parallel telecom lines: As per Annexure-X
- (b) Length of parallelism: As per Annexure-X
- 3 Average value of earth resistivity in the region: 2500 ohm-cms
- 4 Whether LF test necessary: No
- 5 Special conditions subject to which this certificate will be effective As per Annexure-X

Annexure X

Name of the Power Line: 33 kV Underground Cable Line for 362.5MWp/250MW Solar Power Project developing by M/s Khaba Renewable Energy Pvt Ltd, at Village- Khodal, Tehsil- Sheo, District- Barmer, Rajasthan From IDT 5 to 220/33 kV KREPL 250 MW PSS at Khodal Village, Sheo Tehsil, Barmer (Length: 1.102 km)

1. BSNL Telecom Details:

AGM (CFA), CO Jaipur, BSNL vide letter RJCO-19/16(13)/3/2020-CFA/19012 dated 02.02.2026 has stated non-existence of any BSNL telecom assets within the 5 km periphery of proposed route. Thus, BSNL letter is taken as Deemed NOC.

2. Railway Telecom Details:

Deputy CSTE, Telecom, North Western Railway vide letter SG/158/NWR/PTCC/1320 dated 04.02.2026 has given their NOC for charging of the line.

3. EPR zone for the proposed substation is mentioned below:

Name of the proposed Substation	Half diagonal distance, D/2 (mts)	Fault Current I (KA)	Resistance of Earth Mat, R (ohms)	d (mts) at 430 V	d (mts) at 650 V	d (mts) at 7kV	d (mts) at 10kV
220/33 kV KREPL 250 MW PSS at Khodal Village, Sheo Tehsil, Barmer	93.49	35	0.225	1619	1039	12	N.A
ICR	13.28	15.774	0.1	35	19	N.A	N.A

Telecom authorities to ensure the protection of telecom equipment and personnel within the EPR zone of the proposed substation at the cost of the later entrant.

CEA Case No.: RAJ-972 - F

Provisional Approval for the Route of Extra High Tension (EHT)/ High Tension (HT) Power Line / Telecommunication Line

Provisional Approval of the Central Level Power & Telecommunication Co-ordination Committee is hereby conveyed having a validity of 60 days from the date of issuance for **33 kV Underground Cable Line for 362.5MWp/250MW Solar Power Project developing by M/s Khaba Renewable Energy Pvt Ltd, at Village- Khodal, Tehsil- Sheo, District- Barmer, Rajasthan From IDT 6 to 220/33 kV KREPL 250 MW PSS at Khodal Village, Sheo Tehsil, Barmer (Length: 1.123 km)** particulars of which are given in Annexure XI.

The approval is for the route only and is subject to the following conditions.

1. The approval is based on the Power system/ Telecom system conditions' details as reported by the Power supply authority/ Telecom authority at present. Any changes either to Transmission line or the Power system or the paralleling telecommunication lines which are likely to alter the low frequency induction from the estimated at present should be reported to PTCC for its prior approval.
2. The Power and Telecommunication authorities shall be required to adopt such measures as may be recommended by PTCC for counteracting any interference that might arise when the EHT line is in normal operation.
3. Each crossing should satisfy the conditions as laid down in Para 6 -10 of PTCC Code of Practice for crossings.
4. The angle of crossing shall be 90 degrees but in no case less than 60 degrees.
5. The power line shall be equipped with protective switchgear such that the duration of earth current shall be as short as possible but never exceeding 0.5 seconds.
6. The power line shall be energized within a mutually acceptable time limit after obtaining a Certificate from the concerned Telecom and/or Railway authority regarding completion of provision of all protective measures as recommended by PTCC and also under specific clearance from the Telecom and/or Railway authority maintaining the Telecom system.
7. The energization of Extra High Tension power lines would not be held up for want of installation of GD tubes on telecom lines when the induced voltages are in the range of 430 to 650 V.
8. The telecom line shall be commissioned within a mutually acceptable time after completing provision of all protective measures as recommended by PTCC and also after obtaining specific clearance from the Power authority, if certain measures as recommended by PTCC are to be carried out on power system.
9. The later entrant in the field shall bear the entire cost of providing GD tubes and their fitting as recommended by PTCC, including 15% spares and/or any other protective measures as recommended by PTCC.
10. The route approval shall be subject to special conditions as laid down under Annexure XII.

Annexure XI

1

- (a) Name of the Power Supply authority seeking approval M/s Khaba Renewable Energy Private Limited
- (b) Reference number & date: NHPC/25-26/031 dated 31.12.2025
E-mail dated 24.02.2026
- (c) Name of the Power line 33 kV Underground Cable Line for 362.5MWp/250MW Solar Power Project developing by M/s Khaba Renewable Energy Pvt Ltd, at Village- Khodal, Tehsil-Sheo, District- Barmer, Rajasthan From IDT 6 to 220/33 kV KREPL 250 MW PSS at Khodal Village, Sheo Tehsil, Barmer (Length: 1.123 km)
- (d) Length of Power line: 1.123 km
- (e) Operating Voltage 33 kV
- (f) Number of circuits 1

2

- (a) Names of parallel telecom lines: As per Annexure-XII
- (b) Length of parallelism: As per Annexure-XII

3 Average value of earth resistivity in the region: 2500 ohm-cms

4 Whether LF test necessary: No

5 Special conditions subject to which this certificate will be effective As per Annexure-XII

Annexure XII

Name of the Power Line: 33 kV Underground Cable Line for 362.5MWp/250MW Solar Power Project developing by M/s Khaba Renewable Energy Pvt Ltd, at Village- Khodal, Tehsil- Sheo, District- Barmer, Rajasthan From IDT 6 to 220/33 kV KREPL 250 MW PSS at Khodal Village, Sheo Tehsil, Barmer (Length: 1.123 km)

1. BSNL Telecom Details:

AGM (CFA), CO Jaipur, BSNL vide letter RJCO-19/16(13)/3/2020-CFA/19012 dated 02.02.2026 has stated non-existence of any BSNL telecom assets within the 5 km periphery of proposed route. Thus, BSNL letter is taken as Deemed NOC.

2. Railway Telecom Details:

Deputy CSTE, Telecom, North Western Railway vide letter SG/158/NWR/PTCC/1320 dated 04.02.2026 has given their NOC for charging of the line.

3. EPR zone for the proposed substation is mentioned below:

Name of the proposed Substation	Half diagonal distance, D/2 (mts)	Fault Current I (KA)	Resistance of Earth Mat, R (ohms)	d (mts) at 430 V	d (mts) at 650 V	d (mts) at 7kV	d (mts) at 10kV
220/33 kV KREPL 250 MW PSS at Khodal Village, Sheo Tehsil, Barmer	93.49	35	0.225	1619	1039	12	N.A
ICR	13.28	15.774	0.1	35	19	N.A	N.A

Telecom authorities to ensure the protection of telecom equipment and personnel within the EPR zone of the proposed substation at the cost of the later entrant.

CEA Case No.: RAJ-972 - G

Provisional Approval for the Route of Extra High Tension (EHT)/ High Tension (HT) Power Line / Telecommunication Line

Provisional Approval of the Central Level Power & Telecommunication Co-ordination Committee is hereby conveyed having a validity of 60 days from the date of issuance for **33 kV Underground Cable Line for 362.5MWp/250MW Solar Power Project developing by M/s Khaba Renewable Energy Pvt Ltd, at Village- Khodal, Tehsil- Sheo, District- Barmer, Rajasthan From IDT 7 to 220/33 kV KREPL 250 MW PSS at Khodal Village, Sheo Tehsil, Barmer (Length: 1.551 km)** particulars of which are given in Annexure XIII.

The approval is for the route only and is subject to the following conditions.

1. The approval is based on the Power system/ Telecom system conditions' details as reported by the Power supply authority/ Telecom authority at present. Any changes either to Transmission line or the Power system or the paralleling telecommunication lines which are likely to alter the low frequency induction from the estimated at present should be reported to PTCC for its prior approval.
2. The Power and Telecommunication authorities shall be required to adopt such measures as may be recommended by PTCC for counteracting any interference that might arise when the EHT line is in normal operation.
3. Each crossing should satisfy the conditions as laid down in Para 6 -10 of PTCC Code of Practice for crossings.
4. The angle of crossing shall be 90 degrees but in no case less than 60 degrees.
5. The power line shall be equipped with protective switchgear such that the duration of earth current shall be as short as possible but never exceeding 0.5 seconds.
6. The power line shall be energized within a mutually acceptable time limit after obtaining a Certificate from the concerned Telecom and/or Railway authority regarding completion of provision of all protective measures as recommended by PTCC and also under specific clearance from the Telecom and/or Railway authority maintaining the Telecom system.
7. The energization of Extra High Tension power lines would not be held up for want of installation of GD tubes on telecom lines when the induced voltages are in the range of 430 to 650 V.
8. The telecom line shall be commissioned within a mutually acceptable time after completing provision of all protective measures as recommended by PTCC and also after obtaining specific clearance from the Power authority, if certain measures as recommended by PTCC are to be carried out on power system.
9. The later entrant in the field shall bear the entire cost of providing GD tubes and their fitting as recommended by PTCC, including 15% spares and/or any other protective measures as recommended by PTCC.
10. The route approval shall be subject to special conditions as laid down under Annexure XIV.

Annexure XIII

1

- (a) Name of the Power Supply authority seeking approval M/s Khaba Renewable Energy Private Limited
- (b) Reference number & date: NHPC/25-26/031 dated 31.12.2025
E-mail dated 24.02.2026
- (c) Name of the Power line 33 kV Underground Cable Line for 362.5MWp/250MW Solar Power Project developing by M/s Khaba Renewable Energy Pvt Ltd, at Village- Khodal, Tehsil-Sheo, District- Barmer, Rajasthan From IDT 7 to 220/33 kV KREPL 250 MW PSS at Khodal Village, Sheo Tehsil, Barmer (Length: 1.551 km)
- (d) Length of Power line: 1.551 km
- (e) Operating Voltage 33 kV
- (f) Number of circuits 1

2

- (a) Names of parallel telecom lines: As per Annexure-XIV
- (b) Length of parallelism: As per Annexure-XIV
- 3 Average value of earth resistivity in the region: 2500 ohm-cms
- 4 Whether LF test necessary: No
- 5 Special conditions subject to which this certificate will be effective As per Annexure-XIV

Annexure XIV

Name of the Power Line: 33 kV Underground Cable Line for 362.5MWp/250MW Solar Power Project developing by M/s Khaba Renewable Energy Pvt Ltd, at Village- Khodal, Tehsil- Sheo, District- Barmer, Rajasthan From IDT 7 to 220/33 kV KREPL 250 MW PSS at Khodal Village, Sheo Tehsil, Barmer (Length: 1.551 km)

1. BSNL Telecom Details:

AGM (CFA), CO Jaipur, BSNL vide letter RJCO-19/16(13)/3/2020-CFA/19012 dated 02.02.2026 has stated non-existence of any BSNL telecom assets within the 5 km periphery of proposed route. Thus, BSNL letter is taken as Deemed NOC.

2. Railway Telecom Details:

Deputy CSTE, Telecom, North Western Railway vide letter SG/158/NWR/PTCC/1320 dated 04.02.2026 has given their NOC for charging of the line.

3. EPR zone for the proposed substation is mentioned below:

Name of the proposed Substation	Half diagonal distance, D/2 (mts)	Fault Current I (KA)	Resistance of Earth Mat, R (ohms)	d (mts) at 430 V	d (mts) at 650 V	d (mts) at 7kV	d (mts) at 10kV
220/33 kV KREPL 250 MW PSS at Khodal Village, Sheo Tehsil, Barmer	93.49	35	0.225	1619	1039	12	N.A
ICR	13.28	15.774	0.1	35	19	N.A	N.A

Telecom authorities to ensure the protection of telecom equipment and personnel within the EPR zone of the proposed substation at the cost of the later entrant.

CEA Case No.: RAJ-972 - H

Provisional Approval for the Route of Extra High Tension (EHT)/ High Tension (HT) Power Line / Telecommunication Line

Provisional Approval of the Central Level Power & Telecommunication Co-ordination Committee is hereby conveyed having a validity of 60 days from the date of issuance for **33 kV Underground Cable Line for 362.5MWp/250MW Solar Power Project developing by M/s Khaba Renewable Energy Pvt Ltd, at Village- Khodal, Tehsil- Sheo, District- Barmer, Rajasthan from IDT 8 to 220/33 kV KREPL 250 MW PSS at Khodal Village, Sheo Tehsil, Barmer (Length: 1.95 km)** particulars of which are given in Annexure XV.

The approval is for the route only and is subject to the following conditions.

1. The approval is based on the Power system/ Telecom system conditions' details as reported by the Power supply authority/ Telecom authority at present. Any changes either to Transmission line or the Power system or the paralleling telecommunication lines which are likely to alter the low frequency induction from the estimated at present should be reported to PTCC for its prior approval.
2. The Power and Telecommunication authorities shall be required to adopt such measures as may be recommended by PTCC for counteracting any interference that might arise when the EHT line is in normal operation.
3. Each crossing should satisfy the conditions as laid down in Para 6 -10 of PTCC Code of Practice for crossings.
4. The angle of crossing shall be 90 degrees but in no case less than 60 degrees.
5. The power line shall be equipped with protective switchgear such that the duration of earth current shall be as short as possible but never exceeding 0.5 seconds.
6. The power line shall be energized within a mutually acceptable time limit after obtaining a Certificate from the concerned Telecom and/or Railway authority regarding completion of provision of all protective measures as recommended by PTCC and also under specific clearance from the Telecom and/or Railway authority maintaining the Telecom system.
7. The energization of Extra High Tension power lines would not be held up for want of installation of GD tubes on telecom lines when the induced voltages are in the range of 430 to 650 V.
8. The telecom line shall be commissioned within a mutually acceptable time after completing provision of all protective measures as recommended by PTCC and also after obtaining specific clearance from the Power authority, if certain measures as recommended by PTCC are to be carried out on power system.
9. The later entrant in the field shall bear the entire cost of providing GD tubes and their fitting as recommended by PTCC, including 15% spares and/or any other protective measures as recommended by PTCC.
10. The route approval shall be subject to special conditions as laid down under Annexure XVI.

Annexure XV

1

- (a) Name of the Power Supply authority seeking approval M/s Khaba Renewable Energy Private Limited
- (b) Reference number & date: NHPC/25-26/031 dated 31.12.2025
E-mail dated 24.02.2026
- (c) Name of the Power line 33 kV Underground Cable Line for 362.5MWp/250MW Solar Power Project developing by M/s Khaba Renewable Energy Pvt Ltd, at Village- Khodal, Tehsil-Sheo, District- Barmer, Rajasthan from IDT 8 to 220/33 kV KREPL 250 MW PSS at Khodal Village, Sheo Tehsil, Barmer (Length: 1.95 km)
- (d) Length of Power line: 1.95 km
- (e) Operating Voltage 33 kV
- (f) Number of circuits 1

2

- (a) Names of parallel telecom lines: As per Annexure-XVI
- (b) Length of parallelism: As per Annexure-XVI
- 3 Average value of earth resistivity in the region: 2500 ohm-cms
- 4 Whether LF test necessary: No
- 5 Special conditions subject to which this certificate will be effective As per Annexure-XVI

Annexure XVI

Name of the Power Line: 33 kV Underground Cable Line for 362.5MWp/250MW Solar Power Project developing by M/s Khaba Renewable Energy Pvt Ltd, at Village- Khodal, Tehsil- Sheo, District- Barmer, Rajasthan from IDT 8 to 220/33 kV KREPL 250 MW PSS at Khodal Village, Sheo Tehsil, Barmer (Length: 1.95 km)

1. BSNL Telecom Details:

AGM (CFA), CO Jaipur, BSNL vide letter RJCO-19/16(13)/3/2020-CFA/19012 dated 02.02.2026 has stated non-existence of any BSNL telecom assets within the 5 km periphery of proposed route. Thus, BSNL letter is taken as Deemed NOC.

2. Railway Telecom Details:

Deputy CSTE, Telecom, North Western Railway vide letter SG/158/NWR/PTCC/1320 dated 04.02.2026 has given their NOC for charging of the line.

3. EPR zone for the proposed substation is mentioned below:

Name of the proposed Substation	Half diagonal distance, D/2 (mts)	Fault Current I (KA)	Resistance of Earth Mat, R (ohms)	d (mts) at 430 V	d (mts) at 650 V	d (mts) at 7kV	d (mts) at 10kV
220/33 kV KREPL 250 MW PSS at Khodal Village, Sheo Tehsil, Barmer	93.49	35	0.225	1619	1039	12	N.A
ICR	13.28	15.774	0.1	35	19	N.A	N.A

Telecom authorities to ensure the protection of telecom equipment and personnel within the EPR zone of the proposed substation at the cost of the later entrant.

CEA Case No.: RAJ-972 - I

Provisional Approval for the Route of Extra High Tension (EHT)/ High Tension (HT) Power Line / Telecommunication Line

Provisional Approval of the Central Level Power & Telecommunication Co-ordination Committee is hereby conveyed having a validity of 60 days from the date of issuance for **33 kV Underground Cable Line for 362.5MWp/250MW Solar Power Project developing by M/s Khaba Renewable Energy Pvt Ltd, at Village- Khodal, Tehsil- Sheo, District- Barmer, Rajasthan From IDT 9 to 220/33 kV KREPL 250 MW PSS at Khodal Village, Sheo Tehsil, Barmer (Length: 2.308 km)** particulars of which are given in Annexure XVII.

The approval is for the route only and is subject to the following conditions.

1. The approval is based on the Power system/ Telecom system conditions' details as reported by the Power supply authority/ Telecom authority at present. Any changes either to Transmission line or the Power system or the paralleling telecommunication lines which are likely to alter the low frequency induction from the estimated at present should be reported to PTCC for its prior approval.
2. The Power and Telecommunication authorities shall be required to adopt such measures as may be recommended by PTCC for counteracting any interference that might arise when the EHT line is in normal operation.
3. Each crossing should satisfy the conditions as laid down in Para 6 -10 of PTCC Code of Practice for crossings.
4. The angle of crossing shall be 90 degrees but in no case less than 60 degrees.
5. The power line shall be equipped with protective switchgear such that the duration of earth current shall be as short as possible but never exceeding 0.5 seconds.
6. The power line shall be energized within a mutually acceptable time limit after obtaining a Certificate from the concerned Telecom and/or Railway authority regarding completion of provision of all protective measures as recommended by PTCC and also under specific clearance from the Telecom and/or Railway authority maintaining the Telecom system.
7. The energization of Extra High Tension power lines would not be held up for want of installation of GD tubes on telecom lines when the induced voltages are in the range of 430 to 650 V.
8. The telecom line shall be commissioned within a mutually acceptable time after completing provision of all protective measures as recommended by PTCC and also after obtaining specific clearance from the Power authority, if certain measures as recommended by PTCC are to be carried out on power system.
9. The later entrant in the field shall bear the entire cost of providing GD tubes and their fitting as recommended by PTCC, including 15% spares and/or any other protective measures as recommended by PTCC.
10. The route approval shall be subject to special conditions as laid down under Annexure XVIII.

Annexure XVII

1

- (a) Name of the Power Supply authority seeking approval M/s Khaba Renewable Energy Private Limited
- (b) Reference number & date: NHPC/25-26/031 dated 31.12.2025
E-mail dated 24.02.2026
- (c) Name of the Power line 33 kV Underground Cable Line for 362.5MWp/250MW Solar Power Project developing by M/s Khaba Renewable Energy Pvt Ltd, at Village- Khodal, Tehsil-Sheo, District- Barmer, Rajasthan From IDT 9 to 220/33 kV KREPL 250 MW PSS at Khodal Village, Sheo Tehsil, Barmer (Length: 2.308 km)
- (d) Length of Power line: 2.308 km
- (e) Operating Voltage 33 kV
- (f) Number of circuits 1

2

- (a) Names of parallel telecom lines: As per Annexure-XVIII
- (b) Length of parallelism: As per Annexure-XVIII
- 3 Average value of earth resistivity in the region: 2500 ohm-cms
- 4 Whether LF test necessary: No
- 5 Special conditions subject to which this certificate will be effective As per Annexure-XVIII

Annexure XVIII

Name of the Power Line: 33 kV Underground Cable Line for 362.5MWp/250MW Solar Power Project developing by M/s Khaba Renewable Energy Pvt Ltd, at Village- Khodal, Tehsil- Sheo, District- Barmer, Rajasthan From IDT 9 to 220/33 kV KREPL 250 MW PSS at Khodal Village, Sheo Tehsil, Barmer (Length: 2.308 km)

1. BSNL Telecom Details:

AGM (CFA), CO Jaipur, BSNL vide letter RJCO-19/16(13)/3/2020-CFA/19012 dated 02.02.2026 has stated non-existence of any BSNL telecom assets within the 5 km periphery of proposed route. Thus, BSNL letter is taken as Deemed NOC.

2. Railway Telecom Details:

Deputy CSTE, Telecom, North Western Railway vide letter SG/158/NWR/PTCC/1320 dated 04.02.2026 has given their NOC for charging of the line.

3. EPR zone for the proposed substation is mentioned below:

Name of the proposed Substation	Half diagonal distance, D/2 (mts)	Fault Current I (KA)	Resistance of Earth Mat, R (ohms)	d (mts) at 430 V	d (mts) at 650 V	d (mts) at 7kV	d (mts) at 10kV
220/33 kV KREPL 250 MW PSS at Khodal Village, Sheo Tehsil, Barmer	93.49	35	0.225	1619	1039	12	N.A
ICR	13.28	15.774	0.1	35	19	N.A	N.A

Telecom authorities to ensure the protection of telecom equipment and personnel within the EPR zone of the proposed substation at the cost of the later entrant.

CEA Case No.: RAJ-972 - J

Provisional Approval for the Route of Extra High Tension (EHT)/ High Tension (HT) Power Line / Telecommunication Line

Provisional Approval of the Central Level Power & Telecommunication Co-ordination Committee is hereby conveyed having a validity of 60 days from the date of issuance for **33 kV Underground Cable Line for 362.5MWp/250MW Solar Power Project developing by M/s Khaba Renewable Energy Pvt Ltd, at Village- Khodal, Tehsil- Sheo, District- Barmer, Rajasthan From IDT 10 to 220/33 kV KREPL 250 MW PSS at Khodal Village, Sheo Tehsil, Barmer (Length: 2.865 km)** particulars of which are given in Annexure XIX.

The approval is for the route only and is subject to the following conditions.

1. The approval is based on the Power system/ Telecom system conditions' details as reported by the Power supply authority/ Telecom authority at present. Any changes either to Transmission line or the Power system or the paralleling telecommunication lines which are likely to alter the low frequency induction from the estimated at present should be reported to PTCC for its prior approval.
2. The Power and Telecommunication authorities shall be required to adopt such measures as may be recommended by PTCC for counteracting any interference that might arise when the EHT line is in normal operation.
3. Each crossing should satisfy the conditions as laid down in Para 6 -10 of PTCC Code of Practice for crossings.
4. The angle of crossing shall be 90 degrees but in no case less than 60 degrees.
5. The power line shall be equipped with protective switchgear such that the duration of earth current shall be as short as possible but never exceeding 0.5 seconds.
6. The power line shall be energized within a mutually acceptable time limit after obtaining a Certificate from the concerned Telecom and/or Railway authority regarding completion of provision of all protective measures as recommended by PTCC and also under specific clearance from the Telecom and/or Railway authority maintaining the Telecom system.
7. The energization of Extra High Tension power lines would not be held up for want of installation of GD tubes on telecom lines when the induced voltages are in the range of 430 to 650 V.
8. The telecom line shall be commissioned within a mutually acceptable time after completing provision of all protective measures as recommended by PTCC and also after obtaining specific clearance from the Power authority, if certain measures as recommended by PTCC are to be carried out on power system.
9. The later entrant in the field shall bear the entire cost of providing GD tubes and their fitting as recommended by PTCC, including 15% spares and/or any other protective measures as recommended by PTCC.
10. The route approval shall be subject to special conditions as laid down under Annexure XX.

Annexure XIX

1

- (a) Name of the Power Supply authority seeking approval M/s Khaba Renewable Energy Private Limited
- (b) Reference number & date: NHPC/25-26/031 dated 31.12.2025
E-mail dated 24.02.2026
- (c) Name of the Power line 33 kV Underground Cable Line for 362.5MWp/250MW Solar Power Project developing by M/s Khaba Renewable Energy Pvt Ltd, at Village- Khodal, Tehsil-Sheo, District- Barmer, Rajasthan From IDT 10 to 220/33 kV KREPL 250 MW PSS at Khodal Village, Sheo Tehsil, Barmer (Length: 2.865 km)
- (d) Length of Power line: 2.865 km
- (e) Operating Voltage 33 kV
- (f) Number of circuits 1

2

- (a) Names of parallel telecom lines: As per Annexure-XX
- (b) Length of parallelism: As per Annexure-XX
- 3 Average value of earth resistivity in the region: 2500 ohm-cms
- 4 Whether LF test necessary: No
- 5 Special conditions subject to which this certificate will be effective As per Annexure-XX

Annexure XX

Name of the Power Line: 33 kV Underground Cable Line for 362.5MWp/250MW Solar Power Project developing by M/s Khaba Renewable Energy Pvt Ltd, at Village- Khodal, Tehsil- Sheo, District- Barmer, Rajasthan From IDT 10 to 220/33 kV KREPL 250 MW PSS at Khodal Village, Sheo Tehsil, Barmer (Length: 2.865 km)

1. BSNL Telecom Details:

AGM (CFA), CO Jaipur, BSNL vide letter RJCO-19/16(13)/3/2020-CFA/19012 dated 02.02.2026 has stated non-existence of any BSNL telecom assets within the 5 km periphery of proposed route. Thus, BSNL letter is taken as Deemed NOC.

2. Railway Telecom Details:

Deputy CSTE, Telecom, North Western Railway vide letter SG/158/NWR/PTCC/1320 dated 04.02.2026 has given their NOC for charging of the line.

3. EPR zone for the proposed substation is mentioned below:

Name of the proposed Substation	Half diagonal distance, D/2 (mts)	Fault Current I (KA)	Resistance of Earth Mat, R (ohms)	d (mts) at 430 V	d (mts) at 650 V	d (mts) at 7kV	d (mts) at 10kV
220/33 kV KREPL 250 MW PSS at Khodal Village, Sheo Tehsil, Barmer	93.49	35	0.225	1619	1039	12	N.A
ICR	13.28	15.774	0.1	35	19	N.A	N.A

Telecom authorities to ensure the protection of telecom equipment and personnel within the EPR zone of the proposed substation at the cost of the later entrant.

CEA Case No.: RAJ-972 - K

Provisional Approval for the Route of Extra High Tension (EHT)/ High Tension (HT) Power Line / Telecommunication Line

Provisional Approval of the Central Level Power & Telecommunication Co-ordination Committee is hereby conveyed having a validity of 60 days from the date of issuance for **33 kV Underground Cable Line for 362.5MWp/250MW Solar Power Project developing by M/s Khaba Renewable Energy Pvt Ltd, at Village- Khodal, Tehsil- Sheo, District- Barmer, Rajasthan From IDT 12 to 220/33 kV KREPL 250 MW PSS at Khodal Village, Sheo Tehsil, Barmer (Length: 2.327 km)** particulars of which are given in Annexure XXI.

The approval is for the route only and is subject to the following conditions.

1. The approval is based on the Power system/ Telecom system conditions' details as reported by the Power supply authority/ Telecom authority at present. Any changes either to Transmission line or the Power system or the paralleling telecommunication lines which are likely to alter the low frequency induction from the estimated at present should be reported to PTCC for its prior approval.
2. The Power and Telecommunication authorities shall be required to adopt such measures as may be recommended by PTCC for counteracting any interference that might arise when the EHT line is in normal operation.
3. Each crossing should satisfy the conditions as laid down in Para 6 -10 of PTCC Code of Practice for crossings.
4. The angle of crossing shall be 90 degrees but in no case less than 60 degrees.
5. The power line shall be equipped with protective switchgear such that the duration of earth current shall be as short as possible but never exceeding 0.5 seconds.
6. The power line shall be energized within a mutually acceptable time limit after obtaining a Certificate from the concerned Telecom and/or Railway authority regarding completion of provision of all protective measures as recommended by PTCC and also under specific clearance from the Telecom and/or Railway authority maintaining the Telecom system.
7. The energization of Extra High Tension power lines would not be held up for want of installation of GD tubes on telecom lines when the induced voltages are in the range of 430 to 650 V.
8. The telecom line shall be commissioned within a mutually acceptable time after completing provision of all protective measures as recommended by PTCC and also after obtaining specific clearance from the Power authority, if certain measures as recommended by PTCC are to be carried out on power system.
9. The later entrant in the field shall bear the entire cost of providing GD tubes and their fitting as recommended by PTCC, including 15% spares and/or any other protective measures as recommended by PTCC.
10. The route approval shall be subject to special conditions as laid down under Annexure XXII.

Annexure XXI

1

- (a) Name of the Power Supply authority seeking approval M/s Khaba Renewable Energy Private Limited
- (b) Reference number & date: NHPC/25-26/031 dated 31.12.2025
E-mail dated 24.02.2026
- (c) Name of the Power line 33 kV Underground Cable Line for 362.5MWp/250MW Solar Power Project developing by M/s Khaba Renewable Energy Pvt Ltd, at Village- Khodal, Tehsil-Sheo, District- Barmer, Rajasthan From IDT 12 to 220/33 kV KREPL 250 MW PSS at Khodal Village, Sheo Tehsil, Barmer (Length: 2.327 km)
- (d) Length of Power line: 2.327 km
- (e) Operating Voltage 33 kV
- (f) Number of circuits 1

2

- (a) Names of parallel telecom lines: As per Annexure-XXII
- (b) Length of parallelism: As per Annexure-XXII
- 3 Average value of earth resistivity in the region: 2500 ohm-cms
- 4 Whether LF test necessary: No
- 5 Special conditions subject to which this certificate will be effective As per Annexure-XXII

Annexure XXII

Name of the Power Line: 33 kV Underground Cable Line for 362.5MWp/250MW Solar Power Project developing by M/s Khaba Renewable Energy Pvt Ltd, at Village- Khodal, Tehsil- Sheo, District- Barmer, Rajasthan From IDT 12 to 220/33 kV KREPL 250 MW PSS at Khodal Village, Sheo Tehsil, Barmer (Length: 2.327 km)

1. BSNL Telecom Details:

AGM (CFA), CO Jaipur, BSNL vide letter RJCO-19/16(13)/3/2020-CFA/19012 dated 02.02.2026 has stated non-existence of any BSNL telecom assets within the 5 km periphery of proposed route. Thus, BSNL letter is taken as Deemed NOC.

2. Railway Telecom Details:

Deputy CSTE, Telecom, North Western Railway vide letter SG/158/NWR/PTCC/1320 dated 04.02.2026 has given their NOC for charging of the line.

3. EPR zone for the proposed substation is mentioned below:

Name of the proposed Substation	Half diagonal distance, D/2 (mts)	Fault Current I (KA)	Resistance of Earth Mat, R (ohms)	d (mts) at 430 V	d (mts) at 650 V	d (mts) at 7kV	d (mts) at 10kV
220/33 kV KREPL 250 MW PSS at Khodal Village, Sheo Tehsil, Barmer	93.49	35	0.225	1619	1039	12	N.A
ICR	13.28	15.774	0.1	35	19	N.A	N.A

Telecom authorities to ensure the protection of telecom equipment and personnel within the EPR zone of the proposed substation at the cost of the later entrant.

CEA Case No.: RAJ-972 - L

Provisional Approval for the Route of Extra High Tension (EHT)/ High Tension (HT) Power Line / Telecommunication Line

Provisional Approval of the Central Level Power & Telecommunication Co-ordination Committee is hereby conveyed having a validity of 60 days from the date of issuance for **33 kV Underground Cable Line for 362.5MWp/250MW Solar Power Project developing by M/s Khaba Renewable Energy Pvt Ltd, at Village- Khodal, Tehsil- Sheo, District- Barmer, Rajasthan From IDT 13 to 220/33 kV KREPL 250 MW PSS at Khodal Village, Sheo Tehsil, Barmer (Length: 2.243 km)** particulars of which are given in Annexure XXIII.

The approval is for the route only and is subject to the following conditions.

1. The approval is based on the Power system/ Telecom system conditions' details as reported by the Power supply authority/ Telecom authority at present. Any changes either to Transmission line or the Power system or the paralleling telecommunication lines which are likely to alter the low frequency induction from the estimated at present should be reported to PTCC for its prior approval.
2. The Power and Telecommunication authorities shall be required to adopt such measures as may be recommended by PTCC for counteracting any interference that might arise when the EHT line is in normal operation.
3. Each crossing should satisfy the conditions as laid down in Para 6 -10 of PTCC Code of Practice for crossings.
4. The angle of crossing shall be 90 degrees but in no case less than 60 degrees.
5. The power line shall be equipped with protective switchgear such that the duration of earth current shall be as short as possible but never exceeding 0.5 seconds.
6. The power line shall be energized within a mutually acceptable time limit after obtaining a Certificate from the concerned Telecom and/or Railway authority regarding completion of provision of all protective measures as recommended by PTCC and also under specific clearance from the Telecom and/or Railway authority maintaining the Telecom system.
7. The energization of Extra High Tension power lines would not be held up for want of installation of GD tubes on telecom lines when the induced voltages are in the range of 430 to 650 V.
8. The telecom line shall be commissioned within a mutually acceptable time after completing provision of all protective measures as recommended by PTCC and also after obtaining specific clearance from the Power authority, if certain measures as recommended by PTCC are to be carried out on power system.
9. The later entrant in the field shall bear the entire cost of providing GD tubes and their fitting as recommended by PTCC, including 15% spares and/or any other protective measures as recommended by PTCC.
10. The route approval shall be subject to special conditions as laid down under Annexure XXIV.

Annexure XXIII

1

- (a) Name of the Power Supply authority seeking approval M/s Khaba Renewable Energy Private Limited
- (b) Reference number & date: NHPC/25-26/031 dated 31.12.2025
E-mail dated 24.02.2026
- (c) Name of the Power line 33 kV Underground Cable Line for 362.5MWp/250MW Solar Power Project developing by M/s Khaba Renewable Energy Pvt Ltd, at Village- Khodal, Tehsil-Sheo, District- Barmer, Rajasthan From IDT 13 to 220/33 kV KREPL 250 MW PSS at Khodal Village, Sheo Tehsil, Barmer (Length: 2.243 km)
- (d) Length of Power line: 2.243 km
- (e) Operating Voltage 33 kV
- (f) Number of circuits 1

2

- (a) Names of parallel telecom lines: As per Annexure-XXIV
- (b) Length of parallelism: As per Annexure-XXIV
- 3 Average value of earth resistivity in the region: 2500 ohm-cms
- 4 Whether LF test necessary: No
- 5 Special conditions subject to which this certificate will be effective As per Annexure-XXIV

Annexure XXIV

Name of the Power Line: 33 kV Underground Cable Line for 362.5MWp/250MW Solar Power Project developing by M/s Khaba Renewable Energy Pvt Ltd, at Village- Khodal, Tehsil- Sheo, District- Barmer, Rajasthan From IDT 13 to 220/33 kV KREPL 250 MW PSS at Khodal Village, Sheo Tehsil, Barmer (Length: 2.243 km)

1. BSNL Telecom Details:

AGM (CFA), CO Jaipur, BSNL vide letter RJCO-19/16(13)/3/2020-CFA/19012 dated 02.02.2026 has stated non-existence of any BSNL telecom assets within the 5 km periphery of proposed route. Thus, BSNL letter is taken as Deemed NOC.

2. Railway Telecom Details:

Deputy CSTE, Telecom, North Western Railway vide letter SG/158/NWR/PTCC/1320 dated 04.02.2026 has given their NOC for charging of the line.

3. EPR zone for the proposed substation is mentioned below:

Name of the proposed Substation	Half diagonal distance, D/2 (mts)	Fault Current I (KA)	Resistance of Earth Mat, R (ohms)	d (mts) at 430 V	d (mts) at 650 V	d (mts) at 7kV	d (mts) at 10kV
220/33 kV KREPL 250 MW PSS at Khodal Village, Sheo Tehsil, Barmer	93.49	35	0.225	1619	1039	12	N.A
ICR	13.28	15.774	0.1	35	19	N.A	N.A

Telecom authorities to ensure the protection of telecom equipment and personnel within the EPR zone of the proposed substation at the cost of the later entrant.

CEA Case No.: RAJ-972 - M

Provisional Approval for the Route of Extra High Tension (EHT)/ High Tension (HT) Power Line / Telecommunication Line

Provisional Approval of the Central Level Power & Telecommunication Co-ordination Committee is hereby conveyed having a validity of 60 days from the date of issuance for **33 kV Underground Cable Line for 362.5MWp/250MW Solar Power Project developing by M/s Khaba Renewable Energy Pvt Ltd, at Village- Khodal, Tehsil- Sheo, District- Barmer, Rajasthan From IDT 14 to 220/33 kV KREPL 250 MW PSS at Khodal Village, Sheo Tehsil, Barmer (Length: 1.98 km)** particulars of which are given in Annexure XXV.

The approval is for the route only and is subject to the following conditions.

1. The approval is based on the Power system/ Telecom system conditions' details as reported by the Power supply authority/ Telecom authority at present. Any changes either to Transmission line or the Power system or the paralleling telecommunication lines which are likely to alter the low frequency induction from the estimated at present should be reported to PTCC for its prior approval.
2. The Power and Telecommunication authorities shall be required to adopt such measures as may be recommended by PTCC for counteracting any interference that might arise when the EHT line is in normal operation.
3. Each crossing should satisfy the conditions as laid down in Para 6 -10 of PTCC Code of Practice for crossings.
4. The angle of crossing shall be 90 degrees but in no case less than 60 degrees.
5. The power line shall be equipped with protective switchgear such that the duration of earth current shall be as short as possible but never exceeding 0.5 seconds.
6. The power line shall be energized within a mutually acceptable time limit after obtaining a Certificate from the concerned Telecom and/or Railway authority regarding completion of provision of all protective measures as recommended by PTCC and also under specific clearance from the Telecom and/or Railway authority maintaining the Telecom system.
7. The energization of Extra High Tension power lines would not be held up for want of installation of GD tubes on telecom lines when the induced voltages are in the range of 430 to 650 V.
8. The telecom line shall be commissioned within a mutually acceptable time after completing provision of all protective measures as recommended by PTCC and also after obtaining specific clearance from the Power authority, if certain measures as recommended by PTCC are to be carried out on power system.
9. The later entrant in the field shall bear the entire cost of providing GD tubes and their fitting as recommended by PTCC, including 15% spares and/or any other protective measures as recommended by PTCC.
10. The route approval shall be subject to special conditions as laid down under Annexure XXVI.

Annexure XXV

1

- (a) Name of the Power Supply authority seeking approval M/s Khaba Renewable Energy Private Limited
- (b) Reference number & date: NHPC/25-26/031 dated 31.12.2025
E-mail dated 24.02.2026
- (c) Name of the Power line 33 kV Underground Cable Line for 362.5MWp/250MW Solar Power Project developing by M/s Khaba Renewable Energy Pvt Ltd, at Village- Khodal, Tehsil-Sheo, District- Barmer, Rajasthan From IDT 14 to 220/33 kV KREPL 250 MW PSS at Khodal Village, Sheo Tehsil, Barmer (Length: 1.98 km)
- (d) Length of Power line: 1.98 km
- (e) Operating Voltage 33 kV
- (f) Number of circuits 1

2

- (a) Names of parallel telecom lines: As per Annexure-XXVI
- (b) Length of parallelism: As per Annexure-XXVI
- 3 Average value of earth resistivity in the region: 2500 ohm-cms
- 4 Whether LF test necessary: No
- 5 Special conditions subject to which this certificate will be effective As per Annexure-XXVI

Annexure XXVI

Name of the Power Line: 33 kV Underground Cable Line for 362.5MWp/250MW Solar Power Project developing by M/s Khaba Renewable Energy Pvt Ltd, at Village- Khodal, Tehsil- Sheo, District- Barmer, Rajasthan From IDT 14 to 220/33 kV KREPL 250 MW PSS at Khodal Village, Sheo Tehsil, Barmer (Length: 1.98 km)

1. BSNL Telecom Details:

AGM (CFA), CO Jaipur, BSNL vide letter RJCO-19/16(13)/3/2020-CFA/19012 dated 02.02.2026 has stated non-existence of any BSNL telecom assets within the 5 km periphery of proposed route. Thus, BSNL letter is taken as Deemed NOC.

2. Railway Telecom Details:

Deputy CSTE, Telecom, North Western Railway vide letter SG/158/NWR/PTCC/1320 dated 04.02.2026 has given their NOC for charging of the line.

3. EPR zone for the proposed substation is mentioned below:

Name of the proposed Substation	Half diagonal distance, D/2 (mts)	Fault Current I (KA)	Resistance of Earth Mat, R (ohms)	d (mts) at 430 V	d (mts) at 650 V	d (mts) at 7kV	d (mts) at 10kV
220/33 kV KREPL 250 MW PSS at Khodal Village, Sheo Tehsil, Barmer	93.49	35	0.225	1619	1039	12	N.A
ICR	13.28	15.774	0.1	35	19	N.A	N.A

Telecom authorities to ensure the protection of telecom equipment and personnel within the EPR zone of the proposed substation at the cost of the later entrant.

CEA Case No.: RAJ-972 - N

Provisional Approval for the Route of Extra High Tension (EHT)/ High Tension (HT) Power Line / Telecommunication Line

Provisional Approval of the Central Level Power & Telecommunication Co-ordination Committee is hereby conveyed having a validity of 60 days from the date of issuance for **33 kV Underground Cable Line for 362.5MWp/250MW Solar Power Project developing by M/s Khaba Renewable Energy Pvt Ltd, at Village- Khodal, Tehsil- Sheo, District- Barmer, Rajasthan From IDT 15 to 220/33 kV KREPL 250 MW PSS at Khodal Village, Sheo Tehsil, Barmer (Length: 1.16 km)** particulars of which are given in Annexure XXVII.

The approval is for the route only and is subject to the following conditions.

1. The approval is based on the Power system/ Telecom system conditions' details as reported by the Power supply authority/ Telecom authority at present. Any changes either to Transmission line or the Power system or the paralleling telecommunication lines which are likely to alter the low frequency induction from the estimated at present should be reported to PTCC for its prior approval.
2. The Power and Telecommunication authorities shall be required to adopt such measures as may be recommended by PTCC for counteracting any interference that might arise when the EHT line is in normal operation.
3. Each crossing should satisfy the conditions as laid down in Para 6 -10 of PTCC Code of Practice for crossings.
4. The angle of crossing shall be 90 degrees but in no case less than 60 degrees.
5. The power line shall be equipped with protective switchgear such that the duration of earth current shall be as short as possible but never exceeding 0.5 seconds.
6. The power line shall be energized within a mutually acceptable time limit after obtaining a Certificate from the concerned Telecom and/or Railway authority regarding completion of provision of all protective measures as recommended by PTCC and also under specific clearance from the Telecom and/or Railway authority maintaining the Telecom system.
7. The energization of Extra High Tension power lines would not be held up for want of installation of GD tubes on telecom lines when the induced voltages are in the range of 430 to 650 V.
8. The telecom line shall be commissioned within a mutually acceptable time after completing provision of all protective measures as recommended by PTCC and also after obtaining specific clearance from the Power authority, if certain measures as recommended by PTCC are to be carried out on power system.
9. The later entrant in the field shall bear the entire cost of providing GD tubes and their fitting as recommended by PTCC, including 15% spares and/or any other protective measures as recommended by PTCC.
10. The route approval shall be subject to special conditions as laid down under Annexure XXVIII.

Annexure XXVII

1

- (a) Name of the Power Supply authority seeking approval M/s Khaba Renewable Energy Private Limited
- (b) Reference number & date: NHPC/25-26/031 dated 31.12.2025
E-mail dated 24.02.2026
- (c) Name of the Power line 33 kV Underground Cable Line for 362.5MWp/250MW Solar Power Project developing by M/s Khaba Renewable Energy Pvt Ltd, at Village- Khodal, Tehsil-Sheo, District- Barmer, Rajasthan From IDT 15 to 220/33 kV KREPL 250 MW PSS at Khodal Village, Sheo Tehsil, Barmer (Length: 1.16 km)
- (d) Length of Power line: 1.16 km
- (e) Operating Voltage 33 kV
- (f) Number of circuits 1

2

- (a) Names of parallel telecom lines: As per Annexure-XXVIII
- (b) Length of parallelism: As per Annexure-XXVIII
- 3 Average value of earth resistivity in the region: 2500 ohm-cms
- 4 Whether LF test necessary: No
- 5 Special conditions subject to which this certificate will be effective As per Annexure-XXVIII

Annexure XXVIII

Name of the Power Line: 33 kV Underground Cable Line for 362.5MWp/250MW Solar Power Project developing by M/s Khaba Renewable Energy Pvt Ltd, at Village- Khodal, Tehsil- Sheo, District- Barmer, Rajasthan From IDT 15 to 220/33 kV KREPL 250 MW PSS at Khodal Village, Sheo Tehsil, Barmer (Length: 1.16 km)

1. BSNL Telecom Details:

AGM (CFA), CO Jaipur, BSNL vide letter RJCO-19/16(13)/3/2020-CFA/19012 dated 02.02.2026 has stated non-existence of any BSNL telecom assets within the 5 km periphery of proposed route. Thus, BSNL letter is taken as Deemed NOC.

2. Railway Telecom Details:

Deputy CSTE, Telecom, North Western Railway vide letter SG/158/NWR/PTCC/1320 dated 04.02.2026 has given their NOC for charging of the line.

3. EPR zone for the proposed substation is mentioned below:

Name of the proposed Substation	Half diagonal distance, D/2 (mts)	Fault Current I (KA)	Resistance of Earth Mat, R (ohms)	d (mts) at 430 V	d (mts) at 650 V	d (mts) at 7kV	d (mts) at 10kV
220/33 kV KREPL 250 MW PSS at Khodal Village, Sheo Tehsil, Barmer	93.49	35	0.225	1619	1039	12	N.A
ICR	13.28	15.774	0.1	35	19	N.A	N.A

Telecom authorities to ensure the protection of telecom equipment and personnel within the EPR zone of the proposed substation at the cost of the later entrant.

CEA Case No.: RAJ-972 - O

Provisional Approval for the Route of Extra High Tension (EHT)/ High Tension (HT) Power Line / Telecommunication Line

Provisional Approval of the Central Level Power & Telecommunication Co-ordination Committee is hereby conveyed having a validity of 60 days from the date of issuance for **33 kV Underground Cable Line for 362.5MWp/250MW Solar Power Project developing by M/s Khaba Renewable Energy Pvt Ltd, at Village- Khodal, Tehsil- Sheo, District- Barmer, Rajasthan From IDT 16 to 220/33 kV KREPL 250 MW PSS at Khodal Village, Sheo Tehsil, Barmer (Length: 2.178 km)** particulars of which are given in Annexure XXIX.

The approval is for the route only and is subject to the following conditions.

1. The approval is based on the Power system/ Telecom system conditions' details as reported by the Power supply authority/ Telecom authority at present. Any changes either to Transmission line or the Power system or the paralleling telecommunication lines which are likely to alter the low frequency induction from the estimated at present should be reported to PTCC for its prior approval.
2. The Power and Telecommunication authorities shall be required to adopt such measures as may be recommended by PTCC for counteracting any interference that might arise when the EHT line is in normal operation.
3. Each crossing should satisfy the conditions as laid down in Para 6 -10 of PTCC Code of Practice for crossings.
4. The angle of crossing shall be 90 degrees but in no case less than 60 degrees.
5. The power line shall be equipped with protective switchgear such that the duration of earth current shall be as short as possible but never exceeding 0.5 seconds.
6. The power line shall be energized within a mutually acceptable time limit after obtaining a Certificate from the concerned Telecom and/or Railway authority regarding completion of provision of all protective measures as recommended by PTCC and also under specific clearance from the Telecom and/or Railway authority maintaining the Telecom system.
7. The energization of Extra High Tension power lines would not be held up for want of installation of GD tubes on telecom lines when the induced voltages are in the range of 430 to 650 V.
8. The telecom line shall be commissioned within a mutually acceptable time after completing provision of all protective measures as recommended by PTCC and also after obtaining specific clearance from the Power authority, if certain measures as recommended by PTCC are to be carried out on power system.
9. The later entrant in the field shall bear the entire cost of providing GD tubes and their fitting as recommended by PTCC, including 15% spares and/or any other protective measures as recommended by PTCC.
10. The route approval shall be subject to special conditions as laid down under Annexure XXX.

Annexure XXIX

1

- (a) Name of the Power Supply authority seeking approval M/s Khaba Renewable Energy Private Limited
- (b) Reference number & date: NHPC/25-26/031 dated 31.12.2025
E-mail dated 24.02.2026
- (c) Name of the Power line 33 kV Underground Cable Line for 362.5MWp/250MW Solar Power Project developing by M/s Khaba Renewable Energy Pvt Ltd, at Village- Khodal, Tehsil-Sheo, District- Barmer, Rajasthan From IDT 16 to 220/33 kV KREPL 250 MW PSS at Khodal Village, Sheo Tehsil, Barmer (Length: 2.178 km)
- (d) Length of Power line: 2.178 km
- (e) Operating Voltage 33 kV
- (f) Number of circuits 1

2

- (a) Names of parallel telecom lines: As per Annexure-XXX
- (b) Length of parallelism: As per Annexure-XXX
- 3 Average value of earth resistivity in the region: 2500 ohm-cms
- 4 Whether LF test necessary: No
- 5 Special conditions subject to which this certificate will be effective As per Annexure-XXX

Annexure XXX

Name of the Power Line: 33 kV Underground Cable Line for 362.5MWp/250MW Solar Power Project developing by M/s Khaba Renewable Energy Pvt Ltd, at Village- Khodal, Tehsil- Sheo, District- Barmer, Rajasthan From IDT 16 to 220/33 kV KREPL 250 MW PSS at Khodal Village, Sheo Tehsil, Barmer (Length: 2.178 km)

1. BSNL Telecom Details:

AGM (CFA), CO Jaipur, BSNL vide letter RJCO-19/16(13)/3/2020-CFA/19012 dated 02.02.2026 has stated non-existence of any BSNL telecom assets within the 5 km periphery of proposed route. Thus, BSNL letter is taken as Deemed NOC.

2. Railway Telecom Details:

Deputy CSTE, Telecom, North Western Railway vide letter SG/158/NWR/PTCC/1320 dated 04.02.2026 has given their NOC for charging of the line.

3. EPR zone for the proposed substation is mentioned below:

Name of the proposed Substation	Half diagonal distance, D/2 (mts)	Fault Current I (KA)	Resistance of Earth Mat, R (ohms)	d (mts) at 430 V	d (mts) at 650 V	d (mts) at 7kV	d (mts) at 10kV
220/33 kV KREPL 250 MW PSS at Khodal Village, Sheo Tehsil, Barmer	93.49	35	0.225	1619	1039	12	N.A
ICR	13.28	15.774	0.1	35	19	N.A	N.A

Telecom authorities to ensure the protection of telecom equipment and personnel within the EPR zone of the proposed substation at the cost of the later entrant.

CEA Case No.: RAJ-972 - P

Provisional Approval for the Route of Extra High Tension (EHT)/ High Tension (HT) Power Line / Telecommunication Line

Provisional Approval of the Central Level Power & Telecommunication Co-ordination Committee is hereby conveyed having a validity of 60 days from the date of issuance for **33 kV Underground Cable Line for 362.5MWp/250MW Solar Power Project developing by M/s Khaba Renewable Energy Pvt Ltd, at Village- Khodal, Tehsil- Sheo, District- Barmer, Rajasthan From IDT 17 to 220/33 kV KREPL 250 MW PSS at Khodal Village, Sheo Tehsil, Barmer (Length: 3.424 km)** particulars of which are given in Annexure XXXI.

The approval is for the route only and is subject to the following conditions.

1. The approval is based on the Power system/ Telecom system conditions' details as reported by the Power supply authority/ Telecom authority at present. Any changes either to Transmission line or the Power system or the paralleling telecommunication lines which are likely to alter the low frequency induction from the estimated at present should be reported to PTCC for its prior approval.
2. The Power and Telecommunication authorities shall be required to adopt such measures as may be recommended by PTCC for counteracting any interference that might arise when the EHT line is in normal operation.
3. Each crossing should satisfy the conditions as laid down in Para 6 -10 of PTCC Code of Practice for crossings.
4. The angle of crossing shall be 90 degrees but in no case less than 60 degrees.
5. The power line shall be equipped with protective switchgear such that the duration of earth current shall be as short as possible but never exceeding 0.5 seconds.
6. The power line shall be energized within a mutually acceptable time limit after obtaining a Certificate from the concerned Telecom and/or Railway authority regarding completion of provision of all protective measures as recommended by PTCC and also under specific clearance from the Telecom and/or Railway authority maintaining the Telecom system.
7. The energization of Extra High Tension power lines would not be held up for want of installation of GD tubes on telecom lines when the induced voltages are in the range of 430 to 650 V.
8. The telecom line shall be commissioned within a mutually acceptable time after completing provision of all protective measures as recommended by PTCC and also after obtaining specific clearance from the Power authority, if certain measures as recommended by PTCC are to be carried out on power system.
9. The later entrant in the field shall bear the entire cost of providing GD tubes and their fitting as recommended by PTCC, including 15% spares and/or any other protective measures as recommended by PTCC.
10. The route approval shall be subject to special conditions as laid down under Annexure XXXII.

Annexure XXXI

1

- (a) Name of the Power Supply authority seeking approval M/s Khaba Renewable Energy Private Limited
- (b) Reference number & date: NHPC/25-26/031 dated 31.12.2025
E-mail dated 24.02.2026
- (c) Name of the Power line 33 kV Underground Cable Line for 362.5MWp/250MW Solar Power Project developing by M/s Khaba Renewable Energy Pvt Ltd, at Village- Khodal, Tehsil-Sheo, District- Barmer, Rajasthan From IDT 17 to 220/33 kV KREPL 250 MW PSS at Khodal Village, Sheo Tehsil, Barmer (Length: 3.424 km)
- (d) Length of Power line: 3.424 km
- (e) Operating Voltage 33 kV
- (f) Number of circuits 1

2

- (a) Names of parallel telecom lines: As per Annexure-XXXII
- (b) Length of parallelism: As per Annexure-XXXII
- 3 Average value of earth resistivity in the region: 2500 ohm-cms
- 4 Whether LF test necessary: No
- 5 Special conditions subject to which this certificate will be effective As per Annexure-XXXII

Annexure XXXII

Name of the Power Line: 33 kV Underground Cable Line for 362.5MWp/250MW Solar Power Project developing by M/s Khaba Renewable Energy Pvt Ltd, at Village- Khodal, Tehsil- Sheo, District- Barmer, Rajasthan From IDT 17 to 220/33 kV KREPL 250 MW PSS at Khodal Village, Sheo Tehsil, Barmer (Length: 3.424 km)

1. BSNL Telecom Details:

AGM (CFA), CO Jaipur, BSNL vide letter RJCO-19/16(13)/3/2020-CFA/19012 dated 02.02.2026 has stated non-existence of any BSNL telecom assets within the 5 km periphery of proposed route. Thus, BSNL letter is taken as Deemed NOC.

2. Railway Telecom Details:

Deputy CSTE, Telecom, North Western Railway vide letter SG/158/NWR/PTCC/1320 dated 04.02.2026 has given their NOC for charging of the line.

3. EPR zone for the proposed substation is mentioned below:

Name of the proposed Substation	Half diagonal distance, D/2 (mts)	Fault Current I (KA)	Resistance of Earth Mat, R (ohms)	d (mts) at 430 V	d (mts) at 650 V	d (mts) at 7kV	d (mts) at 10kV
220/33 kV KREPL 250 MW PSS at Khodal Village, Sheo Tehsil, Barmer	93.49	35	0.225	1619	1039	12	N.A
ICR	13.28	15.774	0.1	35	19	N.A	N.A

Telecom authorities to ensure the protection of telecom equipment and personnel within the EPR zone of the proposed substation at the cost of the later entrant.

CEA Case No.: RAJ-972 - Q

Provisional Approval for the Route of Extra High Tension (EHT)/ High Tension (HT) Power Line / Telecommunication Line

Provisional Approval of the Central Level Power & Telecommunication Co-ordination Committee is hereby conveyed having a validity of 60 days from the date of issuance for **33 kV Underground Cable Line for 362.5MWp/250MW Solar Power Project developing by M/s Khaba Renewable Energy Pvt Ltd, at Village- Khodal, Tehsil- Sheo, District- Barmer, Rajasthan From IDT 18 to 220/33 kV KREPL 250 MW PSS at Khodal Village, Sheo Tehsil, Barmer (Length: 3.992 km)** particulars of which are given in Annexure XXXIII.

The approval is for the route only and is subject to the following conditions.

1. The approval is based on the Power system/ Telecom system conditions' details as reported by the Power supply authority/ Telecom authority at present. Any changes either to Transmission line or the Power system or the paralleling telecommunication lines which are likely to alter the low frequency induction from the estimated at present should be reported to PTCC for its prior approval.
2. The Power and Telecommunication authorities shall be required to adopt such measures as may be recommended by PTCC for counteracting any interference that might arise when the EHT line is in normal operation.
3. Each crossing should satisfy the conditions as laid down in Para 6 -10 of PTCC Code of Practice for crossings.
4. The angle of crossing shall be 90 degrees but in no case less than 60 degrees.
5. The power line shall be equipped with protective switchgear such that the duration of earth current shall be as short as possible but never exceeding 0.5 seconds.
6. The power line shall be energized within a mutually acceptable time limit after obtaining a Certificate from the concerned Telecom and/or Railway authority regarding completion of provision of all protective measures as recommended by PTCC and also under specific clearance from the Telecom and/or Railway authority maintaining the Telecom system.
7. The energization of Extra High Tension power lines would not be held up for want of installation of GD tubes on telecom lines when the induced voltages are in the range of 430 to 650 V.
8. The telecom line shall be commissioned within a mutually acceptable time after completing provision of all protective measures as recommended by PTCC and also after obtaining specific clearance from the Power authority, if certain measures as recommended by PTCC are to be carried out on power system.
9. The later entrant in the field shall bear the entire cost of providing GD tubes and their fitting as recommended by PTCC, including 15% spares and/or any other protective measures as recommended by PTCC.
10. The route approval shall be subject to special conditions as laid down under Annexure XXXIV.

Annexure XXXIII

1

- (a) Name of the Power Supply authority seeking approval M/s Khaba Renewable Energy Private Limited
- (b) Reference number & date: NHPC/25-26/031 dated 31.12.2025
E-mail dated 24.02.2026
- (c) Name of the Power line 33 kV Underground Cable Line for 362.5MWp/250MW Solar Power Project developing by M/s Khaba Renewable Energy Pvt Ltd, at Village- Khodal, Tehsil-Sheo, District- Barmer, Rajasthan From IDT 18 to 220/33 kV KREPL 250 MW PSS at Khodal Village, Sheo Tehsil, Barmer (Length: 3.992 km)
- (d) Length of Power line: 3.992 km
- (e) Operating Voltage 33 kV
- (f) Number of circuits 1

2

- (a) Names of parallel telecom lines: As per Annexure-XXXIV
- (b) Length of parallelism: As per Annexure-XXXIV
- 3 Average value of earth resistivity in the region: 2500 ohm-cms
- 4 Whether LF test necessary: No
- 5 Special conditions subject to which this certificate will be effective As per Annexure-XXXIV

Annexure XXXIV

Name of the Power Line: 33 kV Underground Cable Line for 362.5MWp/250MW Solar Power Project developing by M/s Khaba Renewable Energy Pvt Ltd, at Village- Khodal, Tehsil- Sheo, District- Barmer, Rajasthan From IDT 18 to 220/33 kV KREPL 250 MW PSS at Khodal Village, Sheo Tehsil, Barmer (Length: 3.992 km)

1. BSNL Telecom Details:

AGM (CFA), CO Jaipur, BSNL vide letter RJCO-19/16(13)/3/2020-CFA/19012 dated 02.02.2026 has stated non-existence of any BSNL telecom assets within the 5 km periphery of proposed route. Thus, BSNL letter is taken as Deemed NOC.

2. Railway Telecom Details:

Deputy CSTE, Telecom, North Western Railway vide letter SG/158/NWR/PTCC/1320 dated 04.02.2026 has given their NOC for charging of the line.

3. EPR zone for the proposed substation is mentioned below:

Name of the proposed Substation	Half diagonal distance, D/2 (mts)	Fault Current I (KA)	Resistance of Earth Mat, R (ohms)	d (mts) at 430 V	d (mts) at 650 V	d (mts) at 7kV	d (mts) at 10kV
220/33 kV KREPL 250 MW PSS at Khodal Village, Sheo Tehsil, Barmer	93.49	35	0.225	1619	1039	12	N.A
ICR	13.28	15.774	0.1	35	19	N.A	N.A

Telecom authorities to ensure the protection of telecom equipment and personnel within the EPR zone of the proposed substation at the cost of the later entrant.

CEA Case No.: RAJ-972 - R

Provisional Approval for the Route of Extra High Tension (EHT)/ High Tension (HT) Power Line / Telecommunication Line

Provisional Approval of the Central Level Power & Telecommunication Co-ordination Committee is hereby conveyed having a validity of 60 days from the date of issuance for **33 kV Underground Cable Line for 362.5MWp/250MW Solar Power Project developing by M/s Khaba Renewable Energy Pvt Ltd, at Village- Khodal, Tehsil- Sheo, District- Barmer, Rajasthan From IDT 22 to 220/33 kV KREPL 250 MW PSS at Khodal Village, Sheo Tehsil, Barmer (Length: 2.86 km)** particulars of which are given in Annexure XXXV.

The approval is for the route only and is subject to the following conditions.

1. The approval is based on the Power system/ Telecom system conditions' details as reported by the Power supply authority/ Telecom authority at present. Any changes either to Transmission line or the Power system or the paralleling telecommunication lines which are likely to alter the low frequency induction from the estimated at present should be reported to PTCC for its prior approval.
2. The Power and Telecommunication authorities shall be required to adopt such measures as may be recommended by PTCC for counteracting any interference that might arise when the EHT line is in normal operation.
3. Each crossing should satisfy the conditions as laid down in Para 6 -10 of PTCC Code of Practice for crossings.
4. The angle of crossing shall be 90 degrees but in no case less than 60 degrees.
5. The power line shall be equipped with protective switchgear such that the duration of earth current shall be as short as possible but never exceeding 0.5 seconds.
6. The power line shall be energized within a mutually acceptable time limit after obtaining a Certificate from the concerned Telecom and/or Railway authority regarding completion of provision of all protective measures as recommended by PTCC and also under specific clearance from the Telecom and/or Railway authority maintaining the Telecom system.
7. The energization of Extra High Tension power lines would not be held up for want of installation of GD tubes on telecom lines when the induced voltages are in the range of 430 to 650 V.
8. The telecom line shall be commissioned within a mutually acceptable time after completing provision of all protective measures as recommended by PTCC and also after obtaining specific clearance from the Power authority, if certain measures as recommended by PTCC are to be carried out on power system.
9. The later entrant in the field shall bear the entire cost of providing GD tubes and their fitting as recommended by PTCC, including 15% spares and/or any other protective measures as recommended by PTCC.
10. The route approval shall be subject to special conditions as laid down under Annexure XXXVI.

Annexure XXXV

1

- (a) Name of the Power Supply authority seeking approval M/s Khaba Renewable Energy Private Limited
- (b) Reference number & date: NHPC/25-26/031 dated 31.12.2025
E-mail dated 24.02.2026
- (c) Name of the Power line 33 kV Underground Cable Line for 362.5MWp/250MW Solar Power Project developing by M/s Khaba Renewable Energy Pvt Ltd, at Village- Khodal, Tehsil-Sheo, District- Barmer, Rajasthan From IDT 22 to 220/33 kV KREPL 250 MW PSS at Khodal Village, Sheo Tehsil, Barmer (Length: 2.86 km)
- (d) Length of Power line: 2.86 km
- (e) Operating Voltage 33 kV
- (f) Number of circuits 1

2

- (a) Names of parallel telecom lines: As per Annexure-XXXVI
- (b) Length of parallelism: As per Annexure-XXXVI
- 3 Average value of earth resistivity in the region: 2500 ohm-cms
- 4 Whether LF test necessary: No
- 5 Special conditions subject to which this certificate will be effective As per Annexure-XXXVI

Annexure XXXVI

Name of the Power Line: 33 kV Underground Cable Line for 362.5MWp/250MW Solar Power Project developing by M/s Khaba Renewable Energy Pvt Ltd, at Village- Khodal, Tehsil- Sheo, District- Barmer, Rajasthan From IDT 22 to 220/33 kV KREPL 250 MW PSS at Khodal Village, Sheo Tehsil, Barmer (Length: 2.86 km)

1. BSNL Telecom Details:

AGM (CFA), CO Jaipur, BSNL vide letter RJCO-19/16(13)/3/2020-CFA/19012 dated 02.02.2026 has stated non-existence of any BSNL telecom assets within the 5 km periphery of proposed route. Thus, BSNL letter is taken as Deemed NOC.

2. Railway Telecom Details:

Deputy CSTE, Telecom, North Western Railway vide letter SG/158/NWR/PTCC/1320 dated 04.02.2026 has given their NOC for charging of the line.

3. EPR zone for the proposed substation is mentioned below:

Name of the proposed Substation	Half diagonal distance, D/2 (mts)	Fault Current I (KA)	Resistance of Earth Mat, R (ohms)	d (mts) at 430 V	d (mts) at 650 V	d (mts) at 7kV	d (mts) at 10kV
220/33 kV KREPL 250 MW PSS at Khodal Village, Sheo Tehsil, Barmer	93.49	35	0.225	1619	1039	12	N.A
ICR	13.28	15.774	0.1	35	19	N.A	N.A

Telecom authorities to ensure the protection of telecom equipment and personnel within the EPR zone of the proposed substation at the cost of the later entrant.