



सत्यमेव जयते



भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
केन्द्रीय विद्युत प्राधिकरण
Central Electricity Authority
विद्युत प्रणाली संचार विकास प्रभाग
Power System Communication Development Division

On behalf of
 Central Level Power & Telecommunication Co-ordination Committee

No: As assigned**Date:** As assigned**Subject:** Certificate of Approval for the Route of Power Line of TEQ Green Power XI Private Limited.

Route Approval Certificate for the following listed lines of TEQ Green Power XI Private Limited is annexed to this letter:

S.No.	Name
1	33 kV overhead transmission Line for 60 MW, Solar Power Project of M/S -TEQ GREEN POWER XI PRIVATE LTD Beed, Maharashtra. Line From Washi Phase 2 (33/33 kV Substation-2) to phase 3 (13.775 MW Solar Parcel). (Length: 3.2 kms) Maharashtra. Line From Washi P Maharashtra. Line From Washi Phase 2 (33/33 kV Substation-2) to phase 3 (13.775 MW Solar Parcel). (Length: 3.2 kms)
2	33 kV overhead transmission Line for 60 MW, Solar Power Project of M/S -TEQ GREEN POWER XI PRIVATE LTD Beed, Maharashtra. Line From Washi Phase 2 (33/33 kV Substation-2) to phase 3 (13.775 MW Solar Parcel). (Length: 3.2 kms) Maharashtra. Line From Washi P Maharashtra. Line From Washi Phase 1 (33/33 kV Substation-1) to New Parcel-1 (4.4 MW Solar Parcel). (Length: 2 kms)
3	33 kV overhead transmission Line for 60 MW, Solar Power Project of M/S -TEQ GREEN POWER XI PRIVATE LTD Beed, Maharashtra. Line From Washi Phase 2 (33/33 kV Substation-2) to phase 3 (13.775 MW Solar Parcel). (Length: 3.2 kms) Maharashtra. Line From Washi P Maharashtra. Line from From Washi Phase 1(33/33 kV Substation-1) to New Parcel-2 (1.1 MW Solar Parcel) (Length: 0.2 kms)

Chief Engineer

1.	TEQ Green Power XI Private Limited	2nd Floor, Square One Mall, Saket Business District Court Chowk, Pushp Vihar, New Delhi - 110 017
----	------------------------------------	---

CEA Case No.: MRA-1339 - 1

Approval for the Route of Extra High Tension (EHT) Power Line / Telecommunication Line

Approval of the Central Level Power & Telecommunication Co-ordination Committee is hereby conveyed for **33 kV overhead transmission Line for 60 MW, Solar Power Project of M/S - TEQ GREEN POWER XI PRIVATE LTD Beed, Maharashtra. Line From Washi Phase 2 (33/33 kV Substation-2) to phase 3 (13.775 MW Solar Parcel). (Length: 3.2 kms) Maharashtra. Line From Washi P Maharashtra. Line From Washi Phase 2 (33/33 kV Substation-2) to phase 3 (13.775 MW Solar Parcel). (Length: 3.2 kms)** particulars of which are given in Annexure I.

The approval is for the route only and is subject to the following conditions.

1. The approval is based on the Power system/ Telecom system conditions' details as reported by the Power supply authority/ Telecom authority at present. Any changes either to Transmission line or the Power system or the paralleling telecommunication lines which are likely to alter the low frequency induction from the estimated at present should be reported to PTCC for its prior approval.
2. The Power and Telecommunication authorities shall be required to adopt such measures as may be recommended by PTCC for counteracting any interference that might arise when the EHT line is in normal operation.
3. Each crossing should satisfy the conditions as laid down in Para 6 -10 of PTCC Code of Practice for crossings.
4. The angle of crossing shall be 90 degrees but in no case less than 60 degrees.
5. The power line shall be equipped with protective switchgear such that the duration of earth current shall be as short as possible but never exceeding 0.5 seconds.
6. The power line shall be energized within a mutually acceptable time limit after obtaining a Certificate from the concerned Telecom and/or Railway authority regarding completion of provision of all protective measures as recommended by PTCC and also under specific clearance from the Telecom and/or Railway authority maintaining the Telecom system.
7. The energization of Extra High Tension power lines would not be held up for want of installation of GD tubes on telecom lines when the induced voltages are in the range of 430 to 650 V.
8. The telecom line shall be commissioned within a mutually acceptable time after completing provision of all protective measures as recommended by PTCC and also after obtaining specific clearance from the Power authority, if certain measures as recommended by PTCC are to be carried out on power system.
9. The later entrant in the field shall bear the entire cost of providing GD tubes and their fitting as recommended by PTCC, including 15% spares and/or any other protective measures as recommended by PTCC.
10. The route approval shall be subject to special conditions as laid down under Annexure II.

Annexure II

Name of the Power Line: 33 kV overhead transmission Line for 60 MW, Solar Power Project of M/S -TEQ GREEN POWER XI PRIVATE LTD Beed, Maharashtra. Line From Washi Phase 2 (33/33 kV Substation-2) to phase 3 (13.775 MW Solar Parcel). (Length: 3.2 kms) Maharashtra. Line From Washi P Maharashtra. Line From Washi Phase 2 (33/33 kV Substation-2) to phase 3 (13.775 MW Solar Parcel). (Length: 3.2 kms)

1. BSNL Telecom Details:

DET (PTCC), Western Zone, BSNL vide letter IC/MBI/PTCC/MRA-2777/03 dated 22.01.2026 has stated non-existence of BSNL UG cable and armoured OFC within the periphery of the proposed route. Thus, BSNL letter is taken as deemed NOC.

2. Railway Telecom Details:

GM (S&T), Central Railway vide reference N.705/T/PTCC/33kV/MAH-1004 dated 02.02.2026 has given their NOC for charging of the line.

3. Defense Telecom Details:

ADG (Telecommunication), MoD vide reference B/46937/Sigs-7(b)/5379 dated 03.02.2026 has given their NOC for charging of the line.

4. EPR zone for the proposed substation is mentioned below:

Name of the proposed Substation	Half diagonal distance, D/2 (mts)	Fault Current I (KA)	Resistance of Earth Mat, R (ohms)	d (mts) at 430 V	d (mts) at 650 V	d (mts) at 7kV	d (mts) at 10kV
IDT	13.7	12.5	0.633	238	153	2	N.A

Telecom authorities to ensure the protection of telecom equipment and personnel within the EPR zone of the proposed substation at the cost of the later entrant.

CEA Case No.: MRA-1339 - 2**Approval for the Route of Extra High Tension (EHT) Power Line / Telecommunication Line**

Approval of the Central Level Power & Telecommunication Co-ordination Committee is hereby conveyed for **33 kV overhead transmission Line for 60 MW, Solar Power Project of M/S - TEQ GREEN POWER XI PRIVATE LTD Beed, Maharashtra. Line From Washi Phase 2 (33/33 kV Substation-2) to phase 3 (13.775 MW Solar Parcel). (Length: 3.2 kms) Maharashtra. Line From Washi P Maharashtra. Line From Washi Phase 1 (33/33 kV Substation-1) to New Parcel-1 (4.4 MW Solar Parcel). (Length: 2 kms)** particulars of which are given in Annexure III.

The approval is for the route only and is subject to the following conditions.

1. The approval is based on the Power system/ Telecom system conditions' details as reported by the Power supply authority/ Telecom authority at present. Any changes either to Transmission line or the Power system or the paralleling telecommunication lines which are likely to alter the low frequency induction from the estimated at present should be reported to PTCC for its prior approval.
2. The Power and Telecommunication authorities shall be required to adopt such measures as may be recommended by PTCC for counteracting any interference that might arise when the EHT line is in normal operation.
3. Each crossing should satisfy the conditions as laid down in Para 6 -10 of PTCC Code of Practice for crossings.
4. The angle of crossing shall be 90 degrees but in no case less than 60 degrees.
5. The power line shall be equipped with protective switchgear such that the duration of earth current shall be as short as possible but never exceeding 0.5 seconds.
6. The power line shall be energized within a mutually acceptable time limit after obtaining a Certificate from the concerned Telecom and/or Railway authority regarding completion of provision of all protective measures as recommended by PTCC and also under specific clearance from the Telecom and/or Railway authority maintaining the Telecom system.
7. The energization of Extra High Tension power lines would not be held up for want of installation of GD tubes on telecom lines when the induced voltages are in the range of 430 to 650 V.
8. The telecom line shall be commissioned within a mutually acceptable time after completing provision of all protective measures as recommended by PTCC and also after obtaining specific clearance from the Power authority, if certain measures as recommended by PTCC are to be carried out on power system.
9. The later entrant in the field shall bear the entire cost of providing GD tubes and their fitting as recommended by PTCC, including 15% spares and/or any other protective measures as recommended by PTCC.
10. The route approval shall be subject to special conditions as laid down under Annexure IV.

Annexure IV

Name of the Power Line: 33 kV overhead transmission Line for 60 MW, Solar Power Project of M/S -TEQ GREEN POWER XI PRIVATE LTD Beed, Maharashtra. Line From Washi Phase 2 (33/33 kV Substation-2) to phase 3 (13.775 MW Solar Parcel). (Length: 3.2 kms) Maharashtra. Line From Washi P Maharashtra. Line From Washi Phase 1 (33/33 kV Substation-1) to New Parcel-1 (4.4 MW Solar Parcel). (Length: 2 kms)

1. BSNL Telecom Details:

DET (PTCC), Western Zone, BSNL vide letter IC/MBI/PTCC/MRA-2777/03 dated 22.01.2026 has stated non-existence of BSNL UG cable and armoured OFC within the periphery of the proposed route. Thus, BSNL letter is taken as deemed NOC.

2. Railway Telecom Details:

GM (S&T), Central Railway vide reference N.705/T/PTCC/33kV/MAH-1004 dated 02.02.2026 has given their NOC for charging of the line.

3. Defense Telecom Details:

ADG (Telecommunication), MoD vide reference B/46937/Sigs-7(b)/5379 dated 03.02.2026 has given their NOC for charging of the line.

4. EPR zone for the proposed substation is mentioned below:

Name of the proposed Substation	Half diagonal distance, D/2 (mts)	Fault Current I (KA)	Resistance of Earth Mat, R (ohms)	d (mts) at 430 V	d (mts) at 650 V	d (mts) at 7kV	d (mts) at 10kV
IDT	13.7	12.5	0.633	238	153	2	N.A

Telecom authorities to ensure the protection of telecom equipment and personnel within the EPR zone of the proposed substation at the cost of the later entrant.

CEA Case No.: MRA-1339 - 3**Approval for the Route of Extra High Tension (EHT) Power Line / Telecommunication Line**

Approval of the Central Level Power & Telecommunication Co-ordination Committee is hereby conveyed for **33 kV overhead transmission Line for 60 MW, Solar Power Project of M/S - TEQ GREEN POWER XI PRIVATE LTD Beed, Maharashtra. Line From Washi Phase 2 (33/33 kV Substation-2) to phase 3 (13.775 MW Solar Parcel). (Length: 3.2 kms) Maharashtra. Line From Washi P Maharashtra. Line from From Washi Phase 1(33/33 kV Substation-1) to New Parcel-2 (1.1 MW Solar Parcel) (Length: 0.2 kms)** particulars of which are given in Annexure V.

The approval is for the route only and is subject to the following conditions.

1. The approval is based on the Power system/ Telecom system conditions' details as reported by the Power supply authority/ Telecom authority at present. Any changes either to Transmission line or the Power system or the paralleling telecommunication lines which are likely to alter the low frequency induction from the estimated at present should be reported to PTCC for its prior approval.
2. The Power and Telecommunication authorities shall be required to adopt such measures as may be recommended by PTCC for counteracting any interference that might arise when the EHT line is in normal operation.
3. Each crossing should satisfy the conditions as laid down in Para 6 -10 of PTCC Code of Practice for crossings.
4. The angle of crossing shall be 90 degrees but in no case less than 60 degrees.
5. The power line shall be equipped with protective switchgear such that the duration of earth current shall be as short as possible but never exceeding 0.5 seconds.
6. The power line shall be energized within a mutually acceptable time limit after obtaining a Certificate from the concerned Telecom and/or Railway authority regarding completion of provision of all protective measures as recommended by PTCC and also under specific clearance from the Telecom and/or Railway authority maintaining the Telecom system.
7. The energization of Extra High Tension power lines would not be held up for want of installation of GD tubes on telecom lines when the induced voltages are in the range of 430 to 650 V.
8. The telecom line shall be commissioned within a mutually acceptable time after completing provision of all protective measures as recommended by PTCC and also after obtaining specific clearance from the Power authority, if certain measures as recommended by PTCC are to be carried out on power system.
9. The later entrant in the field shall bear the entire cost of providing GD tubes and their fitting as recommended by PTCC, including 15% spares and/or any other protective measures as recommended by PTCC.
10. The route approval shall be subject to special conditions as laid down under Annexure VI.

Annexure VI

Name of the Power Line: 33 kV overhead transmission Line for 60 MW, Solar Power Project of M/S -TEQ GREEN POWER XI PRIVATE LTD Beed, Maharashtra. Line From Washi Phase 2 (33/33 kV Substation-2) to phase 3 (13.775 MW Solar Parcel). (Length: 3.2 kms) Maharashtra. Line From Washi P Maharashtra. Line from From Washi Phase 1(33/33 kV Substation-1) to New Parcel-2 (1.1 MW Solar Parcel) (Length: 0.2 kms)

1. BSNL Telecom Details:

DET (PTCC), Western Zone, BSNL vide letter IC/MBI/PTCC/MRA-2777/03 dated 22.01.2026 has stated non-existence of BSNL UG cable and armoured OFC within the periphery of the proposed route. Thus, BSNL letter is taken as deemed NOC.

2. Railway Telecom Details:

GM (S&T), Central Railway vide reference N.705/T/PTCC/33kV/MAH-1004 dated 02.02.2026 has given their NOC for charging of the line.

3. Defense Telecom Details:

ADG (Telecommunication), MoD vide reference B/46937/Sigs-7(b)/5379 dated 03.02.2026 has given their NOC for charging of the line.

4. EPR zone for the proposed substation is mentioned below:

Name of the proposed Substation	Half diagonal distance, D/2 (mts)	Fault Current I (KA)	Resistance of Earth Mat, R (ohms)	d (mts) at 430 V	d (mts) at 650 V	d (mts) at 7kV	d (mts) at 10kV
IDT	13.7	12.5	0.633	238	153	2	N.A

Telecom authorities to ensure the protection of telecom equipment and personnel within the EPR zone of the proposed substation at the cost of the later entrant.