



भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
केन्द्रीय विद्युत प्राधिकरण
Central Electricity Authority
विद्युत प्रणाली संचार विकास प्रभाग
Power System Communication Development Division

On behalf of
 Central Level Power & Telecommunication Co-ordination Committee

No: As assigned

Date: As assigned

Subject: Certificate of Approval for the Route of Power Line of M/s Serentica Renewable India 5 Private Limited.

Route Approval Certificate for the following listed lines of M/s Serentica Renewable India 5 Private Limited is annexed to this letter:

S.No.	Name
1	33KV Feeders of M/s. Serentica Renewables India 5 Private Limited for 3CX300 SQMM 33 KV Al Cable laid Underground and above ground from Block No. 17 of 33 KV feeder no. 328 at 220 /33 KV PSS of Serentica Renewables India 5 Private Limited at Village Jaymalsar, District- Bikaner, Rajasthan. (Length: 2.136 kms).
2	33KV Feeders of M/s. Serentica Renewables India 5 Private Limited for 3CX300 SQMM 33 KV Al Cable laid Underground and above ground from Block No. 18 of 33 KV feeder no. 328 at 220 /33 KV PSS of Serentica Renewables India 5 Private Limited at Village Jaymalsar, District- Bikaner, Rajasthan. (Length: 2.726 kms).
3	33KV Feeders of M/s. Serentica Renewables India 5 Private Limited for 3CX300 SQMM 33 KV Al Cable laid Underground and above ground from Block No. 19 of 33 KV feeder no. 329 at 220 /33 KV PSS of Serentica Renewables India 5 Private Limited at Village Jaymalsar, District- Bikaner, Rajasthan. (Length: 2.475 kms).
4	33KV Feeders of M/s. Serentica Renewables India 5 Private Limited for 3CX300 SQMM 33 KV Al Cable laid Underground and above ground from Block No. 20 of 33 KV feeder no. 330 at 220 /33 KV PSS of Serentica Renewables India 5 Private Limited at Village Jaymalsar, District- Bikaner, Rajasthan. (Length: 3.303 kms).
5	33KV Feeders of M/s. Serentica Renewables India 5 Private Limited for 3CX300 SQMM 33 KV Al Cable laid Underground and above ground from Block No. 21

सेवा भवन, रामाकृष्ण पुरम, सेक्टर -1, नई दिल्ली -110 066 टेलीफोन: 011-26736706 ईमेल: cepcd.cea@gov.in वेबसाइट: www.cea.nic.in

Sewa Bhawan, R.K.Puram, Sector-1, New Delhi-110 066 Telephone: 011-26736706 Email: cepcd.cea@gov.in Website: www.cea.nic.in

	of 33 KV feeder no. 331 at 220 /33 KV PSS of Serentica Renewables India 5 Private Limited at Village Jaymalsar, District- Bikaner, Rajasthan. (Length: 3.179 kms).
6	33KV Feeders of M/s. Serentica Renewables India 5 Private Limited for 3CX300 SQMM 33 KV Al Cable laid Underground and above ground from Block No. 22 of 33 KV feeder no. 332 at 220 /33 KV PSS of Serentica Renewables India 5 Private Limited at Village Jaymalsar, District- Bikaner, Rajasthan. (Length: 1.591 kms).
7	33KV Feeders of M/s. Serentica Renewables India 5 Private Limited for 3CX300 SQMM 33 KV Al Cable laid Underground and above ground from Block No. 23 of 33 KV feeder no. 333 at 220 /33 KV PSS of Serentica Renewables India 5 Private Limited at Village Jaymalsar, District- Bikaner, Rajasthan. (Length: 1.257 kms).
8	33KV Feeders of M/s. Serentica Renewables India 5 Private Limited for 3CX300 SQMM 33 KV Al Cable laid Underground and above ground from Block No. 24 of 33 KV feeder no. 334 at 220 /33 KV PSS of Serentica Renewables India 5 Private Limited at Village Jaymalsar, District- Bikaner, Rajasthan. (Length: 1.385 kms).
9	33KV Feeders of M/s. Serentica Renewables India 5 Private Limited for 3CX300 SQMM 33 KV Al Cable laid Underground and above ground from Block No. 25 of 33 KV feeder no. 335 at 220 /33 KV PSS of Serentica Renewables India 5 Private Limited at Village Jaymalsar, District- Bikaner, Rajasthan. (Length: 2.204 kms).
10	33KV Feeders of M/s. Serentica Renewables India 5 Private Limited for 3CX300 SQMM 33 KV Al Cable laid Underground and above ground from Block No. 26 of 33 KV feeder no. 336 at 220 /33 KV PSS of Serentica Renewables India 5 Private Limited at Village Jaymalsar, District- Bikaner, Rajasthan. (Length: 3.028 kms).
11	33KV Feeders of M/s. Serentica Renewables India 5 Private Limited for 3CX300 SQMM 33 KV Al Cable laid Underground and above ground from Block No. 27 of 33 KV feeder no. 342 at 220 /33 KV PSS of Serentica Renewables India 5 Private Limited at Village Jaymalsar, District- Bikaner, Rajasthan. (Length: 3.836 kms).
12	33KV Feeders of M/s. Serentica Renewables India 5 Private Limited for 3CX300 SQMM 33 KV Al Cable laid Underground and above ground from Block No. 28 of 33 KV feeder no. 343 at 220 /33 KV PSS of Serentica Renewables India 5 Private Limited at Village Jaymalsar, District- Bikaner, Rajasthan. (Length: 2.046 kms).
13	33KV Feeders of M/s. Serentica Renewables India 5 Private Limited for 3CX300 SQMM 33 KV Al Cable laid Underground and above ground from Block No. 29 of 33 KV feeder no. 344 at 220 /33 KV PSS of Serentica Renewables India 5 Private Limited at Village Jaymalsar, District- Bikaner, Rajasthan. (Length: 2.115 kms).

Chief Engineer

1.	M/s Serentica Renewable India 5 Private Limited	5th Floor, RMZ Infinity, Plot No 15, Phase IV, Sector 18, Gurugram, Shahpur, Haryana 122015.
----	---	--

CEA Case No.: RAJ-905 - 328-17**Approval for the Route of Extra High Tension (EHT) Power Line / Telecommunication Line**

Approval of the Central Level Power & Telecommunication Co-ordination Committee is hereby conveyed for **33KV Feeders of M/s. Serentica Renewables India 5 Private Limited for 3CX300 SQMM 33 KV Al Cable laid Underground and above ground from Block No. 17 of 33 KV feeder no. 328 at 220 /33 KV PSS of Serentica Renewables India 5 Private Limited at Village Jaymalsar, District- Bikaner, Rajasthan. (Length: 2.136 kms)**, particulars of which are given in Annexure I.

The approval is for the route only and is subject to the following conditions.

1. The approval is based on the Power system/ Telecom system conditions' details as reported by the Power supply authority/ Telecom authority at present. Any changes either to Transmission line or the Power system or the paralleling telecommunication lines which are likely to alter the low frequency induction from the estimated at present should be reported to PTCC for its prior approval.
2. The Power and Telecommunication authorities shall be required to adopt such measures as may be recommended by PTCC for counteracting any interference that might arise when the EHT line is in normal operation.
3. Each crossing should satisfy the conditions as laid down in Para 6 -10 of PTCC Code of Practice for crossings.
4. The angle of crossing shall be 90 degrees but in no case less than 60 degrees.
5. The power line shall be equipped with protective switchgear such that the duration of earth current shall be as short as possible but never exceeding 0.5 seconds.
6. The power line shall be energized within a mutually acceptable time limit after obtaining a Certificate from the concerned Telecom and/or Railway authority regarding completion of provision of all protective measures as recommended by PTCC and also under specific clearance from the Telecom and/or Railway authority maintaining the Telecom system.
7. The energization of Extra High Tension power lines would not be held up for want of installation of GD tubes on telecom lines when the induced voltages are in the range of 430 to 650 V.
8. The telecom line shall be commissioned within a mutually acceptable time after completing provision of all protective measures as recommended by PTCC and also after obtaining specific clearance from the Power authority, if certain measures as recommended by PTCC are to be carried out on power system.
9. The later entrant in the field shall bear the entire cost of providing GD tubes and their fitting as recommended by PTCC, including 15% spares and/or any other protective measures as recommended by PTCC.
10. The route approval shall be subject to special conditions as laid down under Annexure II.

Annexure I

1

- (a) Name of the Power Supply authority seeking approval M/s Serentica Renewable India 5 Private Limited
- (b) Reference number & date: SRI5PL/PTCC/33kV-UG/25-26/09/05 dated 15.09.2025
E-mail dated 05.02.2026
- (c) Name of the Power line 33KV Feeders of M/s. Serentica Renewables India 5 Private Limited for 3CX300 SQMM 33 KV Al Cable laid Underground and above ground from Block No. 17 of 33 KV feeder no. 328 at 220 /33 KV PSS of Serentica Renewables India 5 Private Limited at Village Jaymalsar, District- Bikaner, Rajasthan. (Length: 2.136 kms).
- (d) Length of Power line: 2.136 kms
- (e) Operating Voltage 33 kV
- (f) Number of circuits 1

2

- (a) Names of parallel telecom lines: As per Annexure-II
- (b) Length of parallelism: As per Annexure-II
- 3 Average value of earth resistivity in the region: 5000 ohm-cms
- 4 Whether LF test necessary: No
- 5 Special conditions subject to which this certificate will be effective As per Annexure-II

Annexure II

Name of the Power Line: 33KV Feeders of M/s. Serentica Renewables India 5 Private Limited for 3CX300 SQMM 33 KV Al Cable laid Underground and above ground from Block No. 17 of 33 KV feeder no. 328 at 220 /33 KV PSS of Serentica Renewables India 5 Private Limited at Village Jaymalsar, District- Bikaner, Rajasthan. (Length: 2.136 kms).

1. BSNL Telecom Details:

AGM (Planning), BSNL, Bikaner vide letter M-3/PTCC Meeting/Bikaner/2025 dated 24.09.2025 has stated non-existence of any BSNL UG or O/H Copper cable, armoured OFC and Exchange within the periphery of 05 kms of the route. Thus, BSNL letter is taken as deemed NOC.

2. Railway Telecom Details:

Deputy CSTE, Tele., North Western Railway vide reference SG/158/NWR/PTCC/1218 dated 06.10.2025 has given their NOC for charging of the line.

3. Defense Telecom Details:

ADG (Telecommunication), MoD, vide letter B/46937/Sigs-7(b)/5134 dated 24.11.2025 has given their NOC for charging of the line.

4. EPR zone for the proposed substation is mentioned below:

Name of the proposed Substation	Half diagonal distance, D/2 (mts)	Fault Current I (KA)	Resistance of Earth Mat, R (ohms)	d (mts) at 430 V	d (mts) at 650 V	d (mts) at 7kV	d (mts) at 10kV
33 kV Solar Block	17.06	25	0.93	905	593	40	23

Telecom authorities to ensure the protection of telecom equipment and personnel within the EPR zone of the proposed substation at the cost of the later entrant.

CEA Case No.: RAJ-905 - 328-18**Approval for the Route of Extra High Tension (EHT) Power Line / Telecommunication Line**

Approval of the Central Level Power & Telecommunication Co-ordination Committee is hereby conveyed for **33KV Feeders of M/s. Serentica Renewables India 5 Private Limited for 3CX300 SQMM 33 KV AI Cable laid Underground and above ground from Block No. 18 of 33 KV feeder no. 328 at 220 /33 KV PSS of Serentica Renewables India 5 Private Limited at Village Jaymalsar, District- Bikaner, Rajasthan. (Length: 2.726 kms)**, particulars of which are given in Annexure III.

The approval is for the route only and is subject to the following conditions.

1. The approval is based on the Power system/ Telecom system conditions' details as reported by the Power supply authority/ Telecom authority at present. Any changes either to Transmission line or the Power system or the paralleling telecommunication lines which are likely to alter the low frequency induction from the estimated at present should be reported to PTCC for its prior approval.
2. The Power and Telecommunication authorities shall be required to adopt such measures as may be recommended by PTCC for counteracting any interference that might arise when the EHT line is in normal operation.
3. Each crossing should satisfy the conditions as laid down in Para 6 -10 of PTCC Code of Practice for crossings.
4. The angle of crossing shall be 90 degrees but in no case less than 60 degrees.
5. The power line shall be equipped with protective switchgear such that the duration of earth current shall be as short as possible but never exceeding 0.5 seconds.
6. The power line shall be energized within a mutually acceptable time limit after obtaining a Certificate from the concerned Telecom and/or Railway authority regarding completion of provision of all protective measures as recommended by PTCC and also under specific clearance from the Telecom and/or Railway authority maintaining the Telecom system.
7. The energization of Extra High Tension power lines would not be held up for want of installation of GD tubes on telecom lines when the induced voltages are in the range of 430 to 650 V.
8. The telecom line shall be commissioned within a mutually acceptable time after completing provision of all protective measures as recommended by PTCC and also after obtaining specific clearance from the Power authority, if certain measures as recommended by PTCC are to be carried out on power system.
9. The later entrant in the field shall bear the entire cost of providing GD tubes and their fitting as recommended by PTCC, including 15% spares and/or any other protective measures as recommended by PTCC.
10. The route approval shall be subject to special conditions as laid down under Annexure IV.

Annexure III

1

- (a) Name of the Power Supply authority seeking approval M/s Serentica Renewable India 5 Private Limited
- (b) Reference number & date: SRI5PL/PTCC/33kV-UG/25-26/09/05 dated 15.09.2025
E-mail dated 05.02.2026
- (c) Name of the Power line 33KV Feeders of M/s. Serentica Renewables India 5 Private Limited for 3CX300 SQMM 33 KV Al Cable laid Underground and above ground from Block No. 18 of 33 KV feeder no. 328 at 220 /33 KV PSS of Serentica Renewables India 5 Private Limited at Village Jaymalsar, District- Bikaner, Rajasthan. (Length: 2.726 kms).
- (d) Length of Power line: 2.726 kms
- (e) Operating Voltage 33 kV
- (f) Number of circuits 1

2

- (a) Names of parallel telecom lines: As per Annexure-IV
- (b) Length of parallelism: As per Annexure-IV
- 3 Average value of earth resistivity in the region: 5000 ohm-cms
- 4 Whether LF test necessary: No
- 5 Special conditions subject to which this certificate will be effective As per Annexure-IV

Annexure IV

Name of the Power Line: 33KV Feeders of M/s. Serentica Renewables India 5 Private Limited for 3CX300 SQMM 33 KV Al Cable laid Underground and above ground from Block No. 18 of 33 KV feeder no. 328 at 220 /33 KV PSS of Serentica Renewables India 5 Private Limited at Village Jaymalsar, District- Bikaner, Rajasthan. (Length: 2.726 kms).

1. BSNL Telecom Details:

AGM (Planning), BSNL, Bikaner vide letter M-3/PTCC Meeting/Bikaner/2025 dated 24.09.2025 has stated non-existence of any BSNL UG or O/H Copper cable, armoured OFC and Exchange within the periphery of 05 kms of the route. Thus, BSNL letter is taken as deemed NOC.

2. Railway Telecom Details:

Deputy CSTE, Tele., North Western Railway vide reference SG/158/NWR/PTCC/1218 dated 06.10.2025 has given their NOC for charging of the line.

3. Defense Telecom Details:

ADG (Telecommunication), MoD, vide letter B/46937/Sigs-7(b)/5134 dated 24.11.2025 has given their NOC for charging of the line.

4. EPR zone for the proposed substation is mentioned below:

Name of the proposed Substation	Half diagonal distance, D/2 (mts)	Fault Current I (KA)	Resistance of Earth Mat, R (ohms)	d (mts) at 430 V	d (mts) at 650 V	d (mts) at 7kV	d (mts) at 10kV
33 kV Solar Block	17.06	25	0.93	905	593	40	23

Telecom authorities to ensure the protection of telecom equipment and personnel within the EPR zone of the proposed substation at the cost of the later entrant.

CEA Case No.: RAJ-905 - 329-19**Approval for the Route of Extra High Tension (EHT) Power Line / Telecommunication Line**

Approval of the Central Level Power & Telecommunication Co-ordination Committee is hereby conveyed for **33KV Feeders of M/s. Serentica Renewables India 5 Private Limited for 3CX300 SQMM 33 KV Al Cable laid Underground and above ground from Block No. 19 of 33 KV feeder no. 329 at 220 /33 KV PSS of Serentica Renewables India 5 Private Limited at Village Jaymalsar, District- Bikaner, Rajasthan. (Length: 2.475 kms)**, particulars of which are given in Annexure V.

The approval is for the route only and is subject to the following conditions.

1. The approval is based on the Power system/ Telecom system conditions' details as reported by the Power supply authority/ Telecom authority at present. Any changes either to Transmission line or the Power system or the paralleling telecommunication lines which are likely to alter the low frequency induction from the estimated at present should be reported to PTCC for its prior approval.
2. The Power and Telecommunication authorities shall be required to adopt such measures as may be recommended by PTCC for counteracting any interference that might arise when the EHT line is in normal operation.
3. Each crossing should satisfy the conditions as laid down in Para 6 -10 of PTCC Code of Practice for crossings.
4. The angle of crossing shall be 90 degrees but in no case less than 60 degrees.
5. The power line shall be equipped with protective switchgear such that the duration of earth current shall be as short as possible but never exceeding 0.5 seconds.
6. The power line shall be energized within a mutually acceptable time limit after obtaining a Certificate from the concerned Telecom and/or Railway authority regarding completion of provision of all protective measures as recommended by PTCC and also under specific clearance from the Telecom and/or Railway authority maintaining the Telecom system.
7. The energization of Extra High Tension power lines would not be held up for want of installation of GD tubes on telecom lines when the induced voltages are in the range of 430 to 650 V.
8. The telecom line shall be commissioned within a mutually acceptable time after completing provision of all protective measures as recommended by PTCC and also after obtaining specific clearance from the Power authority, if certain measures as recommended by PTCC are to be carried out on power system.
9. The later entrant in the field shall bear the entire cost of providing GD tubes and their fitting as recommended by PTCC, including 15% spares and/or any other protective measures as recommended by PTCC.
10. The route approval shall be subject to special conditions as laid down under Annexure VI.

Annexure V

1

- (a) Name of the Power Supply authority seeking approval M/s Serentica Renewable India 5 Private Limited
- (b) Reference number & date: SRI5PL/PTCC/33kV-UG/25-26/09/05 dated 15.09.2025
E-mail dated 05.02.2026
- (c) Name of the Power line 33KV Feeders of M/s. Serentica Renewables India 5 Private Limited for 3CX300 SQMM 33 KV Al Cable laid Underground and above ground from Block No. 19 of 33 KV feeder no. 329 at 220 /33 KV PSS of Serentica Renewables India 5 Private Limited at Village Jaymalsar, District- Bikaner, Rajasthan. (Length: 2.475 kms).
- (d) Length of Power line: 2.475 kms
- (e) Operating Voltage 33 kV
- (f) Number of circuits 1

2

- (a) Names of parallel telecom lines: As per Annexure-VI
- (b) Length of parallelism: As per Annexure-VI
- 3 Average value of earth resistivity in the region: 5000 ohm-cms
- 4 Whether LF test necessary: No
- 5 Special conditions subject to which this certificate will be effective As per Annexure-VI

Annexure VI

Name of the Power Line: 33KV Feeders of M/s. Serentica Renewables India 5 Private Limited for 3CX300 SQMM 33 KV Al Cable laid Underground and above ground from Block No. 19 of 33 KV feeder no. 329 at 220 /33 KV PSS of Serentica Renewables India 5 Private Limited at Village Jaymalsar, District- Bikaner, Rajasthan. (Length: 2.475 kms).

1. BSNL Telecom Details:

AGM (Planning), BSNL, Bikaner vide letter M-3/PTCC Meeting/Bikaner/2025 dated 24.09.2025 has stated non-existence of any BSNL UG or O/H Copper cable, armoured OFC and Exchange within the periphery of 05 kms of the route. Thus, BSNL letter is taken as deemed NOC.

2. Railway Telecom Details:

Deputy CSTE, Tele., North Western Railway vide reference SG/158/NWR/PTCC/1218 dated 06.10.2025 has given their NOC for charging of the line.

3. Defense Telecom Details:

ADG (Telecommunication), MoD, vide letter B/46937/Sigs-7(b)/5134 dated 24.11.2025 has given their NOC for charging of the line.

4. EPR zone for the proposed substation is mentioned below:

Name of the proposed Substation	Half diagonal distance, D/2 (mts)	Fault Current I (KA)	Resistance of Earth Mat, R (ohms)	d (mts) at 430 V	d (mts) at 650 V	d (mts) at 7kV	d (mts) at 10kV
33 kV Solar Block	17.06	25	0.93	905	593	40	23

Telecom authorities to ensure the protection of telecom equipment and personnel within the EPR zone of the proposed substation at the cost of the later entrant.

CEA Case No.: RAJ-905 - 330-20**Approval for the Route of Extra High Tension (EHT) Power Line / Telecommunication Line**

Approval of the Central Level Power & Telecommunication Co-ordination Committee is hereby conveyed for **33KV Feeders of M/s. Serentica Renewables India 5 Private Limited for 3CX300 SQMM 33 KV AI Cable laid Underground and above ground from Block No. 20 of 33 KV feeder no. 330 at 220 /33 KV PSS of Serentica Renewables India 5 Private Limited at Village Jaymalsar, District- Bikaner, Rajasthan. (Length: 3.303 kms)**, particulars of which are given in Annexure VII.

The approval is for the route only and is subject to the following conditions.

1. The approval is based on the Power system/ Telecom system conditions' details as reported by the Power supply authority/ Telecom authority at present. Any changes either to Transmission line or the Power system or the paralleling telecommunication lines which are likely to alter the low frequency induction from the estimated at present should be reported to PTCC for its prior approval.
2. The Power and Telecommunication authorities shall be required to adopt such measures as may be recommended by PTCC for counteracting any interference that might arise when the EHT line is in normal operation.
3. Each crossing should satisfy the conditions as laid down in Para 6 -10 of PTCC Code of Practice for crossings.
4. The angle of crossing shall be 90 degrees but in no case less than 60 degrees.
5. The power line shall be equipped with protective switchgear such that the duration of earth current shall be as short as possible but never exceeding 0.5 seconds.
6. The power line shall be energized within a mutually acceptable time limit after obtaining a Certificate from the concerned Telecom and/or Railway authority regarding completion of provision of all protective measures as recommended by PTCC and also under specific clearance from the Telecom and/or Railway authority maintaining the Telecom system.
7. The energization of Extra High Tension power lines would not be held up for want of installation of GD tubes on telecom lines when the induced voltages are in the range of 430 to 650 V.
8. The telecom line shall be commissioned within a mutually acceptable time after completing provision of all protective measures as recommended by PTCC and also after obtaining specific clearance from the Power authority, if certain measures as recommended by PTCC are to be carried out on power system.
9. The later entrant in the field shall bear the entire cost of providing GD tubes and their fitting as recommended by PTCC, including 15% spares and/or any other protective measures as recommended by PTCC.
10. The route approval shall be subject to special conditions as laid down under Annexure VIII.

Annexure VII

1

- (a) Name of the Power Supply authority seeking approval M/s Serentica Renewable India 5 Private Limited
- (b) Reference number & date: SRI5PL/PTCC/33kV-UG/25-26/09/05 dated 15.09.2025
E-mail dated 05.02.2026
- (c) Name of the Power line 33KV Feeders of M/s. Serentica Renewables India 5 Private Limited for 3CX300 SQMM 33 KV Al Cable laid Underground and above ground from Block No. 20 of 33 KV feeder no. 330 at 220 /33 KV PSS of Serentica Renewables India 5 Private Limited at Village Jaymalsar, District- Bikaner, Rajasthan. (Length: 3.303 kms).
- (d) Length of Power line: 3.303 kms
- (e) Operating Voltage 33 kV
- (f) Number of circuits 1

2

- (a) Names of parallel telecom lines: As per Annexure-VIII
- (b) Length of parallelism: As per Annexure-VIII
- 3 Average value of earth resistivity in the region: 5000 ohm-cms
- 4 Whether LF test necessary: No
- 5 Special conditions subject to which this certificate will be effective As per Annexure-VIII

Annexure VIII

Name of the Power Line: 33KV Feeders of M/s. Serentica Renewables India 5 Private Limited for 3CX300 SQMM 33 KV Al Cable laid Underground and above ground from Block No. 20 of 33 KV feeder no. 330 at 220 /33 KV PSS of Serentica Renewables India 5 Private Limited at Village Jaymalsar, District- Bikaner, Rajasthan. (Length: 3.303 kms).

1. BSNL Telecom Details:

AGM (Planning), BSNL, Bikaner vide letter M-3/PTCC Meeting/Bikaner/2025 dated 24.09.2025 has stated non-existence of any BSNL UG or O/H Copper cable, armoured OFC and Exchange within the periphery of 05 kms of the route. Thus, BSNL letter is taken as deemed NOC.

2. Railway Telecom Details:

Deputy CSTE, Tele., North Western Railway vide reference SG/158/NWR/PTCC/1218 dated 06.10.2025 has given their NOC for charging of the line.

3. Defense Telecom Details:

ADG (Telecommunication), MoD, vide letter B/46937/Sigs-7(b)/5134 dated 24.11.2025 has given their NOC for charging of the line.

4. EPR zone for the proposed substation is mentioned below:

Name of the proposed Substation	Half diagonal distance, D/2 (mts)	Fault Current I (KA)	Resistance of Earth Mat, R (ohms)	d (mts) at 430 V	d (mts) at 650 V	d (mts) at 7kV	d (mts) at 10kV
33 kV Solar Block	17.06	25	0.93	905	593	40	23

Telecom authorities to ensure the protection of telecom equipment and personnel within the EPR zone of the proposed substation at the cost of the later entrant.

CEA Case No.: RAJ-905 - 331-21**Approval for the Route of Extra High Tension (EHT) Power Line / Telecommunication Line**

Approval of the Central Level Power & Telecommunication Co-ordination Committee is hereby conveyed for **33KV Feeders of M/s. Serentica Renewables India 5 Private Limited for 3CX300 SQMM 33 KV Al Cable laid Underground and above ground from Block No. 21 of 33 KV feeder no. 331 at 220 /33 KV PSS of Serentica Renewables India 5 Private Limited at Village Jaymalsar, District- Bikaner, Rajasthan. (Length: 3.179 kms)**, particulars of which are given in Annexure IX.

The approval is for the route only and is subject to the following conditions.

1. The approval is based on the Power system/ Telecom system conditions' details as reported by the Power supply authority/ Telecom authority at present. Any changes either to Transmission line or the Power system or the paralleling telecommunication lines which are likely to alter the low frequency induction from the estimated at present should be reported to PTCC for its prior approval.
2. The Power and Telecommunication authorities shall be required to adopt such measures as may be recommended by PTCC for counteracting any interference that might arise when the EHT line is in normal operation.
3. Each crossing should satisfy the conditions as laid down in Para 6 -10 of PTCC Code of Practice for crossings.
4. The angle of crossing shall be 90 degrees but in no case less than 60 degrees.
5. The power line shall be equipped with protective switchgear such that the duration of earth current shall be as short as possible but never exceeding 0.5 seconds.
6. The power line shall be energized within a mutually acceptable time limit after obtaining a Certificate from the concerned Telecom and/or Railway authority regarding completion of provision of all protective measures as recommended by PTCC and also under specific clearance from the Telecom and/or Railway authority maintaining the Telecom system.
7. The energization of Extra High Tension power lines would not be held up for want of installation of GD tubes on telecom lines when the induced voltages are in the range of 430 to 650 V.
8. The telecom line shall be commissioned within a mutually acceptable time after completing provision of all protective measures as recommended by PTCC and also after obtaining specific clearance from the Power authority, if certain measures as recommended by PTCC are to be carried out on power system.
9. The later entrant in the field shall bear the entire cost of providing GD tubes and their fitting as recommended by PTCC, including 15% spares and/or any other protective measures as recommended by PTCC.
10. The route approval shall be subject to special conditions as laid down under Annexure X.

Annexure IX

1

- (a) Name of the Power Supply authority seeking approval M/s Serentica Renewable India 5 Private Limited
- (b) Reference number & date: SRI5PL/PTCC/33kV-UG/25-26/09/05 dated 15.09.2025
E-mail dated 05.02.2026
- (c) Name of the Power line 33KV Feeders of M/s. Serentica Renewables India 5 Private Limited for 3CX300 SQMM 33 KV Al Cable laid Underground and above ground from Block No. 21 of 33 KV feeder no. 331 at 220 /33 KV PSS of Serentica Renewables India 5 Private Limited at Village Jaymalsar, District- Bikaner, Rajasthan. (Length: 3.179 kms).
- (d) Length of Power line: 3.179 kms
- (e) Operating Voltage 33 kV
- (f) Number of circuits 1

2

- (a) Names of parallel telecom lines: As per Annexure-X
- (b) Length of parallelism: As per Annexure-X
- 3 Average value of earth resistivity in the region: 5000 ohm-cms
- 4 Whether LF test necessary: No
- 5 Special conditions subject to which this certificate will be effective As per Annexure-X

Annexure X

Name of the Power Line: 33KV Feeders of M/s. Serentica Renewables India 5 Private Limited for 3CX300 SQMM 33 KV Al Cable laid Underground and above ground from Block No. 21 of 33 KV feeder no. 331 at 220 /33 KV PSS of Serentica Renewables India 5 Private Limited at Village Jaymalsar, District- Bikaner, Rajasthan. (Length: 3.179 kms).

1. BSNL Telecom Details:

AGM (Planning), BSNL, Bikaner vide letter M-3/PTCC Meeting/Bikaner/2025 dated 24.09.2025 has stated non-existence of any BSNL UG or O/H Copper cable, armoured OFC and Exchange within the periphery of 05 kms of the route. Thus, BSNL letter is taken as deemed NOC.

2. Railway Telecom Details:

Deputy CSTE, Tele., North Western Railway vide reference SG/158/NWR/PTCC/1218 dated 06.10.2025 has given their NOC for charging of the line.

3. Defense Telecom Details:

ADG (Telecommunication), MoD, vide letter B/46937/Sigs-7(b)/5134 dated 24.11.2025 has given their NOC for charging of the line.

4. EPR zone for the proposed substation is mentioned below:

Name of the proposed Substation	Half diagonal distance, D/2 (mts)	Fault Current I (KA)	Resistance of Earth Mat, R (ohms)	d (mts) at 430 V	d (mts) at 650 V	d (mts) at 7kV	d (mts) at 10kV
33 kV Solar Block	17.06	25	0.93	905	593	40	23

Telecom authorities to ensure the protection of telecom equipment and personnel within the EPR zone of the proposed substation at the cost of the later entrant.

CEA Case No.: RAJ-905 - 332-22**Approval for the Route of Extra High Tension (EHT) Power Line / Telecommunication Line**

Approval of the Central Level Power & Telecommunication Co-ordination Committee is hereby conveyed for **33KV Feeders of M/s. Serentica Renewables India 5 Private Limited for 3CX300 SQMM 33 KV AI Cable laid Underground and above ground from Block No. 22 of 33 KV feeder no. 332 at 220 /33 KV PSS of Serentica Renewables India 5 Private Limited at Village Jaymalsar, District- Bikaner, Rajasthan. (Length: 1.591 kms)**, particulars of which are given in Annexure XI.

The approval is for the route only and is subject to the following conditions.

1. The approval is based on the Power system/ Telecom system conditions' details as reported by the Power supply authority/ Telecom authority at present. Any changes either to Transmission line or the Power system or the paralleling telecommunication lines which are likely to alter the low frequency induction from the estimated at present should be reported to PTCC for its prior approval.
2. The Power and Telecommunication authorities shall be required to adopt such measures as may be recommended by PTCC for counteracting any interference that might arise when the EHT line is in normal operation.
3. Each crossing should satisfy the conditions as laid down in Para 6 -10 of PTCC Code of Practice for crossings.
4. The angle of crossing shall be 90 degrees but in no case less than 60 degrees.
5. The power line shall be equipped with protective switchgear such that the duration of earth current shall be as short as possible but never exceeding 0.5 seconds.
6. The power line shall be energized within a mutually acceptable time limit after obtaining a Certificate from the concerned Telecom and/or Railway authority regarding completion of provision of all protective measures as recommended by PTCC and also under specific clearance from the Telecom and/or Railway authority maintaining the Telecom system.
7. The energization of Extra High Tension power lines would not be held up for want of installation of GD tubes on telecom lines when the induced voltages are in the range of 430 to 650 V.
8. The telecom line shall be commissioned within a mutually acceptable time after completing provision of all protective measures as recommended by PTCC and also after obtaining specific clearance from the Power authority, if certain measures as recommended by PTCC are to be carried out on power system.
9. The later entrant in the field shall bear the entire cost of providing GD tubes and their fitting as recommended by PTCC, including 15% spares and/or any other protective measures as recommended by PTCC.
10. The route approval shall be subject to special conditions as laid down under Annexure XII.

Annexure XI

1

- (a) Name of the Power Supply authority seeking approval M/s Serentica Renewable India 5 Private Limited
- (b) Reference number & date: SRI5PL/PTCC/33kV-UG/25-26/09/05 dated 15.09.2025
E-mail dated 05.02.2026
- (c) Name of the Power line 33KV Feeders of M/s. Serentica Renewables India 5 Private Limited for 3CX300 SQMM 33 KV Al Cable laid Underground and above ground from Block No. 22 of 33 KV feeder no. 332 at 220 /33 KV PSS of Serentica Renewables India 5 Private Limited at Village Jaymalsar, District- Bikaner, Rajasthan. (Length: 1.591 kms).
- (d) Length of Power line: 1.591 kms
- (e) Operating Voltage 33 kV
- (f) Number of circuits 1

2

- (a) Names of parallel telecom lines: As per Annexure-XII
- (b) Length of parallelism: As per Annexure-XII

3 Average value of earth resistivity in the region: 5000 ohm-cms

4 Whether LF test necessary: No

5 Special conditions subject to which this certificate will be effective As per Annexure-XII

Annexure XII

Name of the Power Line: 33KV Feeders of M/s. Serentica Renewables India 5 Private Limited for 3CX300 SQMM 33 KV Al Cable laid Underground and above ground from Block No. 22 of 33 KV feeder no. 332 at 220 /33 KV PSS of Serentica Renewables India 5 Private Limited at Village Jaymalsar, District- Bikaner, Rajasthan. (Length: 1.591 kms).

1. BSNL Telecom Details:

AGM (Planning), BSNL, Bikaner vide letter M-3/PTCC Meeting/Bikaner/2025 dated 24.09.2025 has stated non-existence of any BSNL UG or O/H Copper cable, armoured OFC and Exchange within the periphery of 05 kms of the route. Thus, BSNL letter is taken as deemed NOC.

2. Railway Telecom Details:

Deputy CSTE, Tele., North Western Railway vide reference SG/158/NWR/PTCC/1218 dated 06.10.2025 has given their NOC for charging of the line.

3. Defense Telecom Details:

ADG (Telecommunication), MoD, vide letter B/46937/Sigs-7(b)/5134 dated 24.11.2025 has given their NOC for charging of the line.

4. EPR zone for the proposed substation is mentioned below:

Name of the proposed Substation	Half diagonal distance, D/2 (mts)	Fault Current I (KA)	Resistance of Earth Mat, R (ohms)	d (mts) at 430 V	d (mts) at 650 V	d (mts) at 7kV	d (mts) at 10kV
33 kV Solar Block	17.06	25	0.93	905	593	40	23

Telecom authorities to ensure the protection of telecom equipment and personnel within the EPR zone of the proposed substation at the cost of the later entrant.

CEA Case No.: RAJ-905 - 333-23**Approval for the Route of Extra High Tension (EHT) Power Line / Telecommunication Line**

Approval of the Central Level Power & Telecommunication Co-ordination Committee is hereby conveyed for **33KV Feeders of M/s. Serentica Renewables India 5 Private Limited for 3CX300 SQMM 33 KV AI Cable laid Underground and above ground from Block No. 23 of 33 KV feeder no. 333 at 220 /33 KV PSS of Serentica Renewables India 5 Private Limited at Village Jaymalsar, District- Bikaner, Rajasthan. (Length: 1.257 kms)**, particulars of which are given in Annexure XIII.

The approval is for the route only and is subject to the following conditions.

1. The approval is based on the Power system/ Telecom system conditions' details as reported by the Power supply authority/ Telecom authority at present. Any changes either to Transmission line or the Power system or the paralleling telecommunication lines which are likely to alter the low frequency induction from the estimated at present should be reported to PTCC for its prior approval.
2. The Power and Telecommunication authorities shall be required to adopt such measures as may be recommended by PTCC for counteracting any interference that might arise when the EHT line is in normal operation.
3. Each crossing should satisfy the conditions as laid down in Para 6 -10 of PTCC Code of Practice for crossings.
4. The angle of crossing shall be 90 degrees but in no case less than 60 degrees.
5. The power line shall be equipped with protective switchgear such that the duration of earth current shall be as short as possible but never exceeding 0.5 seconds.
6. The power line shall be energized within a mutually acceptable time limit after obtaining a Certificate from the concerned Telecom and/or Railway authority regarding completion of provision of all protective measures as recommended by PTCC and also under specific clearance from the Telecom and/or Railway authority maintaining the Telecom system.
7. The energization of Extra High Tension power lines would not be held up for want of installation of GD tubes on telecom lines when the induced voltages are in the range of 430 to 650 V.
8. The telecom line shall be commissioned within a mutually acceptable time after completing provision of all protective measures as recommended by PTCC and also after obtaining specific clearance from the Power authority, if certain measures as recommended by PTCC are to be carried out on power system.
9. The later entrant in the field shall bear the entire cost of providing GD tubes and their fitting as recommended by PTCC, including 15% spares and/or any other protective measures as recommended by PTCC.
10. The route approval shall be subject to special conditions as laid down under Annexure XIV.

Annexure XIII

1

- (a) Name of the Power Supply authority seeking approval M/s Serentica Renewable India 5 Private Limited
- (b) Reference number & date: SRI5PL/PTCC/33kV-UG/25-26/09/05 dated 15.09.2025
E-mail dated 05.02.2026
- (c) Name of the Power line 33KV Feeders of M/s. Serentica Renewables India 5 Private Limited for 3CX300 SQMM 33 KV Al Cable laid Underground and above ground from Block No. 23 of 33 KV feeder no. 333 at 220 /33 KV PSS of Serentica Renewables India 5 Private Limited at Village Jaymalsar, District- Bikaner, Rajasthan. (Length: 1.257 kms).
- (d) Length of Power line: 1.257 kms
- (e) Operating Voltage 33 kV
- (f) Number of circuits 1

2

- (a) Names of parallel telecom lines: As per Annexure-XIV
- (b) Length of parallelism: As per Annexure-XIV
- 3 Average value of earth resistivity in the region: 5000 ohm-cms
- 4 Whether LF test necessary: No
- 5 Special conditions subject to which this certificate will be effective As per Annexure-XIV

Annexure XIV

Name of the Power Line: 33KV Feeders of M/s. Serentica Renewables India 5 Private Limited for 3CX300 SQMM 33 KV Al Cable laid Underground and above ground from Block No. 23 of 33 KV feeder no. 333 at 220 /33 KV PSS of Serentica Renewables India 5 Private Limited at Village Jaymalsar, District- Bikaner, Rajasthan. (Length: 1.257 kms).

1. BSNL Telecom Details:

AGM (Planning), BSNL, Bikaner vide letter M-3/PTCC Meeting/Bikaner/2025 dated 24.09.2025 has stated non-existence of any BSNL UG or O/H Copper cable, armoured OFC and Exchange within the periphery of 05 kms of the route. Thus, BSNL letter is taken as deemed NOC.

2. Railway Telecom Details:

Deputy CSTE, Tele., North Western Railway vide reference SG/158/NWR/PTCC/1218 dated 06.10.2025 has given their NOC for charging of the line.

3. Defense Telecom Details:

ADG (Telecommunication), MoD, vide letter B/46937/Sigs-7(b)/5134 dated 24.11.2025 has given their NOC for charging of the line.

4. EPR zone for the proposed substation is mentioned below:

Name of the proposed Substation	Half diagonal distance, D/2 (mts)	Fault Current I (KA)	Resistance of Earth Mat, R (ohms)	d (mts) at 430 V	d (mts) at 650 V	d (mts) at 7kV	d (mts) at 10kV
33 kV Solar Block	17.06	25	0.93	905	593	40	23

Telecom authorities to ensure the protection of telecom equipment and personnel within the EPR zone of the proposed substation at the cost of the later entrant.

CEA Case No.: RAJ-905 - 334-24**Approval for the Route of Extra High Tension (EHT) Power Line / Telecommunication Line**

Approval of the Central Level Power & Telecommunication Co-ordination Committee is hereby conveyed for **33KV Feeders of M/s. Serentica Renewables India 5 Private Limited for 3CX300 SQMM 33 KV Al Cable laid Underground and above ground from Block No. 24 of 33 KV feeder no. 334 at 220 /33 KV PSS of Serentica Renewables India 5 Private Limited at Village Jaymalsar, District- Bikaner, Rajasthan. (Length: 1.385 kms)**, particulars of which are given in Annexure XV.

The approval is for the route only and is subject to the following conditions.

1. The approval is based on the Power system/ Telecom system conditions' details as reported by the Power supply authority/ Telecom authority at present. Any changes either to Transmission line or the Power system or the paralleling telecommunication lines which are likely to alter the low frequency induction from the estimated at present should be reported to PTCC for its prior approval.
2. The Power and Telecommunication authorities shall be required to adopt such measures as may be recommended by PTCC for counteracting any interference that might arise when the EHT line is in normal operation.
3. Each crossing should satisfy the conditions as laid down in Para 6 -10 of PTCC Code of Practice for crossings.
4. The angle of crossing shall be 90 degrees but in no case less than 60 degrees.
5. The power line shall be equipped with protective switchgear such that the duration of earth current shall be as short as possible but never exceeding 0.5 seconds.
6. The power line shall be energized within a mutually acceptable time limit after obtaining a Certificate from the concerned Telecom and/or Railway authority regarding completion of provision of all protective measures as recommended by PTCC and also under specific clearance from the Telecom and/or Railway authority maintaining the Telecom system.
7. The energization of Extra High Tension power lines would not be held up for want of installation of GD tubes on telecom lines when the induced voltages are in the range of 430 to 650 V.
8. The telecom line shall be commissioned within a mutually acceptable time after completing provision of all protective measures as recommended by PTCC and also after obtaining specific clearance from the Power authority, if certain measures as recommended by PTCC are to be carried out on power system.
9. The later entrant in the field shall bear the entire cost of providing GD tubes and their fitting as recommended by PTCC, including 15% spares and/or any other protective measures as recommended by PTCC.
10. The route approval shall be subject to special conditions as laid down under Annexure XVI.

Annexure XV

1

- (a) Name of the Power Supply authority seeking approval M/s Serentica Renewable India 5 Private Limited
- (b) Reference number & date: SRI5PL/PTCC/33kV-UG/25-26/09/05 dated 15.09.2025
E-mail dated 05.02.2026
- (c) Name of the Power line 33KV Feeders of M/s. Serentica Renewables India 5 Private Limited for 3CX300 SQMM 33 KV Al Cable laid Underground and above ground from Block No. 24 of 33 KV feeder no. 334 at 220 /33 KV PSS of Serentica Renewables India 5 Private Limited at Village Jaymalsar, District- Bikaner, Rajasthan. (Length: 1.385 kms).
- (d) Length of Power line: 1.385 kms
- (e) Operating Voltage 33 kV
- (f) Number of circuits 1

2

- (a) Names of parallel telecom lines: As per Annexure-XVI
- (b) Length of parallelism: As per Annexure-XVI
- 3 Average value of earth resistivity in the region: 5000 ohm-cms
- 4 Whether LF test necessary: No
- 5 Special conditions subject to which this certificate will be effective As per Annexure-XVI

Annexure XVI

Name of the Power Line: 33KV Feeders of M/s. Serentica Renewables India 5 Private Limited for 3CX300 SQMM 33 KV Al Cable laid Underground and above ground from Block No. 24 of 33 KV feeder no. 334 at 220 /33 KV PSS of Serentica Renewables India 5 Private Limited at Village Jaymalsar, District- Bikaner, Rajasthan. (Length: 1.385 kms).

1. BSNL Telecom Details:

AGM (Planning), BSNL, Bikaner vide letter M-3/PTCC Meeting/Bikaner/2025 dated 24.09.2025 has stated non-existence of any BSNL UG or O/H Copper cable, armoured OFC and Exchange within the periphery of 05 kms of the route. Thus, BSNL letter is taken as deemed NOC.

2. Railway Telecom Details:

Deputy CSTE, Tele., North Western Railway vide reference SG/158/NWR/PTCC/1218 dated 06.10.2025 has given their NOC for charging of the line.

3. Defense Telecom Details:

ADG (Telecommunication), MoD, vide letter B/46937/Sigs-7(b)/5134 dated 24.11.2025 has given their NOC for charging of the line.

4. EPR zone for the proposed substation is mentioned below:

Name of the proposed Substation	Half diagonal distance, D/2 (mts)	Fault Current I (KA)	Resistance of Earth Mat, R (ohms)	d (mts) at 430 V	d (mts) at 650 V	d (mts) at 7kV	d (mts) at 10kV
33 kV Solar Block	17.06	25	0.93	905	593	40	23

Telecom authorities to ensure the protection of telecom equipment and personnel within the EPR zone of the proposed substation at the cost of the later entrant.

CEA Case No.: RAJ-905 - 335-25**Approval for the Route of Extra High Tension (EHT) Power Line / Telecommunication Line**

Approval of the Central Level Power & Telecommunication Co-ordination Committee is hereby conveyed for **33KV Feeders of M/s. Serentica Renewables India 5 Private Limited for 3CX300 SQMM 33 KV Al Cable laid Underground and above ground from Block No. 25 of 33 KV feeder no. 335 at 220 /33 KV PSS of Serentica Renewables India 5 Private Limited at Village Jaymalsar, District- Bikaner, Rajasthan. (Length: 2.204 kms)**, particulars of which are given in Annexure XVII.

The approval is for the route only and is subject to the following conditions.

1. The approval is based on the Power system/ Telecom system conditions' details as reported by the Power supply authority/ Telecom authority at present. Any changes either to Transmission line or the Power system or the paralleling telecommunication lines which are likely to alter the low frequency induction from the estimated at present should be reported to PTCC for its prior approval.
2. The Power and Telecommunication authorities shall be required to adopt such measures as may be recommended by PTCC for counteracting any interference that might arise when the EHT line is in normal operation.
3. Each crossing should satisfy the conditions as laid down in Para 6 -10 of PTCC Code of Practice for crossings.
4. The angle of crossing shall be 90 degrees but in no case less than 60 degrees.
5. The power line shall be equipped with protective switchgear such that the duration of earth current shall be as short as possible but never exceeding 0.5 seconds.
6. The power line shall be energized within a mutually acceptable time limit after obtaining a Certificate from the concerned Telecom and/or Railway authority regarding completion of provision of all protective measures as recommended by PTCC and also under specific clearance from the Telecom and/or Railway authority maintaining the Telecom system.
7. The energization of Extra High Tension power lines would not be held up for want of installation of GD tubes on telecom lines when the induced voltages are in the range of 430 to 650 V.
8. The telecom line shall be commissioned within a mutually acceptable time after completing provision of all protective measures as recommended by PTCC and also after obtaining specific clearance from the Power authority, if certain measures as recommended by PTCC are to be carried out on power system.
9. The later entrant in the field shall bear the entire cost of providing GD tubes and their fitting as recommended by PTCC, including 15% spares and/or any other protective measures as recommended by PTCC.
10. The route approval shall be subject to special conditions as laid down under Annexure XVIII.

Annexure XVII

1

- (a) Name of the Power Supply authority seeking approval M/s Serentica Renewable India 5 Private Limited
- (b) Reference number & date: SRI5PL/PTCC/33kV-UG/25-26/09/05 dated 15.09.2025
E-mail dated 05.02.2026
- (c) Name of the Power line 33KV Feeders of M/s. Serentica Renewables India 5 Private Limited for 3CX300 SQMM 33 KV Al Cable laid Underground and above ground from Block No. 25 of 33 KV feeder no. 335 at 220 /33 KV PSS of Serentica Renewables India 5 Private Limited at Village Jaymalsar, District- Bikaner, Rajasthan. (Length: 2.204 kms).
- (d) Length of Power line: 2.204 kms
- (e) Operating Voltage 33 kV
- (f) Number of circuits 1

2

- (a) Names of parallel telecom lines: As per Annexure-XVIII
- (b) Length of parallelism: As per Annexure-XVIII
- 3 Average value of earth resistivity in the region: 5000 ohm-cms
- 4 Whether LF test necessary: No
- 5 Special conditions subject to which this certificate will be effective As per Annexure-XVIII

Annexure XVIII

Name of the Power Line: 33KV Feeders of M/s. Serentica Renewables India 5 Private Limited for 3CX300 SQMM 33 KV Al Cable laid Underground and above ground from Block No. 25 of 33 KV feeder no. 335 at 220 /33 KV PSS of Serentica Renewables India 5 Private Limited at Village Jaymalsar, District- Bikaner, Rajasthan. (Length: 2.204 kms).

1. BSNL Telecom Details:

AGM (Planning), BSNL, Bikaner vide letter M-3/PTCC Meeting/Bikaner/2025 dated 24.09.2025 has stated non-existence of any BSNL UG or O/H Copper cable, armoured OFC and Exchange within the periphery of 05 kms of the route. Thus, BSNL letter is taken as deemed NOC.

2. Railway Telecom Details:

Deputy CSTE, Tele., North Western Railway vide reference SG/158/NWR/PTCC/1218 dated 06.10.2025 has given their NOC for charging of the line.

3. Defense Telecom Details:

ADG (Telecommunication), MoD, vide letter B/46937/Sigs-7(b)/5134 dated 24.11.2025 has given their NOC for charging of the line.

4. EPR zone for the proposed substation is mentioned below:

Name of the proposed Substation	Half diagonal distance, D/2 (mts)	Fault Current I (KA)	Resistance of Earth Mat, R (ohms)	d (mts) at 430 V	d (mts) at 650 V	d (mts) at 7kV	d (mts) at 10kV
33 kV Solar Block	17.06	25	0.93	905	593	40	23

Telecom authorities to ensure the protection of telecom equipment and personnel within the EPR zone of the proposed substation at the cost of the later entrant.

CEA Case No.: RAJ-905 - 336-26**Approval for the Route of Extra High Tension (EHT) Power Line / Telecommunication Line**

Approval of the Central Level Power & Telecommunication Co-ordination Committee is hereby conveyed for **33KV Feeders of M/s. Serentica Renewables India 5 Private Limited for 3CX300 SQMM 33 KV Al Cable laid Underground and above ground from Block No. 26 of 33 KV feeder no. 336 at 220 /33 KV PSS of Serentica Renewables India 5 Private Limited at Village Jaymalsar, District- Bikaner, Rajasthan. (Length: 3.028 kms)**, particulars of which are given in Annexure XIX.

The approval is for the route only and is subject to the following conditions.

1. The approval is based on the Power system/ Telecom system conditions' details as reported by the Power supply authority/ Telecom authority at present. Any changes either to Transmission line or the Power system or the paralleling telecommunication lines which are likely to alter the low frequency induction from the estimated at present should be reported to PTCC for its prior approval.
2. The Power and Telecommunication authorities shall be required to adopt such measures as may be recommended by PTCC for counteracting any interference that might arise when the EHT line is in normal operation.
3. Each crossing should satisfy the conditions as laid down in Para 6 -10 of PTCC Code of Practice for crossings.
4. The angle of crossing shall be 90 degrees but in no case less than 60 degrees.
5. The power line shall be equipped with protective switchgear such that the duration of earth current shall be as short as possible but never exceeding 0.5 seconds.
6. The power line shall be energized within a mutually acceptable time limit after obtaining a Certificate from the concerned Telecom and/or Railway authority regarding completion of provision of all protective measures as recommended by PTCC and also under specific clearance from the Telecom and/or Railway authority maintaining the Telecom system.
7. The energization of Extra High Tension power lines would not be held up for want of installation of GD tubes on telecom lines when the induced voltages are in the range of 430 to 650 V.
8. The telecom line shall be commissioned within a mutually acceptable time after completing provision of all protective measures as recommended by PTCC and also after obtaining specific clearance from the Power authority, if certain measures as recommended by PTCC are to be carried out on power system.
9. The later entrant in the field shall bear the entire cost of providing GD tubes and their fitting as recommended by PTCC, including 15% spares and/or any other protective measures as recommended by PTCC.
10. The route approval shall be subject to special conditions as laid down under Annexure XX.

Annexure XIX

1

- (a) Name of the Power Supply authority seeking approval M/s Serentica Renewable India 5 Private Limited
- (b) Reference number & date: SRI5PL/PTCC/33kV-UG/25-26/09/05 dated 15.09.2025
E-mail dated 05.02.2026
- (c) Name of the Power line 33KV Feeders of M/s. Serentica Renewables India 5 Private Limited for 3CX300 SQMM 33 KV Al Cable laid Underground and above ground from Block No. 26 of 33 KV feeder no. 336 at 220 /33 KV PSS of Serentica Renewables India 5 Private Limited at Village Jaymalsar, District- Bikaner, Rajasthan. (Length: 3.028 kms).
- (d) Length of Power line: 3.028 kms
- (e) Operating Voltage 33 kV
- (f) Number of circuits 1

2

- (a) Names of parallel telecom lines: As per Annexure-XX
- (b) Length of parallelism: As per Annexure-XX

3 Average value of earth resistivity in the region: 5000 ohm-cms

4 Whether LF test necessary: No

5 Special conditions subject to which this certificate will be effective As per Annexure-XX

Annexure XX

Name of the Power Line: 33KV Feeders of M/s. Serentica Renewables India 5 Private Limited for 3CX300 SQMM 33 KV Al Cable laid Underground and above ground from Block No. 26 of 33 KV feeder no. 336 at 220 /33 KV PSS of Serentica Renewables India 5 Private Limited at Village Jaymalsar, District- Bikaner, Rajasthan. (Length: 3.028 kms).

1. BSNL Telecom Details:

AGM (Planning), BSNL, Bikaner vide letter M-3/PTCC Meeting/Bikaner/2025 dated 24.09.2025 has stated non-existence of any BSNL UG or O/H Copper cable, armoured OFC and Exchange within the periphery of 05 kms of the route. Thus, BSNL letter is taken as deemed NOC.

2. Railway Telecom Details:

Deputy CSTE, Tele., North Western Railway vide reference SG/158/NWR/PTCC/1218 dated 06.10.2025 has given their NOC for charging of the line.

3. Defense Telecom Details:

ADG (Telecommunication), MoD, vide letter B/46937/Sigs-7(b)/5134 dated 24.11.2025 has given their NOC for charging of the line.

4. EPR zone for the proposed substation is mentioned below:

Name of the proposed Substation	Half diagonal distance, D/2 (mts)	Fault Current I (KA)	Resistance of Earth Mat, R (ohms)	d (mts) at 430 V	d (mts) at 650 V	d (mts) at 7kV	d (mts) at 10kV
33 kV Solar Block	17.06	25	0.93	905	593	40	23

Telecom authorities to ensure the protection of telecom equipment and personnel within the EPR zone of the proposed substation at the cost of the later entrant.

CEA Case No.: RAJ-905 - 342-27**Approval for the Route of Extra High Tension (EHT) Power Line / Telecommunication Line**

Approval of the Central Level Power & Telecommunication Co-ordination Committee is hereby conveyed for **33KV Feeders of M/s. Serentica Renewables India 5 Private Limited for 3CX300 SQMM 33 KV Al Cable laid Underground and above ground from Block No. 27 of 33 KV feeder no. 342 at 220 /33 KV PSS of Serentica Renewables India 5 Private Limited at Village Jaymalsar, District- Bikaner, Rajasthan. (Length: 3.836 kms)**, particulars of which are given in Annexure XXI.

The approval is for the route only and is subject to the following conditions.

1. The approval is based on the Power system/ Telecom system conditions' details as reported by the Power supply authority/ Telecom authority at present. Any changes either to Transmission line or the Power system or the paralleling telecommunication lines which are likely to alter the low frequency induction from the estimated at present should be reported to PTCC for its prior approval.
2. The Power and Telecommunication authorities shall be required to adopt such measures as may be recommended by PTCC for counteracting any interference that might arise when the EHT line is in normal operation.
3. Each crossing should satisfy the conditions as laid down in Para 6 -10 of PTCC Code of Practice for crossings.
4. The angle of crossing shall be 90 degrees but in no case less than 60 degrees.
5. The power line shall be equipped with protective switchgear such that the duration of earth current shall be as short as possible but never exceeding 0.5 seconds.
6. The power line shall be energized within a mutually acceptable time limit after obtaining a Certificate from the concerned Telecom and/or Railway authority regarding completion of provision of all protective measures as recommended by PTCC and also under specific clearance from the Telecom and/or Railway authority maintaining the Telecom system.
7. The energization of Extra High Tension power lines would not be held up for want of installation of GD tubes on telecom lines when the induced voltages are in the range of 430 to 650 V.
8. The telecom line shall be commissioned within a mutually acceptable time after completing provision of all protective measures as recommended by PTCC and also after obtaining specific clearance from the Power authority, if certain measures as recommended by PTCC are to be carried out on power system.
9. The later entrant in the field shall bear the entire cost of providing GD tubes and their fitting as recommended by PTCC, including 15% spares and/or any other protective measures as recommended by PTCC.
10. The route approval shall be subject to special conditions as laid down under Annexure XXII.

Annexure XXI

1

- (a) Name of the Power Supply authority seeking approval M/s Serentica Renewable India 5 Private Limited
- (b) Reference number & date: SRI5PL/PTCC/33kV-UG/25-26/09/05 dated 15.09.2025
E-mail dated 05.02.2026
- (c) Name of the Power line 33KV Feeders of M/s. Serentica Renewables India 5 Private Limited for 3CX300 SQMM 33 KV Al Cable laid Underground and above ground from Block No. 27 of 33 KV feeder no. 342 at 220 /33 KV PSS of Serentica Renewables India 5 Private Limited at Village Jaymalsar, District- Bikaner, Rajasthan. (Length: 3.836 kms).
- (d) Length of Power line: 3.836 kms
- (e) Operating Voltage 33 kV
- (f) Number of circuits 1

2

- (a) Names of parallel telecom lines: As per Annexure-XXII
- (b) Length of parallelism: As per Annexure-XXII
- 3 Average value of earth resistivity in the region: 5000 ohm-cms
- 4 Whether LF test necessary: No
- 5 Special conditions subject to which this certificate will be effective As per Annexure-XXII

Annexure XXII

Name of the Power Line: 33KV Feeders of M/s. Serentica Renewables India 5 Private Limited for 3CX300 SQMM 33 KV Al Cable laid Underground and above ground from Block No. 27 of 33 KV feeder no. 342 at 220 /33 KV PSS of Serentica Renewables India 5 Private Limited at Village Jaymalsar, District- Bikaner, Rajasthan. (Length: 3.836 kms).

1. BSNL Telecom Details:

AGM (Planning), BSNL, Bikaner vide letter M-3/PTCC Meeting/Bikaner/2025 dated 24.09.2025 has stated non-existence of any BSNL UG or O/H Copper cable, armoured OFC and Exchange within the periphery of 05 kms of the route. Thus, BSNL letter is taken as deemed NOC.

2. Railway Telecom Details:

Deputy CSTE, Tele., North Western Railway vide reference SG/158/NWR/PTCC/1218 dated 06.10.2025 has given their NOC for charging of the line.

3. Defense Telecom Details:

ADG (Telecommunication), MoD, vide letter B/46937/Sigs-7(b)/5134 dated 24.11.2025 has given their NOC for charging of the line.

4. EPR zone for the proposed substation is mentioned below:

Name of the proposed Substation	Half diagonal distance, D/2 (mts)	Fault Current I (KA)	Resistance of Earth Mat, R (ohms)	d (mts) at 430 V	d (mts) at 650 V	d (mts) at 7kV	d (mts) at 10kV
33 kV Solar Block	17.06	25	0.93	905	593	40	23

Telecom authorities to ensure the protection of telecom equipment and personnel within the EPR zone of the proposed substation at the cost of the later entrant.

CEA Case No.: RAJ-905 - 343-28**Approval for the Route of Extra High Tension (EHT) Power Line / Telecommunication Line**

Approval of the Central Level Power & Telecommunication Co-ordination Committee is hereby conveyed for **33KV Feeders of M/s. Serentica Renewables India 5 Private Limited for 3CX300 SQMM 33 KV AI Cable laid Underground and above ground from Block No. 28 of 33 KV feeder no. 343 at 220 /33 KV PSS of Serentica Renewables India 5 Private Limited at Village Jaymalsar, District- Bikaner, Rajasthan. (Length: 2.046 kms)**, particulars of which are given in Annexure XXIII.

The approval is for the route only and is subject to the following conditions.

1. The approval is based on the Power system/ Telecom system conditions' details as reported by the Power supply authority/ Telecom authority at present. Any changes either to Transmission line or the Power system or the paralleling telecommunication lines which are likely to alter the low frequency induction from the estimated at present should be reported to PTCC for its prior approval.
2. The Power and Telecommunication authorities shall be required to adopt such measures as may be recommended by PTCC for counteracting any interference that might arise when the EHT line is in normal operation.
3. Each crossing should satisfy the conditions as laid down in Para 6 -10 of PTCC Code of Practice for crossings.
4. The angle of crossing shall be 90 degrees but in no case less than 60 degrees.
5. The power line shall be equipped with protective switchgear such that the duration of earth current shall be as short as possible but never exceeding 0.5 seconds.
6. The power line shall be energized within a mutually acceptable time limit after obtaining a Certificate from the concerned Telecom and/or Railway authority regarding completion of provision of all protective measures as recommended by PTCC and also under specific clearance from the Telecom and/or Railway authority maintaining the Telecom system.
7. The energization of Extra High Tension power lines would not be held up for want of installation of GD tubes on telecom lines when the induced voltages are in the range of 430 to 650 V.
8. The telecom line shall be commissioned within a mutually acceptable time after completing provision of all protective measures as recommended by PTCC and also after obtaining specific clearance from the Power authority, if certain measures as recommended by PTCC are to be carried out on power system.
9. The later entrant in the field shall bear the entire cost of providing GD tubes and their fitting as recommended by PTCC, including 15% spares and/or any other protective measures as recommended by PTCC.
10. The route approval shall be subject to special conditions as laid down under Annexure XXIV.

Annexure XXIII

1

- (a) Name of the Power Supply authority seeking approval M/s Serentica Renewable India 5 Private Limited
- (b) Reference number & date: SRI5PL/PTCC/33kV-UG/25-26/09/05 dated 15.09.2025
E-mail dated 05.02.2026
- (c) Name of the Power line 33KV Feeders of M/s. Serentica Renewables India 5 Private Limited for 3CX300 SQMM 33 KV Al Cable laid Underground and above ground from Block No. 28 of 33 KV feeder no. 343 at 220 /33 KV PSS of Serentica Renewables India 5 Private Limited at Village Jaymalsar, District- Bikaner, Rajasthan. (Length: 2.046 kms).
- (d) Length of Power line: 2.046 kms
- (e) Operating Voltage 33 kV
- (f) Number of circuits 1

2

- (a) Names of parallel telecom lines: As per Annexure-XXIV
- (b) Length of parallelism: As per Annexure-XXIV
- 3 Average value of earth resistivity in the region: 5000 ohm-cms
- 4 Whether LF test necessary: No
- 5 Special conditions subject to which this certificate will be effective As per Annexure-XXIV

Annexure XXIV

Name of the Power Line: 33KV Feeders of M/s. Serentica Renewables India 5 Private Limited for 3CX300 SQMM 33 KV Al Cable laid Underground and above ground from Block No. 28 of 33 KV feeder no. 343 at 220 /33 KV PSS of Serentica Renewables India 5 Private Limited at Village Jaymalsar, District- Bikaner, Rajasthan. (Length: 2.046 kms).

1. BSNL Telecom Details:

AGM (Planning), BSNL, Bikaner vide letter M-3/PTCC Meeting/Bikaner/2025 dated 24.09.2025 has stated non-existence of any BSNL UG or O/H Copper cable, armoured OFC and Exchange within the periphery of 05 kms of the route. Thus, BSNL letter is taken as deemed NOC.

2. Railway Telecom Details:

Deputy CSTE, Tele., North Western Railway vide reference SG/158/NWR/PTCC/1218 dated 06.10.2025 has given their NOC for charging of the line.

3. Defense Telecom Details:

ADG (Telecommunication), MoD, vide letter B/46937/Sigs-7(b)/5134 dated 24.11.2025 has given their NOC for charging of the line.

4. EPR zone for the proposed substation is mentioned below:

Name of the proposed Substation	Half diagonal distance, D/2 (mts)	Fault Current I (KA)	Resistance of Earth Mat, R (ohms)	d (mts) at 430 V	d (mts) at 650 V	d (mts) at 7kV	d (mts) at 10kV
33 kV Solar Block	17.06	25	0.93	905	593	40	23

Telecom authorities to ensure the protection of telecom equipment and personnel within the EPR zone of the proposed substation at the cost of the later entrant.

CEA Case No.: RAJ-905 - 344-29**Approval for the Route of Extra High Tension (EHT) Power Line / Telecommunication Line**

Approval of the Central Level Power & Telecommunication Co-ordination Committee is hereby conveyed for **33KV Feeders of M/s. Serentica Renewables India 5 Private Limited for 3CX300 SQMM 33 KV Al Cable laid Underground and above ground from Block No. 29 of 33 KV feeder no. 344 at 220 /33 KV PSS of Serentica Renewables India 5 Private Limited at Village Jaymalsar, District- Bikaner, Rajasthan. (Length: 2.115 kms)**, particulars of which are given in Annexure XXV.

The approval is for the route only and is subject to the following conditions.

1. The approval is based on the Power system/ Telecom system conditions' details as reported by the Power supply authority/ Telecom authority at present. Any changes either to Transmission line or the Power system or the paralleling telecommunication lines which are likely to alter the low frequency induction from the estimated at present should be reported to PTCC for its prior approval.
2. The Power and Telecommunication authorities shall be required to adopt such measures as may be recommended by PTCC for counteracting any interference that might arise when the EHT line is in normal operation.
3. Each crossing should satisfy the conditions as laid down in Para 6 -10 of PTCC Code of Practice for crossings.
4. The angle of crossing shall be 90 degrees but in no case less than 60 degrees.
5. The power line shall be equipped with protective switchgear such that the duration of earth current shall be as short as possible but never exceeding 0.5 seconds.
6. The power line shall be energized within a mutually acceptable time limit after obtaining a Certificate from the concerned Telecom and/or Railway authority regarding completion of provision of all protective measures as recommended by PTCC and also under specific clearance from the Telecom and/or Railway authority maintaining the Telecom system.
7. The energization of Extra High Tension power lines would not be held up for want of installation of GD tubes on telecom lines when the induced voltages are in the range of 430 to 650 V.
8. The telecom line shall be commissioned within a mutually acceptable time after completing provision of all protective measures as recommended by PTCC and also after obtaining specific clearance from the Power authority, if certain measures as recommended by PTCC are to be carried out on power system.
9. The later entrant in the field shall bear the entire cost of providing GD tubes and their fitting as recommended by PTCC, including 15% spares and/or any other protective measures as recommended by PTCC.
10. The route approval shall be subject to special conditions as laid down under Annexure XXVI.

Annexure XXV

1

- (a) Name of the Power Supply authority seeking approval M/s Serentica Renewable India 5 Private Limited
- (b) Reference number & date: SRI5PL/PTCC/33kV-UG/25-26/09/05 dated 15.09.2025
E-mail dated 05.02.2026
- (c) Name of the Power line 33KV Feeders of M/s. Serentica Renewables India 5 Private Limited for 3CX300 SQMM 33 KV Al Cable laid Underground and above ground from Block No. 29 of 33 KV feeder no. 344 at 220 /33 KV PSS of Serentica Renewables India 5 Private Limited at Village Jaymalsar, District- Bikaner, Rajasthan. (Length: 2.115 kms).
- (d) Length of Power line: 2.115 kms
- (e) Operating Voltage 33 kV
- (f) Number of circuits 1

2

- (a) Names of parallel telecom lines: As per Annexure-XXVI
- (b) Length of parallelism: As per Annexure-XXVI
- 3 Average value of earth resistivity in the region: 5000 ohm-cms
- 4 Whether LF test necessary: No
- 5 Special conditions subject to which this certificate will be effective As per Annexure-XXVI

Annexure XXVI

Name of the Power Line: 33KV Feeders of M/s. Serentica Renewables India 5 Private Limited for 3CX300 SQMM 33 KV Al Cable laid Underground and above ground from Block No. 29 of 33 KV feeder no. 344 at 220 /33 KV PSS of Serentica Renewables India 5 Private Limited at Village Jaymalsar, District- Bikaner, Rajasthan. (Length: 2.115 kms).

1. BSNL Telecom Details:

AGM (Planning), BSNL, Bikaner vide letter M-3/PTCC Meeting/Bikaner/2025 dated 24.09.2025 has stated non-existence of any BSNL UG or O/H Copper cable, armoured OFC and Exchange within the periphery of 05 kms of the route. Thus, BSNL letter is taken as deemed NOC.

2. Railway Telecom Details:

Deputy CSTE, Tele., North Western Railway vide reference SG/158/NWR/PTCC/1218 dated 06.10.2025 has given their NOC for charging of the line.

3. Defense Telecom Details:

ADG (Telecommunication), MoD, vide letter B/46937/Sigs-7(b)/5134 dated 24.11.2025 has given their NOC for charging of the line.

4. EPR zone for the proposed substation is mentioned below:

Name of the proposed Substation	Half diagonal distance, D/2 (mts)	Fault Current I (KA)	Resistance of Earth Mat, R (ohms)	d (mts) at 430 V	d (mts) at 650 V	d (mts) at 7kV	d (mts) at 10kV
33 kV Solar Block	17.06	25	0.93	905	593	40	23

Telecom authorities to ensure the protection of telecom equipment and personnel within the EPR zone of the proposed substation at the cost of the later entrant.