



सत्यमेव जयते



**भारत सरकार**  
**Government of India**  
**विद्युत मंत्रालय**  
**Ministry of Power**  
**केन्द्रीय विद्युत प्राधिकरण**  
**Central Electricity Authority**  
**विद्युत प्रणाली संचार विकास प्रभाग**  
**Power System Communication Development Division**  
 \*\*\*\*\*

On behalf of  
 Central Level Power & Telecommunication Co-ordination Committee

**No:** As assigned

**Date:** As assigned

**Subject:** Provisional Certificate of Approval for the Route of Power Line of NTPC Green Energy Limited.

**Provisional Route Approval Certificate** for the following listed lines of NTPC Green Energy Limited is annexed to this letter:

S.No.	Name
1	33KV UG Cable from existing 33KV Existing Pooling Switch gear to Proposed 33/0.66KV 6MW (AC) additional block and 33KV UG Cable from Proposed 33/0.66KV 6MW (AC) additional block to proposed 2 nos of 33/0.66KV 2.2MVA Transformer at M/s NTPC CPSU Solar Power Plant, Ettayapuram, Thoothukudi District, Tamil Nadu.

Chief Engineer

To,

1.	NTPC Green Energy Limited	4th/5th Floor, RE Building, NETRA Complex, E-3, Ecotech-II, Udyog Vihar, Greater Noida, Gautam Buddha Nagar, Uttar Pradesh
----	---------------------------	--

**CEA Case No.: TN - 789**

Provisional Approval for the Route of Extra High Tension (EHT)/ High Tension (HT) Power Line / Telecommunication Line

**Provisional Approval** of the Central Level Power & Telecommunication Co-ordination Committee is hereby conveyed having a validity of 60 days from the date of issuance for **33KV UG Cable from existing 33KV Existing Pooling Switch gear to Proposed 33/0.66KV 6MW (AC) additional block and 33KV UG Cable from Proposed 33/0.66KV 6MW (AC) additional block to proposed 2 nos of 33/0.66KV 2.2MVA Transformer at M/s NTPC CPSU Solar Power Plant, Ettayapuram, Thoothukudi District, Tamil Nadu.** particulars of which are given in Annexure I.

The approval is for the route only and is subject to the following conditions.

1. The approval is based on the Power system/ Telecom system conditions' details as reported by the Power supply authority/ Telecom authority at present. Any changes either to Transmission line or the Power system or the paralleling telecommunication lines which are likely to alter the low frequency induction from the estimated at present should be reported to PTCC for its prior approval.
2. The Power and Telecommunication authorities shall be required to adopt such measures as may be recommended by PTCC for counteracting any interference that might arise when the EHT line is in normal operation.
3. Each crossing should satisfy the conditions as laid down in Para 6 -10 of PTCC Code of Practice for crossings.
4. The angle of crossing shall be 90 degrees but in no case less than 60 degrees.
5. The power line shall be equipped with protective switchgear such that the duration of earth current shall be as short as possible but never exceeding 0.5 seconds.
6. The power line shall be energized within a mutually acceptable time limit after obtaining a Certificate from the concerned Telecom and/or Railway authority regarding completion of provision of all protective measures as recommended by PTCC and also under specific clearance from the Telecom and/or Railway authority maintaining the Telecom system.
7. The energization of Extra High Tension power lines would not be held up for want of installation of GD tubes on telecom lines when the induced voltages are in the range of 430 to 650 V.
8. The telecom line shall be commissioned within a mutually acceptable time after completing provision of all protective measures as recommended by PTCC and also after obtaining specific clearance from the Power authority, if certain measures as recommended by PTCC are to be carried out on power system.
9. The later entrant in the field shall bear the entire cost of providing GD tubes and their fitting as recommended by PTCC, including 15% spares and/or any other protective measures as recommended by PTCC.
10. The route approval shall be subject to special conditions as laid down under Annexure II.

**Annexure I**

1

- (a) Name of the Power Supply authority seeking approval NTPC Green Energy Limited
- (b) Reference number & date: NGEL/Ettayapuram/Letter/007 dated 10.01.2026
- (c) Name of the Power line 33KV UG Cable from existing 33KV Existing Pooling Switch gear to Proposed 33/0.66KV 6MW (AC) additional block and 33KV UG Cable from Proposed 33/0.66KV 6MW (AC) additional block to proposed 2 nos of 33/0.66KV 2.2MVA Transformer at M/s NTPC CPSU Solar Power Plant, Ettayapuram, Thoothukudi District, Tamil Nadu.
- (d) Length of Power line:
- (e) Operating Voltage 33 kV
- (f) Number of circuits S/C

2

- (a) Names of parallel telecom lines: As per Annexure-II
- (b) Length of parallelism: As per Annexure-II
- 3 Average value of earth resistivity in the region: 10000 ohm-cms
- 4 Whether LF test necessary: No
- 5 Special conditions subject to which this certificate will be effective As per Annexure-II

## **Annexure II**

**Name of the Power Line:** 33KV UG Cable from existing 33KV Existing Pooling Switch gear to Proposed 33/0.66KV 6MW (AC) additional block and 33KV UG Cable from Proposed 33/0.66KV 6MW (AC) additional block to proposed 2 nos of 33/0.66KV 2.2MVA Transformer at M/s NTPC CPSU Solar Power Plant, Ettayapuram, Thoothukudi District, Tamil Nadu.

### **1. BSNL Telecom Details:**

DET (PTCC), South Region, Chennai BSNL vide letter No. SR-PTCC/MTN 1711/06 dated 18.02.2026 has informed that there is no telecom lines/ cable or assets exists in the corridor of the power line.

### **2. Railway Telecom Details:**

GM (S&T) , Southern Railway vide letter No.188020.W.384/3/6/65 dated 04-03-2026 has given NOC for charging of the line