



सत्यमेव जयते



भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
केन्द्रीय विद्युत प्राधिकरण
Central Electricity Authority
विद्युत प्रणाली संचार विकास प्रभाग
Power System Communication Development Division

CEA Case No.: CHH-93		
Induced Voltage calculation for PTCC proposal of 220kV D/C Transmission Line from 765/400/220 kV PGCIL Raipur pool to 220/132 kV CSPTCL Gendpur (Kabirdham) S/s. (Length - 59.35 km)		
S. No	Reference No.	Dated
(i)	CSPTCL: 02-04/ PL/PTCC-98/2681	11.03.2026
(ii)	CSPTCL: e-mail	06.04.2026
(iii)	CSPTCL: Undertaking received via e-mail	06.04.2026
(iv)	BSNL : IC/MBI/PTCC/MP received via e-mail	26.03.2026
(v)	BSNL : Details received via e-mail	06.04.2026
(vi)	SECR: SECR/S&T/PTCC /NOC/ 1746	23.03.2026

The PTCC proposal submitted vide references (i) and (ii) has been examined. DET-PTCC (WZ), BSNL and Dy. CSTE /Tele, South East Central Railway have issued their No Objection Certificate (NOC) vide references (iv) and (vi) respectively. As all stations are existing, the EPR zone is not warranted.

Telecommunication details from Defense are still pending and vide above reference (iii) transmission utility has shown urgency for charging of line and has requested for provisional PTCC approval. Taking above into consideration, necessary action for issuance of provisional PTCC route approval (RAC) shall be taken under intimation to this office in the stipulated period as specified in PTCC Manual and subsequent CLPTCC meetings.

As per the decision taken in 111th and 112th CLPTCC meeting, necessary instructions for “Deemed Energization approval” shall be specified while issuing provisional RAC.

Chief Engineer

To,

1.	Divisional Engineer (PTCC), Western Zone	QA & Inspection circle, 1st floor, D-wing, BSNL Admin Bldg., Juhu Tara Road, Santa Cruz (West), Mumbai-400055	
2.	Director General of Signals	General Staff Branch, Integrated HQ, MoD (army), Sena Bhawan, DHQ, PO, New Delhi- 110 105	With a request to provide details of Telecom assets/ NOC at the earliest for issuance of final RAC.
3.	CSPTCL	Office of the executive Director (PC&RA), 3 rd Floor, State Load Dispatch Center Danganiya, Raipur (C.G.) – 492013	Copy for information