



सत्यमेव जयते



भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
केन्द्रीय विद्युत प्राधिकरण
Central Electricity Authority
विद्युत प्रणाली संचार विकास प्रभाग
Power System Communication Development Division

CEA Case No.: GUJ-1045		
Final Approval of the Central Level Power & Telecommunication Co-ordination Committee for 33 KV UG for 8 Nos of Feeders from 400/33 KV S/s SRPL-PSS-10 to Battery Energy Storage System (BESS) located near PSS-10 Khavda RE Park, Near Karim Shahi 10 km prior to Vighakot border (Length: 16.363 km) - regd.		
S. No	Reference No.	Dated
(i)	ARE43L: ARE43L/PTCC/25-26/BESS Khavda/001	11.10.2025
(ii)	CEA File No: CEA-PS-17-11(12)/16/2026-PCD Division/I/59497/2026	22.01.2026
(iii)	BSNL: IC/MBI/PTCC/Offline/GUJ-3174	23.01.2026
(iv)	Defense: B/46937/Sigs7(b)/5259	10.03.2026
(v)	Adani: Email for Defense NOC	15.04.2026

Vide reference (ii) above, Provisional Approval of the Central Level Power & Telecommunication Co-ordination Committee was conveyed for below mentioned lines considering the urgent request for charging of the lines by M/s Adani Renewable Energy Forty Three Limited.

S.No.	Name
1	33 kV Feeder No.0104 3C x 400 sqmm Al cable laid underground from 400/33 kV Substation (SRPL-PSS-10) to M/s Adani Renewable Energy Forty Three Limited Battery Energy Storage System (BESS) located near PSS-10, Khavda RE Park (Length: 2.185 kms)
2	33 kV Feeder No.0206 3C x 400 sqmm Al cable laid underground from 400/33 kV Substation (SRPL-PSS-10) to M/s Adani Renewable Energy Forty Three Limited Battery Energy Storage System (BESS) located near PSS-10, Khavda RE Park (Length: 1.755 kms)
3	33 kV Feeder No.0304 3C x 400 sqmm Al cable laid underground from 400/33 kV Substation (SRPL-PSS-10) to M/s Adani Renewable Energy Forty Three Limited Battery Energy Storage System (BESS) located near PSS-10, Khavda RE Park (Length: 2.025 kms)

4	33 kV Feeder No.0404 3C x 400 sqmm Al cable laid underground from 400/33 kV Substation (SRPL-PSS-10) to M/s Adani Renewable Energy Forty Three Limited Battery Energy Storage System (BESS) located near PSS-10, Khavda RE Park (Length: 1.825 kms)
5	33 kV Feeder No.0507 3C x 400 sqmm Al cable laid underground from 400/33 kV Substation (SRPL-PSS-10) to M/s Adani Renewable Energy Forty Three Limited Battery Energy Storage System (BESS) located near PSS-10, Khavda RE Park (Length: 1.630 kms)
6	33 kV Feeder No.0606 3C x 400 sqmm Al cable laid underground from 400/33 kV Substation (SRPL-PSS-10) to M/s Adani Renewable Energy Forty Three Limited Battery Energy Storage System (BESS) located near PSS-10, Khavda RE Park (Length: 1.635 kms)
7	33 kV Feeder No.0706 3C x 400 sqmm Al cable laid underground from 400/33 kV Substation (SRPL-PSS-10) to M/s Adani Renewable Energy Forty Three Limited Battery Energy Storage System (BESS) located near PSS-10, Khavda RE Park (Length: 2.574 kms)
8	33 kV Feeder No.0804 3C x 400 sqmm Al cable laid underground from 400/33 kV Substation (SRPL-PSS-10) to M/s Adani Renewable Energy Forty Three Limited Battery Energy Storage System (BESS) located near PSS-10, Khavda RE Park (Length: 2.734 kms)

Now BSNL and DG Signals, MoD vide reference (iii) and (iv) above respectively has accorded their No Objection Certificate (NOC) for charging of the above mentioned transmission lines. In view of the above, Final Approval of the Central Level Power & Telecommunication Co-ordination Committee is hereby conveyed to the route of above mentioned transmission lines.

Encl.: As above

Chief Engineer

To,

1.	M/s Adani Renewable Energy Forty Three Limited	Adani Corporate House, Shantigram, Nr. Vaishno Devi Circle, S.G. Highway, Khodiyar, Ahemdabad-382421, Gujarat
----	--	---