



सत्यमेव जयते



भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
केन्द्रीय विद्युत प्राधिकरण
Central Electricity Authority
विद्युत प्रणाली संचार विकास प्रभाग
Power System Communication Development Division

CEA Case No.: GUJ-1057		
Final Approval of the Central Level Power & Telecommunication Co-ordination Committee for 33 KV UG cable with 3CX300 sqmm 33 KV E Armoured HT cable from 400 KV PSS-08 to Solar Plant IDT (Plot no. A15a) of Adani Hybrid Energy Jaisalmer Five Ltd (AHEJ5L) at Khavda re Park (Length: 85.384 km) - regd.		
S. No	Reference No.	Dated
(i)	AHEJ5L: Khavda/PSS-08/AHEJ5L/PTCC-33kV UG/02	13.01.2026
(ii)	CEA File No: CEA-PS-17-11(12)/187/2025-PCD Division/I/60242/2026	06.02.2026
(iii)	Defense: B/46937/Sigs7(b)/5320	12.03.2026
(iv)	Adani: Email for Defense NOC	01.04.2026

Vide reference (ii) above, Provisional Approval of the Central Level Power & Telecommunication Co-ordination Committee was conveyed for below mentioned lines considering the urgent request for charging of the lines by M/s Adani Hybrid Energy Jaisalmer Five Limited.

S.No.	Name
1	33 kV, 3C x 300 sqmm armoured HT UG cable feeder no. 0606 from 400/33 kV Substation PSS-8 to Solar Plant IDT block no. 9 & 10 (Plot No. 15A) of M/s Adani Hybrid Energy Jaisalmer Five Limited at Khavda RE Park (Length: 13.319 kms)
2	33 kV, 3C x 300 sqmm armoured HT UG cable feeder no. 0607 from 400/33 kV Substation PSS-8 to Solar Plant IDT block no. 4 & 7 (Plot No. 15A) of M/s Adani Hybrid Energy Jaisalmer Five Limited at Khavda RE Park (Length: 16.951 kms)
3	33 kV, 3C x 300 sqmm armoured HT UG cable feeder no. 0608 from 400/33 kV Substation PSS-8 to Solar Plant IDT block no. 1 & 12 (Plot No. 15A) of M/s Adani Hybrid Energy Jaisalmer Five Limited at Khavda RE Park (Length: 11.863 kms)
4	33 kV, 3C x 300 sqmm armoured HT UG cable feeder no. 0613 from 400/33 kV Substation PSS-8 to Solar Plant IDT block no. 3 & 8 (Plot No. 15A) of M/s Adani Hybrid Energy Jaisalmer Five Limited at Khavda RE Park (Length: 13.554 kms)

5	33 kV, 3C x 300 sqmm armoured HT UG cable feeder no. 0614 from 400/33 kV Substation PSS-8 to Solar Plant IDT block no. 5 & 6 (Plot No. 15A) of M/s Adani Hybrid Energy Jaisalmer Five Limited at Khavda RE Park (Length: 17.509 kms)
6	33 kV, 3C x 300 sqmm armoured HT UG cable feeder no. 0614 from 400/33 kV Substation PSS-8 to Solar Plant IDT block no. 11 & 12 (Plot No. 15A) of M/s Adani Hybrid Energy Jaisalmer Five Limited at Khavda RE Park (Length: 12.188 kms)

Now DG Signals, MoD vide reference (iii) above has accorded their No Objection Certificate (NOC) for charging of the above mentioned transmission lines. In view of the above, Final Approval of the Central Level Power & Telecommunication Co-ordination Committee is hereby conveyed to the route of above mentioned transmission lines.

Encl.: As above

Chief Engineer

To,

1.	M/s Adani Hybrid Energy Jaisalmer Five Limited	Adani Corporate House, Shantigram, Nr. Vaishno Devi Circle, S.G. Highway, Khodiyar, Ahemdabad-382421, Gujarat
----	--	---