



सत्यमेव जयते



भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
केन्द्रीय विद्युत प्राधिकरण
Central Electricity Authority
विद्युत प्रणाली संचार विकास प्रभाग
Power System Communication Development Division

CEA Case No.: GUJ-1063		
Final Approval of the Central Level Power & Telecommunication Co-ordination Committee for 33 KV UG cable with 3CX300 sqmm 33 KV (E) Armoured HT cable from 400 KV PSS-10 to Solar Plant IDT (Plot no. S5a) of Adani Green Energy Twenty Four Ltd (AGE24L) at Khavda re Park (Length: 31.848 km) - regd.		
S. No	Reference No.	Dated
(i)	AGE24L: Khavda/PSS-10/AGE24L/PTCC-33kV UG/01	01.11.2025
(ii)	CEA File No: CEA-PS-17-11(12)/209/2025-PCD Division/I/58440/2025	31.12.2026
(iii)	Defense: B/46937/Sigs7(b)/5323	10.03.2026
(iv)	Adani: Email for Defense NOC	01.04.2026

Vide reference (ii) above, Provisional Approval of the Central Level Power & Telecommunication Co-ordination Committee was conveyed for below mentioned lines considering the urgent request for charging of the lines by M/s Adani Green Energy Twenty Four Limited.

S. No	Name
1.	33 KV XLPE, Al, Ar, U/G cable (2RX3CX300 Sq.mm) from proposed Feeder No - 309 including Inverter Duty Transformer (2 nos. of 800V/33 KV, 12.5 MVA) from Solar Block 4 & 9 to Feeder number 309 at SRPL PSS-10 33/400 kV, Solar Power Project of M/s Adani Green Energy Twenty Four Limited in Village-Khavda, District-Kachchh (Line Length Approx. 5.506 kms).
2.	33 KV XLPE, Al, Ar, U/G cable (2RX3CX300 Sq.mm) from proposed Feeder No - 115 including Inverter Duty Transformer (2 nos. of 800V/33 KV, 12.5 MVA) from Solar Block 7 & 12 to Feeder number 115 at SRPL PSS-10 33/400 kV, Solar Power Project of M/s Adani Green Energy Twenty Four Limited in Village-Khavda, District-Kachchh (Line Length Approx. 4.798 kms).

3.	33 KV XLPE, Al, Ar, U/G cable (2RX3CX300 Sq.mm) from proposed Feeder No - 215 including Inverter Duty Transformer (2 nos. of 800V/33 KV, 12.5 MVA) from Solar Block 10 & 11 to Feeder number 215 at SRPL PSS-10 33/400 kV, Solar Power Project of M/s Adani Green Energy Twenty Four Limited in Village-Khavda, District-Kachchh (Line Length Approx. 6.797 kms).
4.	33 KV XLPE, Al, Ar, U/G cable (2RX3CX300 Sq.mm) from proposed Feeder No - 214 including Inverter Duty Transformer (2 nos. of 800V/33 KV, 12.5 MVA) from Solar Block 6 & 8 to Feeder number 214 at SRPL PSS-10 33/400 kV, Solar Power Project of M/s Adani Green Energy Twenty Four Limited in Village-Khavda, District-Kachchh (Line Length Approx. 5.997 kms).
5.	33 KV XLPE, Al, Ar, U/G cable (2RX3CX300 Sq.mm) from proposed Feeder No - 109 including Inverter Duty Transformer (2 nos. of 800V/33 KV, 12.5 MVA) from Solar Block 3 & 5 to Feeder number 109 at SRPL PSS-10 33/400 kV, Solar Power Project of M/s Adani Green Energy Twenty Four Limited in Village-Khavda, District-Kachchh (Line Length Approx. 5.155 kms).
6.	33 KV XLPE, Al, Ar, U/G cable (2RX3CX300 Sq.mm) from proposed Feeder No - 307 including Inverter Duty Transformer (2 nos. of 800V/33 KV, 12.5 MVA) from Solar Block 1 & 2 to Feeder number 307 at SRPL PSS-10 33/400 kV, Solar Power Project of M/s Adani Green Energy Twenty Four Limited in Village-Khavda, District-Kachchh (Line Length Approx. 3.595 kms).

Now DG Signals, MoD vide reference (iii) above has accorded their No Objection Certificate (NOC) for charging of the above mentioned transmission lines. In view of the above, Final Approval of the Central Level Power & Telecommunication Co-ordination Committee is hereby conveyed to the route of above mentioned transmission lines.

Encl.: As above

Chief Engineer

To,

1.	M/s Adani Green Energy Twenty Four Limited	Adani Corporate House, Shantigram, Nr. Vaishno Devi Circle, SG Highway, Khodiyar, Ahmedabad-382421
----	--	--