



सत्यमेव जयते



**भारत सरकार**  
**Government of India**  
**विद्युत मंत्रालय**  
**Ministry of Power**  
**केन्द्रीय विद्युत प्राधिकरण**  
**Central Electricity Authority**  
**विद्युत प्रणाली संचार विकास प्रभाग**  
**Power System Communication Development Division**  
 \*\*\*\*\*

On behalf of  
 Central Level Power & Telecommunication Co-ordination Committee

**No:** As assigned

**Date:** As assigned

**Subject:** Certificate of Approval for the Route of Power Line of M/s Serentica Renewables India 6 Private Limited.

**Route Approval Certificate** for the following listed lines of M/s Serentica Renewables India 6 Private Limited is annexed to this letter:

S.No.	Name
1	33KV Feeder No. 320 through SPR HT RMU Board 1 to Solar Block No. 1 and Solar Block No. 1 to Solar Block No. 2, Partially laid underground (Length: - 2.73 kms) and partially Overhead on D/c line (Length: - 6.59 kms) on Eco Panther Conductor for 53MW Solar Power Plant of M/s. Serentica Renewables India 6 Private Limited to 220/33 KV PSS of Serentica Renewables India 3 Private Limited at Village Balagod, Gadag. (Total Length: - 9.32 kms).
2	33KV Feeder No. 321 through SPR HT RMU Board 2 to Solar Block No. 3 and Solar Block No. 3 to Solar Block No. 4 Partially laid underground (Length: - 1.44 kms) and partially Overhead on D/c line (Length: - 6.59 kms) on Eco Panther Conductor for 53MW Solar Power Plant of M/s. Serentica Renewables India 6 Private Limited to 220/33 KV PSS of Serentica Renewables India 3 Private Limited at Village Balagod, Gadag. (Total Length: - 8.03 kms)

Chief Engineer

1.	M/s Serentica Renewables India 6 Private Limited	RMZ Infinity, 5th Floor, Plot No. 15, Udyog Vihar, Phase-IV, Gurugram – 122 015
----	--	---

**CEA Case No.: KNK 1200 - 1****Approval for the Route of Extra High Tension (EHT) Power Line / Telecommunication Line**

**Approval** of the Central Level Power & Telecommunication Co-ordination Committee is hereby conveyed for **33KV Feeder No. 320 through SPR HT RMU Board 1 to Solar Block No. 1 and Solar Block No. 1 to Solar Block No. 2, Partially laid underground (Length: - 2.73 kms) and partially Overhead on D/c line (Length: - 6.59 kms) on Eco Panther Conductor for 53MW Solar Power Plant of M/s. Serentica Renewables India 6 Private Limited to 220/33 KV PSS of Serentica Renewables India 3 Private Limited at Village Balagod, Gadag. (Total Length: - 9.32 kms)**, particulars of which are given in Annexure I.

The approval is for the route only and is subject to the following conditions.

1. The approval is based on the Power system/ Telecom system conditions' details as reported by the Power supply authority/ Telecom authority at present. Any changes either to Transmission line or the Power system or the paralleling telecommunication lines which are likely to alter the low frequency induction from the estimated at present should be reported to PTCC for its prior approval.
2. The Power and Telecommunication authorities shall be required to adopt such measures as may be recommended by PTCC for counteracting any interference that might arise when the EHT line is in normal operation.
3. Each crossing should satisfy the conditions as laid down in Para 6 -10 of PTCC Code of Practice for crossings.
4. The angle of crossing shall be 90 degrees but in no case less than 60 degrees.
5. The power line shall be equipped with protective switchgear such that the duration of earth current shall be as short as possible but never exceeding 0.5 seconds.
6. The power line shall be energized within a mutually acceptable time limit after obtaining a Certificate from the concerned Telecom and/or Railway authority regarding completion of provision of all protective measures as recommended by PTCC and also under specific clearance from the Telecom and/or Railway authority maintaining the Telecom system.
7. The energization of Extra High Tension power lines would not be held up for want of installation of GD tubes on telecom lines when the induced voltages are in the range of 430 to 650 V.
8. The telecom line shall be commissioned within a mutually acceptable time after completing provision of all protective measures as recommended by PTCC and also after obtaining specific clearance from the Power authority, if certain measures as recommended by PTCC are to be carried out on power system.
9. The later entrant in the field shall bear the entire cost of providing GD tubes and their fitting as recommended by PTCC, including 15% spares and/or any other protective measures as recommended by PTCC.
10. The route approval shall be subject to special conditions as laid down under Annexure II.

**Annexure I**

1

- (a) Name of the Power Supply authority seeking approval M/s Serentica Renewables India 6 Private Limited
- (b) Reference number & date: Serentica/PTCC/33kVDC/25-26/01 dated 20.09.2025
- (c) Name of the Power line 33KV Feeder No. 320 through SPR HT RMU Board 1 to Solar Block No. 1 and Solar Block No. 1 to Solar Block No. 2, Partially laid underground (Length: - 2.73 kms) and partially Overhead on D/c line (Length: - 6.59 kms) on Eco Panther Conductor for 53MW Solar Power Plant of M/s. Serentica Renewables India 6 Private Limited to 220/33 KV PSS of Serentica Renewables India 3 Private Limited at Village Balagod, Gadag. (Total Length: - 9.32 kms).
- (d) Length of Power line: 9.32 kms
- (e) Operating Voltage 33 kV
- (f) Number of circuits S/C

2

- (a) Names of parallel telecom lines: As per Annexure-II
- (b) Length of parallelism: As per Annexure-II
- 3 Average value of earth resistivity in the region: 20000 ohm-cms
- 4 Whether LF test necessary: No
- 5 Special conditions subject to which this certificate will be effective As per Annexure-II

## Annexure II

**Name of the Power Line:** 33KV Feeder No. 320 through SPR HT RMU Board 1 to Solar Block No. 1 and Solar Block No. 1 to Solar Block No. 2, Partially laid underground (Length: - 2.73 kms) and partially Overhead on D/c line (Length: - 6.59 kms) on Eco Panther Conductor for 53MW Solar Power Plant of M/s. Serentica Renewables India 6 Private Limited to 220/33 KV PSS of Serentica Renewables India 3 Private Limited at Village Balagod, Gadag. (Total Length: - 9.32 kms).

### 1. BSNL Telecom Details:

DET (PTCC), Southern Region, Bangalore vide Letter No: SR-PTCCIKNK-1200/5 dated 23.12.2025 has given NOC for charging of the line.

### 2. Railway Telecom Details:

PCSTE, SOUTH WESTERN RAILWAY vide letter SG/SWR/PTCC/Corres/E: 2-12 dated 23.12.2025 has given NOC for charging of the line.

### 3. Defense Telecom Details:

ADG(Telecom) , Ministry of Defence vide letter B/46937/Sigs-7(b)/5144 dated 18.12.2025 has accorded NOC for charging of the line.

4. EPR zone for the proposed substation is mentioned below:

Name of the proposed Substation	Half diagonal distance, D/2 (mts)	Fault Current I (KA)	Resistance of Earth Mat, R (ohms)	d (mts) at 430 V	d (mts) at 650 V	d (mts) at 7kV	d (mts) at 10kV
ICR BLock	40.31	25	0.5	1131	735	32	10

Telecom authorities to ensure the protection of telecom equipment and personnel within the EPR zone of the proposed substation at the cost of the later entrant.

**CEA Case No.: KNK 1200 - 2****Approval for the Route of Extra High Tension (EHT) Power Line / Telecommunication Line**

**Approval** of the Central Level Power & Telecommunication Co-ordination Committee is hereby conveyed for **33KV Feeder No. 321 through SPR HT RMU Board 2 to Solar Block No. 3 and Solar Block No. 3 to Solar Block No. 4 Partially laid underground (Length: - 1.44 kms) and partially Overhead on D/c line (Length: - 6.59 kms) on Eco Panther Conductor for 53MW Solar Power Plant of M/s. Serentica Renewables India 6 Private Limited to 220/33 KV PSS of Serentica Renewables India 3 Private Limited at Village Balagod, Gadag. (Total Length: - 8.03 kms)** particulars of which are given in Annexure III.

The approval is for the route only and is subject to the following conditions.

1. The approval is based on the Power system/ Telecom system conditions' details as reported by the Power supply authority/ Telecom authority at present. Any changes either to Transmission line or the Power system or the paralleling telecommunication lines which are likely to alter the low frequency induction from the estimated at present should be reported to PTCC for its prior approval.
2. The Power and Telecommunication authorities shall be required to adopt such measures as may be recommended by PTCC for counteracting any interference that might arise when the EHT line is in normal operation.
3. Each crossing should satisfy the conditions as laid down in Para 6 -10 of PTCC Code of Practice for crossings.
4. The angle of crossing shall be 90 degrees but in no case less than 60 degrees.
5. The power line shall be equipped with protective switchgear such that the duration of earth current shall be as short as possible but never exceeding 0.5 seconds.
6. The power line shall be energized within a mutually acceptable time limit after obtaining a Certificate from the concerned Telecom and/or Railway authority regarding completion of provision of all protective measures as recommended by PTCC and also under specific clearance from the Telecom and/or Railway authority maintaining the Telecom system.
7. The energization of Extra High Tension power lines would not be held up for want of installation of GD tubes on telecom lines when the induced voltages are in the range of 430 to 650 V.
8. The telecom line shall be commissioned within a mutually acceptable time after completing provision of all protective measures as recommended by PTCC and also after obtaining specific clearance from the Power authority, if certain measures as recommended by PTCC are to be carried out on power system.
9. The later entrant in the field shall bear the entire cost of providing GD tubes and their fitting as recommended by PTCC, including 15% spares and/or any other protective measures as recommended by PTCC.
10. The route approval shall be subject to special conditions as laid down under Annexure IV.

**Annexure III**

1

- (a) Name of the Power Supply authority seeking approval M/s Serentica Renewables India 6 Private Limited
- (b) Reference number & date: Serentica/PTCC/33kVDC/25-26/01 dated 20.09.2025
- (c) Name of the Power line 33KV Feeder No. 321 through SPR HT RMU Board 2 to Solar Block No. 3 and Solar Block No. 3 to Solar Block No. 4 Partially laid underground (Length: - 1.44 kms) and partially Overhead on D/c line (Length: - 6.59 kms) on Eco Panther Conductor for 53MW Solar Power Plant of M/s. Serentica Renewables India 6 Private Limited to 220/33 KV PSS of Serentica Renewables India 3 Private Limited at Village Balagod, Gadag. (Total Length: - 8.03 kms)
- (d) Length of Power line: 8.03 kms
- (e) Operating Voltage 33 kV
- (f) Number of circuits S/C

2

- (a) Names of parallel telecom lines: As per Annexure-IV
- (b) Length of parallelism: As per Annexure-IV
- 3 Average value of earth resistivity in the region: 20000 ohm-cms
- 4 Whether LF test necessary: No
- 5 Special conditions subject to which this certificate will be effective As per Annexure-IV

## Annexure IV

**Name of the Power Line:** 33KV Feeder No. 321 through SPR HT RMU Board 2 to Solar Block No. 3 and Solar Block No. 3 to Solar Block No. 4 Partially laid underground (Length: - 1.44 kms) and partially Overhead on D/c line (Length: - 6.59 kms) on Eco Panther Conductor for 53MW Solar Power Plant of M/s. Serentica Renewables India 6 Private Limited to 220/33 KV PSS of Serentica Renewables India 3 Private Limited at Village Balagod, Gadag. (Total Length: - 8.03 kms)

### 1. BSNL Telecom Details:

DET (PTCC), Southern Region, Bangalore vide Letter No: SR-PTCCIKNK-1200/5 dated 23.12.2025 has given NOC for charging of the line.

### 2. Railway Telecom Details:

PCSTE, SOUTH WESTERN RAILWAY vide letter SG/SWR/PTCC/Corres/E: 2-12 dated 23.12.2025 has given NOC for charging of the line.

### 3. Defense Telecom Details:

ADG(Telecom) , Ministry of Defence vide letter B/46937/Sigs-7(b)/5144 dated 18.12.2025 has accorded NOC for charging of the line.

4. EPR zone for the proposed substation is mentioned below:

Name of the proposed Substation	Half diagonal distance, D/2 (mts)	Fault Current I (KA)	Resistance of Earth Mat, R (ohms)	d (mts) at 430 V	d (mts) at 650 V	d (mts) at 7kV	d (mts) at 10kV
ICR BLock	40.31	25	0.5	1131	735	32	10

Telecom authorities to ensure the protection of telecom equipment and personnel within the EPR zone of the proposed substation at the cost of the later entrant.