



**Report on
Resource Adequacy Plan
(Generation) for
Arunachal Pradesh
(2025-26 to 2035-36)
(Version 2.0)**

January, 2026

**Government of India
Ministry of Power
Central Electricity Authority**

Contents

Disclaimer.....	i
Executive Summary.....	ii
1.0 Introduction	1
2.0 Highlights of the Previous RA Study (Up to FY 2031–32).....	2
3.0 RA Study for Arunachal Pradesh (from 2025-26 to 2035-36).....	3
3.1 Present Power Scenario in Arunachal Pradesh.....	3
3.2 Demand Analysis of the FY 2024-25	4
4.0 Principles of Generation Planning	6
4.1 Generation Expansion Planning Tool -ORDENA.....	6
5.0 Reliability Analysis.....	7
5.1 Variation in electricity demand.....	8
5.2 Variation in RE.....	8
5.3 Forced outage of Thermal Generators	9
6.0 Inputs/Assumptions for the Study	9
7.0 Outcome of the Study.....	12
8.0 Conclusions	16

Disclaimer

This Resource Adequacy Study for the state of Arunachal Pradesh has been conducted based on data and inputs provided by Arunachal Pradesh. The findings, analysis and conclusions presented in this report are contingent upon the accuracy, completeness and timeliness of the information furnished by Arunachal Pradesh. Any discrepancies or limitations in the data may affect the outcomes of the study accordingly.

In accordance with the Resource Adequacy Guidelines dated 28th June 2023, each Distribution Licensee is mandated to prepare a Resource Adequacy Plan (RAP) for a 10-year horizon, referred to as Long-Term Distribution Licensee Resource Adequacy Plan (LT-DRAP), which shall be vetted and validated by Central Electricity Authority (CEA). CEA has facilitated this study and prepared the report solely to assist Arunachal Pradesh in fulfilling this requirement.

It is expressly stated that the responsibility for the implementation of the study's recommendations, ensuring the adequacy of electricity resources, and undertaking any related actions including financial implications, if any, rests entirely with the State.

Executive Summary

Ministry of Power had notified the Electricity (Amendment) Rules in December, 2022. As per Rule 16 of the Electricity (Amendment) Rules, Ministry of Power has notified Resource Adequacy (RA) Guidelines. According to these Guidelines, Central Electricity Authority (CEA) is entrusted with the responsibility of preparing the Long-Term National Resource Adequacy Plan (LT-NRAP). Further, each Distribution Utility is required to carry out a Long-Term Distribution Licensee Resource Adequacy Plan (LT-DRAP) to reliably meet its peak electricity demand and electrical energy requirements.

As per the Resource Adequacy Guidelines dated 28th June 2023, each Distribution Licensee shall undertake a Resource Adequacy Plan (RAP) with a 10-year planning horizon, LT-DRAP, to meet its own peak and electrical energy requirements. This plan shall be vetted/validated by CEA to leverage the benefits of national-level optimization for the Distribution Licensees. The LT-DRAP shall be prepared by the Distribution Licensees on an annual rolling basis, factoring in the already contracted capacity and optimizing the requirement for additional capacity.

Government of India has notified the Renewable Purchase Obligation (RPO) trajectory up to 2029-30 vide gazette notification dated 20th October 2023, which mandates that a specified portion of energy consumption must be met from renewable energy sources.

To support the state in fulfilling this requirement, CEA, initially carried a Resource Adequacy (RA) study with a planning horizon up to FY 2031-32, based on the data available with CEA and NERPC and in compliance with the RPO trajectory specified in the then Ministry of Power's Office Memorandum dated 22nd July 2022. This study has now been updated and extended to cover the period upto FY 2035-36, incorporating the latest data furnished by the State and planning assumptions. The RPO requirement for the state has also been assessed in accordance with the order dated 20th October, 2023.

The electrical energy requirement and peak electricity demand for Arunachal Pradesh, as furnished by Arunachal Pradesh, are projected to increase with a CAGR of 7.9% and 9.7% respectively from 2025-26 to 2035-36. However, as per mid-term review of 20th EPS projections, the electricity energy requirement and peak electricity demand for Arunachal Pradesh is projected to increase with a CAGR of 4.6% and 3.6% respectively from 2025-26 to 2035-36. For satisfying resource adequacy i.e., meeting the electricity demand reliably and at affordable cost, the state needs to methodically plan its capacity expansion either by investing in new generation or by procuring power. In view of the reduction in cost of solar panels and Energy storage systems, planning for long term optimal generation capacity mix gains tremendous importance so as the future generation capacity mix is cost effective as well as environment friendly.

The study for Arunachal Pradesh, based on existing contracted capacity and planned capacity additions, indicates that the available capacity is sufficient to meet the projected electricity demand.

To find out the least cost option for generation capacity expansion for the period 2025-26 to 2035-36, generation expansion study has been carried out with an objective to minimize the total system cost of generation while fulfilling all the technical constraints associated with various power generation technologies. Additionally, reliability study has been carried out to determine the probability of unmet demand and hours by implementing the variation in demand, RE and forced outage of thermal generators (Coal/ Lignite) etc.

Generation capacity expansion pathways have been considered for the long-term study based on the yearly capacity addition plan of Arunachal Pradesh along with RPO constraints for solar and DRE technologies. The Renewable capacities have been assessed in view of adherence to RPO notified by order of Ministry of Power dated 20th October,2023, considering the fungibility among different sources.

The Resource adequacy studies have projected likely optimal capacity mix for future years till 2035-36 which shall be able to meet anticipated demand reliably at every instance. Based on the study, the likely total projected contracted capacity for the year 2035-36 is around 1,122 MW which consists of 45 MW from coal; 48 MW from gas; 994 MW from hydro; 3 MW from solar; 32 MW from Distributed Renewable Energy (DRE) source. This capacity shall be able to meet the projected electricity demand with prescribed reliability criteria.

1.0 Introduction

Ministry of Power has notified the Electricity (Amendment) Rules 2022, in December 2022. Rule 16 (I) of the said rules stipulates that *“A guideline for assessment of resource adequacy during the generation planning stage (one year or beyond) as well as during the operational planning stage (up to one year) shall be issued by the Central Government in consultation with the Authority”*. Accordingly, the Resource Adequacy Guidelines have been notified in June, 2023, by Ministry of Power in consultation with Central Electricity Authority.

Resource Adequacy is generally defined as a mechanism to ensure that there is an adequate supply of generation resources to serve expected demand reliably at least cost. A key aspect of resource adequacy planning is to ensure that adequate generation capacities are available round-the-clock to reliably serve demand, under various scenarios. This naturally translates into the need for ensuring adequate reserve margin which could cater to varying levels of demand and supply conditions in the grid. In the wake of high RE generation, it is important to understand demand-supply situation in the grid precisely due to high seasonality and intermittency in RE generation. Resource Adequacy exercise may also help in assessment of capacity requirement to be tied up or contracted on long term, medium term, and short-term basis.

Further, Ministry of Power vide notification dated 20th October, 2023, had notified the RPO trajectory for the states/Discoms. Based on the trajectory specified, hydro, wind and other (solar, biomass etc.) RPO quantum in million units (MUs) has been calculated to find additional quantum of renewable capacity that the states/Discoms have to contract in addition to the existing/planned capacity to meet their RPO targets.

To support the state in fulfilling the Resource Adequacy Guidelines and complying with the Renewable Purchase Obligation (RPO) notification, CEA has carried out the RA study for the state of Arunachal Pradesh based on inputs furnished by Arunachal Pradesh. The study recommends an optimal resource mix up to FY 2035-36, taking into account technical and financial parameters associated with various generation technologies. It aims to optimize long-term power procurement while ensuring resource adequacy to meet demand on a 24x7 basis, considering variations in demand, variations in RE generation, and forced outage of thermal capacities. The study also assesses the Planning Reserve Margin (PRM) required by the state to account for the aforementioned uncertainties, ensuring that demand can be reliably met throughout the year.

Prior to this, CEA had conducted the RA study for the state up to FY 2031-32, based on data available with CEA and in accordance with the then RPO trajectory specified in the Ministry of Power's Office Memorandum dated 22nd July 2022.

2.0 Highlights of the Previous RA Study (Up to FY 2031–32)

1. In the earlier Resource Adequacy (RA) study, financial year 2022-23 had been considered as the base year, and the study covered the period from 2023-24 to 2031-32. The fuel-wise contracted capacity by Arunachal Pradesh as on 31st March, 2023, is given in Fig. 1.




Figure 1: Fuel-wise Contracted Capacity (in MW) as on 31st March, 2023

2. The peak electricity demand and electrical energy projections as per the 20th EPS report that has been considered in the study is given in Table 1.

Table 1: Peak electricity demand and electrical energy projections as per the 20th EPS

	2023-24	2024-25	2025-26	2026-27	2027-28	2028-29	2029-30	2030-31	2031-32
Electrical Energy Projections (MU)	964	1012	1064	1117	1170	1227	1289	1347	1397
Y-o-Y Growth		4.98%	5.14%	4.98%	4.74%	4.87%	5.05%	4.50%	3.71%
Peak Electricity Demand Projections (MW)	190	201	211	223	234	246	259	271	282
Y-o-Y Growth		5.79%	4.98%	5.69%	4.93%	5.13%	5.28%	4.63%	4.06%

3. To meet the above projected peak electricity demand and electrical energy requirement reliably, the source-wise projected capacity (in MW) as outlined in the previous report is given in Table 2.

Table 2: Source-wise projected capacities

Year	Coal	Gas	Hydro	Solar	SToA/MToA*	Total
2023-24	45	47	227	6	18	343
2024-25	45	47	904	6	0	1002
2025-26	45	47	904	6	0	1002

2026-27	45	47	904	6	0	1002
2027-28	45	47	904	6	0	1002
2028-29	45	47	904	6	0	1002
2029-30	45	47	904	6	0	1002
2030-31	45	47	904	6	0	1002
2031-32	45	47	904	6	0	1002

*The SToA/MToA value represents the peak power requirement in MW and it was recommended that this requirement may be met through power procurement from the market or through bilateral agreements.

4. The year-wise planned and additional capacity contract addition (in MW) for the above tabulated cumulative capacity is given in Table 3.

Table 3: Year-wise planned and additional capacity contract addition

FY	Hydro		Total		SToA/MToA*
	Planned	Additional	Planned	Additional	Additional
2023-24	83	0	83	0	18
2024-25	677	0	677	0	0
2025-26	0	0	0	0	0
2026-27	0	0	0	0	0
2027-28	0	0	0	0	0
2028-29	0	0	0	0	0
2029-30	0	0	0	0	0
2030-31	0	0	0	0	0
2031-32	0	0	0	0	0
Total	760	0	760	0	18

*Requirement is for a particular year

3.0 RA Study for Arunachal Pradesh (from 2025-26 to 2035-36)

3.1 Present Power Scenario in Arunachal Pradesh

The power supply position for Arunachal Pradesh from 2022-23 to 2024-25 is given in Table 4.

Table 4: Power Supply Position of Arunachal Pradesh

Power Supply Position						
Year	Energy required (MU)	Energy supplied (MU)	Gap (MU)	Peak Demand (MW)	Peak Met (MW)	Demand not met (MW)
2021-22	875	874	1	197	168	29
2022-23	915	892	23	167	167	0
2023-24	1014	1014	0	186	186	0
2024-25	1050	1050	0	218	191	27

The data in Table 4 indicates that over the past four years, Arunachal Pradesh's electrical energy demand and peak electricity demand have increased at a Compound Annual Growth Rate (CAGR) of 6.26% and 3.34% respectively.

As of March 2025, the total contracted capacity for Arunachal Pradesh is 414 MW. Out of the total contracted capacity (CC), the share of non-fossil fuel-based CC is 78 %. The fuel-wise contracted capacity as on 31st March, 2025 is given in Table 5 and Fig. 2.

Table 5: Fuel-wise Contracted Capacity as on March 2025

Source	Contracted Capacity (MW)	%
Coal	45	11
Gas	48	11
Hydro	318	77
SOLAR	3	1
Total	414	100




Figure 2: Fuel-wise Contracted Capacity (in MW) as on 31st March, 2025

3.2 Demand Analysis of the FY 2024-25

Hourly demand pattern of 2024-25 was analyzed and it was observed that the peak demand season for State of Arunachal Pradesh is typically during the months from December to February. Arunachal Pradesh witnesses peak demand during non-solar hours. The month wise average hourly demand observed for the year 2024-25 is shown in Fig. 3.




Figure 3: Average Hourly Demand Variation (Month-wise) for 2024-25

From the hourly demand data of 2024-25 the daily peak during solar hours and non-solar hours are plotted in Fig. 4. Daily peak occurs in Arunachal Pradesh during non-solar hours in almost every month of the year.




Figure 4: Solar and non-solar peak in MW for the year 2024-25

The hourly demand pattern of 2024-25 was analysed for finding out the number of occurrences of the peak and near peak demand. Such instances are critical for study purpose as it is necessary to ensure resource adequacy during such instances with an optimal mix of long-term, medium-term and short-term contracts. Frequency Distribution of hourly demand profile for 2024-25 is shown in Fig. 5.




Figure 5: Frequency Distribution of Hourly Demand Profile of 2024-25

4.0 Principles of Generation Planning

The objective of the Generation Planning process is to obtain an optimal generation capacity mix in the least cost manner to meet the electricity demand at every instance of time while ensuring the most efficient use of resources.

The major aspects considered in the planning process are:

- i) To Supply 24x7 reliable power to the consumers
- ii) To achieve objectives of all policies of the Government of India such as RPO trajectory, RE capacity addition
- iii) To achieve sustainable development.
- iv) To fulfil desired operational characteristics of the system such as reliability and flexibility.
- v) Most efficient use of resources.
- vi) Fuel availability

4.1 Generation Expansion Planning Tool -ORDENA

The studies have been carried out using a generation expansion planning model namely ORDENA. ORDENA is a mixed integer linear optimization program that minimizes the Net Present Value (NPV) of investment and operating costs subject to several constraints. The major constraints include balancing electricity supply and demand, resource supply limits, planning and operating reserve limits, and policy targets. These constraints are met considering a broad portfolio of conventional generation, renewable generation, and storage.

ORDENA has a reliability module to determine the trustworthiness of the system using Monte Carlo simulations. The software is also capable of carrying out hourly/sub-hourly economic

generation dispatch considering all the technical constraints associated with various generation technologies.

The schematic diagram of the software is given in Fig. 6.




Figure 6: Schematic Diagram

5.0 Reliability Analysis

One of the main criteria of resource adequacy studies is to determine the reliability of the system to meet the demand adequately at every instance of time. This reliability is measured via two indices i.e. LOLP (Loss of Load Probability) and EENS (Expected Energy Not Served). These indices have been defined in resource adequacy guidelines as below:

- **Loss of Load Probability (LOLP):** Measure of the probability that a system's load may exceed the generation and firm power contracts available to meet that load in a year. E.g., 0.0274 % probability of load being lost.
- **Expected Energy Not Served (EENS):** Expected amount of energy (MWh) that may not be served for each year within the planning period under study. It is a summation of the expected number of megawatt hours of demand that may not be served for the year. This is an energy-centric metric that considers the magnitude and duration of energy being not served, calculated in Mega Watt hours (MWh). The metric can be normalized (i.e., divided by the total system electrical energy requirement) to create a Normalized Energy Not Served (NENS) metric.

Monte Carlo /Stochastic simulation has been used to factor-in the uncertainty associated with various generation resources and demand. It is an approach which is used to predict the probability of a variety of outcomes when the potential for random variables is present, as compared to deterministic modelling of economic dispatch model. Monte Carlo simulation helps in analysing the randomness associated with RE energy resource, demand pattern changes and forced outages of plant. A large no. of random samples of these variables is simultaneously simulated to ascertain system reliability indices (i.e. Loss of load probability

LOLP & Energy Not Served (ENS)) and the system robustness in case of above variation of system parameters.

Planning Reserve Margin (PRM): To meet the prescribed standard of LOLP / NENS conditions, sufficient reserve margins need to be maintained in the system for adequately addressing the demand and supply variations. Planning Reserve Margin (PRM) is the predominant metric used to ensure adequacy of generation resources in the system. PRM in a power system is generally expressed as a certain percent of the projected peak electricity demand.

5.1 Variation in electricity demand

The variation in electricity demand pattern for last two years viz. 2023-24 and 2024-25 (with 2023-24 as base year) has been analyzed. The demand pattern variation across 2023-24 and 2024-25 is shown in Fig. 7.




Figure 7: Hourly Variation in Electricity Demand across years

It can be observed that the hourly demand typically varies within $\pm 10\%$ for 57.56% of instances. This variation is primarily due to temperature, weather parameter or any random outages of transmission line and generating units etc. This variation has been captured in the reliability study by incorporating a variation of $\pm 10\%$ in the projected hourly demand for the future years by introducing a random variable (with normal distribution) for demand as per observed behavior over the years.

5.2 Variation in RE

In the Long-term capacity expansion planning studies, a particular profile for Solar generation is considered based on the observed solar generation data to determine the optimal capacity mix. However, due to intermittent nature of these sources, generation from these non-dispatchable sources may vary across years. As per the analyses carried out based on historical generation

data, solar and hydro based generation has been varied by $\pm 10\%$ to incorporate the variation in these generation sources and plan for requisite measures to mitigate such behavior.

5.3 Forced outage of Thermal Generators

The average forced outage rate of thermal generators is typically 10% with $\pm 5\%$ variation. The same has been incorporated in the model.

Based on these variations, reliability studies have been carried out to ascertain robustness of the system.

6.0 Inputs/Assumptions for the Study

- i) The peak electricity demand and electrical energy requirement for Arunachal Pradesh as per the mid-term review of 20th EPS is given in Table 6.

Table 6: Demand Projections as per the mid-term review of 20th EPS

FY	Peak Electricity Demand Projections (MW)	Y-o-Y Growth	Electrical Energy Requirement Projections (MU)	Y-o-Y Growth
2025-26	206		1118	
2026-27	217	5.34%	1178	5.32%
2027-28	226	4.18%	1242	5.44%
2028-29	236	4.18%	1309	5.43%
2029-30	245	4.02%	1378	5.25%
2030-31	253	3.03%	1436	4.23%
2031-32	259	2.69%	1492	3.87%
2032-33	268	3.38%	1560	4.56%
2033-34	277	3.29%	1630	4.46%
2034-35	286	3.20%	1701	4.36%
2035-36	295	3.10%	1753	3.10%

- ii) Future demand profile till the year 2035-36 has been projected using the demand profile for the year 2024-25 as the base profile.
- iii) The actual solar and hydro generation profiles and CUFs have been considered as per data available in CEA.
- iv) The planned capacity has been considered based on the tie-up information as furnished by Arunachal Pradesh. The same is summarised in Table 7 and details are furnished in Annexure.

Table 7: Source wise planned capacity addition

FY	Hydro (MW) (Conventional/Small)
2025-26	0
2026-27	609
2027-28	14
2028-29	53
Total	676

- v) **Renewable Purchase Obligation (RPO) trajectory:** Ministry of Power gazette notification dated 20th October, 2023 had notified the source wise minimum share of consumption of non-fossil sources (renewable energy) by designated consumers, till the year 2029-30 as given in Table 8.

Table 8: Renewable Purchase Obligation (RPO) trajectory (%) as per MoP order

Sl. No.	Year	Wind renewable energy	Hydro renewable energy	Other renewable energy	Distributed renewable energy	Total renewable energy
(1)	(2)	(3)	(4)	(5)	(6)	(7)
1.	2024-25	0.67	0.38	27.35	1.5	29.91
2.	2025-26	1.45	1.22	28.24	2.1	33.01
3.	2026-27	1.97	1.34	29.94	2.7	35.95
4.	2027-28	2.45	1.42	31.64	3.3	38.81
5.	2028-29	2.95	1.42	33.1	3.9	41.36
6.	2029-30	3.48	1.33	34.02	4.5	43.33

Further, in view of the country's energy transition goals as well as the long-term net zero target of 2070, it is estimated that the share of RE generation in the generation mix will continue to proportionally increase beyond 2029-30. Therefore, the RPO trajectory is assumed to rise steadily beyond 2029-30. However, the DRE percentage has been assumed to be constant from 2029-30 onwards. Further, being a hilly state, the DRE percentage for Arunachal Pradesh has been taken as half of the percentage what other states are obliged to meet. Hence, the suggested trajectory of Renewable Purchase Requirement up to 2035-36 is given in Table 9.

Table 9: Renewable Purchase Obligation (RPO) trajectory (%) considered for the study

Sl. No.	Year	Wind renewable energy	Hydro renewable energy	Other renewable energy	Distributed renewable energy*	Total renewable energy
(1)	(2)	(3)	(4)	(5)	(6)	(7)
1.	2024-25	0.67	0.38	28.10	0.75	29.91
2.	2025-26	1.45	1.22	29.29	1.05	33.01
3.	2026-27	1.97	1.34	31.29	1.35	35.95
4.	2027-28	2.45	1.42	33.29	1.65	38.81
5.	2028-29	2.95	1.42	35.05	1.95	41.36
6.	2029-30	3.48	1.33	36.27	2.25	43.33
7.	2030-31	43.25			2.25	45.5
8.	2031-32	44.75			2.25	47
9.	2032-33	46.05			2.25	48.3
10.	2033-34	47.25			2.25	49.5
11.	2034-35	48.75			2.25	51.0
12.	2035-36	49.75			2.25	52.0

* For Hilly states, DRE Percentage is half of the percentage what other states are obliged to meet.

Based on the trajectory specified, RPO quantum in million units (MUs) from hydro, wind, other (Solar, biomass etc.) and distributed renewable energy (DRE) is calculated and given in Table 10.

Table 10: Total Energy required to meet RPO (MU)

Sl. No.	Year	Wind renewable energy	Hydro renewable energy	Other renewable energy	Distributed renewable energy	Total renewable energy
(1)	(2)	(3)	(4)	(5)	(6)	(7)
1.	2025-26	16.21	13.64	327.53	11.74	369.13
2.	2026-27	23.20	15.78	368.52	15.90	423.41
3.	2027-28	30.43	17.63	413.41	20.49	481.96
4.	2028-29	38.62	18.59	458.91	25.53	541.52
5.	2029-30	47.96	18.33	499.82	31.01	597.11
6.	2030-31	621.25			32.32	653.56
7.	2031-32	667.70			33.57	701.27
8.	2032-33	718.43			35.10	753.53
9.	2033-34	770.02			36.67	806.69
10.	2034-35	829.08			38.27	867.35
11.	2035-36	872.29			39.45	911.74

As indicated in Table 11, the state with its existing and envisaged future capacity additions will be able to meet its RPO requirements from RE sources other than DRE, however state will not be able to fulfill its DRE requirement as indicated in Table 12 from the year 2025-26 onwards.

Table 11: Renewable Energy Surplus/Deficit other than DRE

FY	RE Generation required to meet RPO		RE Generation available/met (From existing/ planned contracts)		RPO Surplus (+)/ Deficit (-)
	(MU)	(%)	(MU)	(%)	(%)
2025-26	357.39	31.96%	948.80	85%	52.89%
2026-27	407.51	34.60%	1162.60	99%	64.11%
2027-28	461.47	37.16%	1221.81	98%	61.23%
2028-29	515.99	39.41%	1283.72	98%	58.64%
2029-30	566.10	41.08%	1347.66	98%	56.71%
2030-31	621.25	43.25%	1398.78	97%	54.13%
2031-32	667.70	44.75%	1442.53	97%	51.93%
2032-33	718.43	46.05%	1497.01	96%	49.90%
2033-34	770.02	47.25%	1551.45	95%	47.95%
2034-35	829.08	48.75%	1607.85	95%	45.79%
2035-36	872.29	49.75%	1661.67	95%	45.02%

Table 12: Renewable Energy from DRE

FY	DRE required to meet RPO		DRE available/met (From existing/ planned contracts)		RPO Surplus (+)/ Deficit (-)
	(MU)	(%)	(MU)	(%)	(%)
2025-26	11.74	1.05%	0.00	0.0%	-1.05%
2026-27	15.90	1.35%	0.00	0.0%	-1.35%
2027-28	20.49	1.65%	0.00	0.0%	-1.65%
2028-29	25.53	1.95%	0.00	0.0%	-1.95%
2029-30	31.01	2.25%	0.00	0.0%	-2.25%
2030-31	32.32	2.25%	0.00	0.0%	-2.25%
2031-32	33.57	2.25%	0.00	0.0%	-2.25%
2032-33	35.10	2.25%	0.00	0.0%	-2.25%
2033-34	36.67	2.25%	0.00	0.0%	-2.25%
2034-35	38.27	2.25%	0.00	0.0%	-2.25%
2035-36	39.45	2.25%	0.00	0.0%	-2.25%

7.0 Outcome of the Study

To meet the projected electricity demand while fulfilling the RPO requirement, the capacity projections for Arunachal Pradesh are given in Table 13.

Table 13: Year-wise contracted capacity projections (in MW)

Year	Coal	Gas	Hydro	Solar	DRE
2025-26	45	48	318	3	10
2026-27	45	48	912	3	13
2027-28	45	48	941	3	17
2028-29	45	48	994	3	21
2029-30	45	48	994	3	25
2030-31	45	48	994	3	26
2031-32	45	48	994	3	27
2032-33	45	48	994	3	29
2033-34	45	48	994	3	30
2034-35	45	48	994	3	31
2035-36	45	48	994	3	32

The projected year-wise contracted capacity mix is given in Figure 8.




Figure 8: Projected Contracted Capacity Mix Year-wise (MW)

Reliability studies have been conducted based on the projected capacity for the year 2035-36. The analysis confirms that the projected capacity meets the reliability criteria specified in the National Electricity Plan (NEP), with the Loss of Load Probability (LoLP) and Not-Served Energy (NENS) remaining within the permissible limits of 0.2% and 0.05%, respectively [as specified in the National Electricity Plan (Generation)].

As per the studies, the likely total projected contracted capacity for the year 2035-36 is around 1,122 MW which consists of 45 MW from coal; 48 MW from Gas; 994 MW from hydro; 3 MW from solar and 32 MW from Distributed Renewable Energy (DRE) source. This capacity shall be able to meet the projected demand with prescribed reliability criteria and to comply with the stipulated Renewable Purchase Obligation (RPO) targets. The planning reserve margin for the state has been assessed as 4%. Capacity mix required by 2035-36 is shown in Figure 9.




Figure 9: Contracted Capacity Mix in 2035-36

It is important to note that any deviations in the commissioning schedule of the planned capacity could result in a situation where the state is unable to meet the projected peak electricity demand and electrical energy requirements identified in this study with the available resources. Such changes may also lead to an increase in the cost of meeting the state’s power demand reliably.

As per the study, the state likely needs to contract the following capacities (planned and additional) every year till 2035-36 to meet its demand reliably as shown in Table 14.

Table 14: Year wise Capacity Addition (in MW)

FY	Hydro	DRE	TOTAL	
	Planned	Additional	Planned	Additional
2025-26	0	10	0	10
2026-27	594	3	594	3
2027-28	30	4	30	4
2028-29	53	4	53	4
2029-30	0	4	0	4
2030-31	0	1	0	1
2031-32	0	1	0	1

FY	Hydro	DRE	TOTAL	
	Planned	Additional	Planned	Additional
2032-33	0	2	0	2
2033-34	0	1	0	1
2034-35	0	1	0	1
2035-36	0	1	0 <td 1	
Total	677	32	677	32

The projected net generation mix for the state is shown in Figure 10 and 11.




Figure 10: Year-wise projected net generation mix (in %)




Figure 11: Year-wise projected net generation (in GWh)

8.0 Conclusions

Based on the Resource Adequacy studies of Arunachal Pradesh up to the year 2035-36, the following conclusions may be drawn:

1. The study has considered peak electricity demand and electrical energy requirement projections as per the projections of Mid-term review of 20th EPS, which envisages that the annual electrical energy requirement of the state is likely to grow at a CAGR of 4.6% while the peak electricity demand for the state is likely to grow at a CAGR of 3.6% for the period of 2025-26 to 2035-36. The projected peak electricity demand and electrical energy requirement in 2035-36 is 295 MW and 1,753 MU respectively. It has been observed that the peak electricity demand season is typically from December to February with peak demand occurring during non-solar hours.
2. Arunachal Pradesh with its existing and planned capacity is likely to witness no energy deficit in the years from 2025-26 to 2035-36.
3. Based on the study, the likely total projected contracted capacity for the year 2035-36 is around 1,122 MW which consists of 45 MW from coal; 48 MW from gas; 994 MW from

hydro; 3 MW from solar and 32 MW from Distributed Renewable Energy (DRE) source. This capacity shall be able to meet the projected electricity demand with prescribed reliability criteria and to comply with the stipulated Renewable Purchase Obligation (RPO) targets for the years 2025-26 to 2035-36. The resulting PRM for Arunachal Pradesh has been assessed to be 4%.

4. Though the state is likely to be surplus in terms of RE Capacity (tied up/planned), the state will not be able to meet the stipulated RPO requirement from DRE Sources and needs to contract additional DRE capacity of 32 MW by 2035-36.
5. Timely commissioning of planned capacities is critical to ensuring that the state meets its projected peak electricity demand and electrical energy requirements reliably. Any deviation from the planned schedule may lead to resource shortfalls and could significantly increase the cost of reliably meeting the state's power demand.

Planned Contracted (MW) considered in the study

Sl. No.	Tied capacity name	Type of generation	Likely COD	Arunachal Pradesh share (in MW)
1.	Subansiri Lower	Hydro	2026-27	594
2.	Yameng SHEP	Hydro	2027-28	15
3.	Pareng SHEP	Hydro	2027-28	14.5
4.	Ressing SHEP	Hydro	2028-29	12
5.	Dengzi SHEP	Hydro	2028-29	18
6.	Keyi SHEP	Hydro	2028-29	23

Assumption for Resource Adequacy Studies

1. Peak Electricity Demand and Electrical energy requirement: As per mid-term review of 20th EPS.
2. Demand Profile: Based on hourly demand profile of 2024-25.
3. Existing & Planned Capacity: As per the information shared by the state.
4. Cost parameters: based on information in National Electricity Plan.

RE CUF considered

Hydro	Solar	DRE
35 %	18%	14%

Technical Parameters

Technology	Type	Availability (%)	Ramping (%/min)	Min. Technical . (%)
Coal/ Lignite	Existing/Planned	85	1	55
	Candidate	88	1	55
Gas	Existing	90	5	40
Nuclear	Existing/Planned	68	Const. Load	-
Biomass	Existing/Planned	60	2	50
Hydro	Existing/Planned/ Candidate	As per available hourly generation profile	100	-
Solar	Existing/Planned		-	-
	Candidate		-	-
Wind	Existing/Planned		-	-
	Candidate	-	-	
Pumped Storage Plant	Existing/Planned	95	50	-
	Candidate		50	-
Battery Energy Storage System	Candidate	98	NA	-

Technology	Type	Heat Rate (MCal/MWh)		Aux. Consum. (%)	Min. online time (hr)	Min. offline time (hr)
		At max loading	At min loading			
Coal	Existing/Planned	2300 to 2879	2438 to 3052	7.0	6	4
	Candidate (SC & USC)	2060 to 2125	2183 to 2253	6.5	6	4
Gas	Existing	2000 to 2900	2260 to 3277	2.5	4	3
Nuclear	Existing/Planned	2777	2777	10	6	4
	Candidate	2777	2777	10	-	-
Biomass	Existing/Planned	4200	4450	8	6	4
	Candidate	4200	4450	8	6	4
Hydro	Existing/Planned	-	-	0.7	-	-
	Candidate	-	-	0.7	-	-
Pumped Storage	Existing/Planned	-	-	Round Trip efficiency 80 %	-	-
	Candidate	-	-		-	-
Battery Energy Storage System	Candidate	-	-	Round Trip efficiency 88%	-	-

Transmission Parameters

A single node has been considered for the purpose of study with all generating units and demand connected to the node. No transmission bottleneck has been considered for the study. Interstate ATC limit has not been considered in the study.