

I/14062/2021

Central Electricity Authority
 Technical Services Section
CORRIGENDUM No. 1
Dated 18.2.2021

Subject: E-TENDER ID 2021_CEA_615325_1 dated 05.02.2021

This has the reference of E- TENDER ID 2021_CEA_615325_1 which was earlier published on 09.02.2021 for Supply, installation, testing, and commissioning of new Ductable Inverter Type AC units (55 nos. x 8.5 TR) to be integrated with existing duct and dismantling the old Ductable AC (indoor and outdoor) for CEA offices situated at Sewa Bhawan, R.K. Puram, New Delhi:-110066. The following clauses of the tender documents has been amended as under:-

Sl. No.	Clause no.	Page No.	Existing Clause	To be read as
1	1.3.11	10	Rated Capacity: 8.5TR	Rated Capacity: 8.5±0.5 TR
2	1.3.11	10	Rated Cooling Capacity: 102000 Btu/hr or more 29.9kW or more	Rated Cooling Capacity: 102000±6000 Btu/hr or more 29.9±1.78kW or more
3	1.3.11	10	Compressor: High efficiency scroll type (inverter)	Compressor: High efficiency scroll/Rotary type (inverter)
4	7.6 Sl No. 4	37	Supply of copper refrigerant piping along with Insulation	Supply of Set of copper refrigerant piping (Liquid and Suction lines) along with Insulation
5	5.5	20	Period of contract: Two (2) calendar months commencing from the date of commencement specified in the letter of intent, awarding the contract.	Period of contract: Three (3) calendar months commencing from the date of commencement specified in the letter of intent, awarding the contract.