

CENTRAL ELECTRICITY AUTHORITY
POWER SYSTEM WING
Power System Project Monitoring Division

Sub-Stations (220 kV and above) Commissioned/Ready for commissioning During - June 2026

As on 30-June-2026

Sl No	Name of Sub Stations	Voltage Ratio (kV/kV)	Executing Agency	ISTS/Intra state	Capacity (MW/MVA)
1.	2.	3.	4.		6.
CENTRAL SECTOR					
1	1x500 MVA 400/220 kV ICT- 2nd at Jabalpur PS under Project: Western Region Expansion Scheme XXXIII Part A (WRES-XXXIII Part A)	400/220	PGCIL	ISTS	500
2	3x500 MVA, 400/220 kV ICT (5th, 6th and 7th) at Ananthpuram under Project: Transmission scheme for Solar Energy Zone in Ananthpuram (Ananthapur) (2500 MW) and Kurnool (1000 MW), Andhra Pradesh	400/220	PGCIL	ISTS	1500
3	1x500 MVA, 400/220 kV ICT (5th) at Fatehgarh III PS under Project: Augmentation of Transformation capacity at 400/220 kV fatehgarh III PS (Section-1) by 400/220 kV, 1x500 MVA ICT (5th)	400/220	PGCIL	ISTS	500
4	1x1500 MVA, 765/400 kV ICT (4th) at Padghe (PG) GIS under Project: Transmission System for Evacuation of power from Potential RE Zone in Khavda Area of Gujarat under phase IV (7GW)-Part E4	765/400	PGCIL	ISTS	1500
Total of CENTRAL SECTOR					4000
STATE SECTOR					
5	Chaygaon GIS (2x100 MVA)	220/33	AEGCL	Intra state	200
6	220/132 kV Dharmavaram SS	220/132	APTRANSCO	Intra state	100
7	220/132/33 kV Atchutapuram GIS	220/132	APTRANSCO	Intra state	100
8	400 kV GIS Thallayapalem (ICT 2)	400/220	APTRANSCO	Intra state	500
9	220/132/33 kV SS Undi (Aug.) (From 3x160 MVA to 4x160 MVA)	220/132	APTRANSCO	Intra state	160
10	220 kV Yerraguntla SS (Aug.) (160- 100 MVA)	220/132	APTRANSCO	Intra state	60
11	220/132 kV Bhilai SS (Aug.) (160-125 MVA)	220/132	CSPTCL	Intra state	35
12	220/132/33 kV S/s Kuthrel (Dharsiwa)(Aug.)(3rd 160 MVA)	220/132	CSPTCL	Intra state	160
13	Okhla SS (Aug.)	220/33/11	DTL	Intra state	100
14	220 kV Zaghadia SS (Aug.) (from 420 MVA to 470 MVA)	220/66	GETCO	Intra state	50
15	400 kV Bina S/s (Aug.)(Additional 315 MVA T/F)	400/220	MPPTCL	Intra state	315
16	220/33 kV Deosane SS (2nd T/F)	220/33	MSETCL	Intra state	50
17	220 kV Jalna (Aug.)(late reported, (commissioned in April-2026)	220/132	MSETCL	Intra state	200
18	220/33 kV GSS Parjang	220/33	OPTCL	Intra state	40
19	Selaqui, Dehradun GIS (2x 50 MVA)	220/33	PTCUL	Intra state	100
20	400 kV GSS Ajmer (District: Ajmer) (Aug.)(Additional 500 MVA)	400/220	RRVPNL	Intra state	500

Sl No	Name of Sub Stations	Voltage Ratio (kV/kV)	Executing Agency	ISTS/Intra state	Capacity (MW/MVA)
1.	2.	3.	4.		6.
21	220 kV GSS Chainpura Chhota (District: Churu)	220/132	RRVPNL	Intra state	160
22	220 kV GSS Dausa (District: Dausa)(Aug.)(200-100 MVA)	220/132	RRVPNL	Intra state	100
23	230/110 kV Hosur SS (Aug.)(3rd 160 MVA)	230/110	TANTRANSCO	Intra state	160
24	220/132 kV SS Jagityal (Aug.) (160-100 MVA)	220/132	TGTRANSCO	Intra state	60
25	220/132 kV SS Parigi (Aug.)160-100 MVA)	220/132	TGTRANSCO	Intra state	60
26	Mahachanda 220/132 kV GIS (T/F-II)	220/132	WBSETCL	Intra state	200
Total of STATE SECTOR					3410
PRIVATE SECTOR					
27	400/220 kV, 3x500 MVA ICT augmentation (4th, 5th and 6th) at Pachora PS (Transmission system for evacuation of power from RE projects in Rajgarh (1000 MW) SEZ in Madhya Pradesh-Phase II)	400/220	G R Infra	ISTS	1500
Total of PRIVATE SECTOR					1500
Grand Total					8910