

CENTRAL ELECTRICITY AUTHORITY
POWER SYSTEM WING
Power System Project Monitoring Division

Sub-Stations (220 kV and above) Commissioned/Ready for commissioning During - July 2026

As on 31-July-2026

Sl No	Name of Sub Stations	Voltage Ratio (kV/kV)	Executing Agency	ISTS/Intra state	Capacity (MW/MVA)
1.	2.	3.	4.		6.
CENTRAL SECTOR					
1	1x500 MVA, 400/220 kV ICT- 1 at Jabalpur PS under Project: Western Region Expansion Scheme XXXIII Part A (WRES-XXXIII Part A)	400/220	PGCIL	ISTS	500
2	2x500 MVA, 400/220 kV ICT-1st & 3rd at Bikaner-III Pooling Station under Project: Transmission system for evacuation of power from Rajasthan REZ Ph-IV (Part-1) (Bikaner Complex): PART-A	400/220	PGCIL	ISTS	1000
3	1x500 MVA (4th) ICT at Hissar (PG) S/S under Project: Augmentation of transformation capacity at 400/220kV Hisar (PG) Substation in Haryana by 1x500 MVA, 400/220kV ICT (4th)	400/220	PGCIL	ISTS	500
4	1x500 MVA (7th), 400/220 kV ICTs at Tumkur (Pavagada) under Project: Augmentation of transformation capacity by 2x500MVA (7th & 8th), 400/220kV ICTs at Tumkur (Pavagada) 400/220kV Pooling Station	400/220			500
5	1x1500 MVA, 765/400 kV ICT (1st) at Koppal-II (Phase- A) under Project: Transmission Scheme for integration of Renewable Energy Zone (Phase-II) in Koppal-II (Phase-A & B) and Gadag-II (Phase- A) in Karnataka	765/400	PGCIL	ISTS	1500
Total of CENTRAL SECTOR					4000
STATE SECTOR					
6	Semariya SS (2X160 MVA)	220/132	CSPTCL	Intra state	320
7	220 kV R K Puram (Aug.)	220/33/11	DTL	Intra state	100
8	220 kV Gavasad (Augmentation from 250 MVA to 360 MVA)	220/66	GETCO	Intra state	110
9	220 kV Savarkundla (Augmentation from 420 MVA to 480 MVA)	220/66	GETCO	Intra state	60
10	220 kV Substation Rewari (Aug.)	220/132	HVPNL	Intra state	100
11	Nadamanchale SS	220/110	KPTCL	Intra state	100
12	400/220 kV Huliurdurga Sub Stations (2X500 MVA)	400/220	KPTCL	Intra state	1000
13	220/66 kV Huliurdurga Sub Stations (2X100 MVA)	220/66	KPTCL	Intra state	200
14	220 kV Sayane (Aug.)	220/33	MSETCL	Intra state	50
15	220 kV Pirangut (Aug.)	220/22	MSETCL	Intra state	50
16	220 kV Bridgestone (Aug.)	220/33	MSETCL	Intra state	50
17	220 kV Sawangi (Replacement) 1x (50-25) MVA	220/33	MSETCL	Intra state	25
18	220 kV Mahape (Replacement) 1x (100-50) MVA	220/22-22	MSETCL	Intra state	50
19	220/33 kV GSS Bonai (Aug.)	220/33	OPTCL	Intra state	40
20	220 kV GNDTP Bathinda s/s (Aug.)	220/66	PSTCL	Intra state	160

Sl No	Name of Sub Stations	Voltage Ratio (kV/kV)	Executing Agency	ISTS/Intra state	Capacity (MW/MVA)
1.	2.	3.	4.		6.
21	220 kV GSS Dooni (District: Tonk)(Aug.)	220/132	RRVNL	Intra state	100
22	220 kV GSS Sirohi (District: Sirohi)(Aug.)(100-50 MVA)	220/132	RRVNL	Intra state	50
23	Nallur 230/110 kV SS	230/110	TANTRANSCO	Intra state	100
24	Thuvakudy 230/110 kV SS (Aug.)(1x100 to 2x100 MVA)	230/110	TANTRANSCO	Intra state	100
25	220 kV Bhoopalapally (KTPP) SS (PTR-II)	220/132	TGTRANSCO	Intra state	100
26	400/220/132 KV SS Narsapur (Capacity Augmented from 1x100 MVA+2x160 MVA to 3x160 MVA)	220/132	TGTRANSCO	Intra state	60
27	400 kV S/s Garautha (Jhansi) (2x500 MVA T/F-II & T/F-III) (GEC-II)	400/220	UPPTCL	Intra state	1000
28	220 kV S/s Dakaur (Dakore), Jalaun (GEC-II)	220/132	UPPTCL	Intra state	160
29	220 kV S/s Bangra (Jhansi) (GEC-II)	220/132	UPPTCL	Intra state	160
	Total of STATE SECTOR				4245
	Grand Total				8245